



COUNCIL AGENDA

Monday, August 11, 2025
4:00 PM

	Pages
1. CALL TO ORDER	
2. DISCLOSURE OF PECUNIARY INTEREST	
3. CONFIRMATION OF THE AGENDA AND ADOPTION OF MINUTES	
3.1 Approval of Agenda Moved by: _____ Seconded by: _____ That Goderich Town Council hereby accepts the August 11, 2025, Regular Council Agenda, as presented.	
3.2 Adoption of Minutes Moved by: _____ Seconded by: _____ That Goderich Town Council hereby adopts the July 28, 2025, Regular Council Minutes, as printed.	7
4. PUBLIC MEETING(S)	
5. DELEGATIONS AND PRESENTATIONS	
5.1 Mark Nonkes, County of Huron re: Newcomer Experiences of Housing in Huron & Perth	16
5.2 Sean Pittman, Conservation and Energy Management Lead, Aladaco Consulting Inc. re: Green House Gas Reduction Pathway Feasibility Study	40
5.3 Mayor's Remarks	
5.4 Councillors' Remarks	
6. STAFF REPORTS Moved by: _____ Seconded by: _____ That the Staff Reports be received for information and the noted action be approved.	
6.1 Deanna Hastie, Director of Corporate Services/Treasurer re: Capital Project Status Report to June 30, 2025 Staff Recommendation: Receive for information	306

6.2	Deanna Hastie, Director of Corporate Services/Treasurer re: Council and Staff Expenses to June 30, 2025 Staff Recommendation: Receive for information	309
6.3	Deanna Hastie, Director of Corporate Services/Treasurer re: Direct Electronic Transfer Limit Increase Request Staff Recommendation: Concur and refer to By-Law 119 of 2025	316
6.4	Jason Dykstra, Building Services Manager/CBO re: Celtic Festival - Temporary Sign Staff Recommendation: Concur	318
6.5	Jeff Wormington, Fire Services Manager and Fire Chief re: Breathing Air Compressor Report Staff Recommendation: Concur	320
6.6	Jeff Wormington, Fire Services Manager and Fire Chief re: Q2 Staff Report Staff Recommendation: Receive for information	323
6.7	Jessica Clapp, Asset Management and Environmental Services Manager re: GHG Reduction Feasibility Study - Final Report Staff Recommendation: Concur and refer to agenda item 5.2	325
6.8	Jessica Clapp, Asset Management and Environmental Services Manager re: Public Sector Digest Citywide Decision Support Module Staff Recommendation: Concur	331
6.9	Michaela Johnston, Emergency Management Coordinator, Accessibility and Health and Safety Manager re: Enhancing Access to Spaces for Everyone Grant Staff Recommendation: Concur	334
6.10	Michaela Johnston, Emergency Management Coordinator, Accessibility and Health and Safety Manager re: Firehouse Subs Grant - Summer 2025 Staff Recommendation: Concur	337
6.11	Jenna Ujiye, Tourism and Community Development Officer re: 2025 Goderich Salt and Harvest Festival Update Staff Recommendation: Concur	339
6.12	Emma MacNeil, Tourism Events and Marketing Coordinator re: August Events Staff Recommendation: Concur	350

7. CORRESPONDENCE RECEIVED AND COPIED FOR WHICH THE DIRECTION OF COUNCIL IS REQUIRED

8. CORRESPONDENCE RECEIVED FOR INFORMATION

Moved by: _____
 Seconded by: _____
 That the correspondence be received for information.

8.1	Community Safety and Well-Being for Huron Oversight Committee - July 16, 2025 Minutes	354
8.2	Kate Krouskie re: Memorial Arena Proposal	357

8.3	North Huron Resolution re: Financial Support for Implementation of Community Safety and Well-Being Plan	359
8.4	Roderick Scapillati re: Memorial Arena Demolition	360
8.5	Michael Bennie re: Solid Fuel BBQing	362

9. CORRESPONDENCE RECEIVED AND RECOMMENDED ACTION NOTED

10. UNFINISHED BUSINESS

10.1	Jason Dykstra, Building Services Manager/Chief Building Official re: Digital sign installation at 411 Huron Road - pending	
10.2	Frank Hurkmans, Goderich Port Management Corporation re: Request for a Port of Goderich Pick-up Truck - pending	
10.3	Official Plan Amendment and Zoning By-Law Amendment Application GOD OPA 19 and Z04-25 - 110 Picton/Lawn Bowling (Town of Goderich) - pending	
10.4	GSP Group Inc. re: Goderich Memorial Arena Comprehensive Plan: Future Use Recommendations and Financial Viability Report - pending	
10.5	Recommended Motion from the Memorial Arena Task Force - pending	
10.6	B. M. Ross and Associates Limited re: North Harbour Road Trail Stairs - Tender Review - pending	

11. BY-LAWS

Moved by: _____

Seconded by: _____

That By-Law 119 of 2025, be read a first, second, and third time, collectively.

11.1	By-Law 119 of 2025 - Refer to agenda item 6.3 Being a By-law of the Corporation of the Town of Goderich authorizing the municipality to utilize the direct electronic funds transfer service offered by BMO Bank of Montreal	363
------	---	-----

12. MOTIONS AND NOTICE OF MOTIONS

- 12.1 Councillor John Thompson, Notice of Motion re: Standing Senate Committee on Agriculture and Forestry report titled "Critical Ground: Why Soil is Essential to Canada's Economic, Environmental, Human and Social Health"
- Moved by: _____
- Seconded by: _____
- Whereas the agricultural sector of Huron County depends on the health of the soils in Huron County;
- And Whereas soil erosion poses a very significant threat to the long-term health of the soils in Huron County;
- And Whereas the Town of Goderich owns some agricultural land which is an asset for the Town;
- And Whereas the Town of Goderich is committed to protecting the assets of the Town from preventable harm;
- And Whereas the Standing Senate Committee on Agriculture and Forestry published a report in 2024 titled "Critical Ground: Why Soil is Essential to Canada's Economic, Environmental, Human and Social Health" (the Report) that contained twenty-five (25) recommendations in total for the federal government;
- And Whereas, Recommendation 7 of Critical Ground stated that "The Government of Canada encourage provinces, territories, and municipalities to develop measures—as a form of land use planning—that best preserve and protect agricultural land in their jurisdictions;"
- Therefore, be it resolved that the Town of Goderich urge the Government of Canada and the Province of Ontario to commit to recognizing a sense of urgency and act accordingly in order to protect and conserve soil as per Recommendation 25;
- And Further That this motion be circulated to the following parties:
- Robert Black, Senate Standing Committee on Agriculture and Forestry
All local municipalities within Huron County
Lisa Thompson, Minister of Rural Affairs
Todd McCarthy, Minister of Environment, Conservation and Parks
Trevor Jones, Minister of Agriculture, Food and Agribusiness
Ben Lobb, Huron-Bruce MP
Julie Dabrusin, Federal Minister of Environment and Climate Change
Heath MacDonald, Federal Minister of Agriculture and Agri-Food and Rural Economic Development

13. NEW BUSINESS

Upcoming Meetings:

- Tuesday, August 12, 2025, at 1:30 PM, Mid-Huron Landfill Site Board
- Tuesday, August 12, 2025, at 2:30 PM, Mid-Huron Recycling Centre Board
- Wednesday, September 3, 2025, at 2 PM, 2027 Bi-Centennial Committee
- Thursday, September 4, 2025, at 11 AM, BIA Advertising and Events Committee
- Monday, September 8, 2025, at 4 PM, Council

14. CLOSED SESSION

In the event that Council enters into a possible Closed Session pursuant to Section 239 (2) of the Municipal Act, Council will reconvene following the Closed Session at which time the public and press may be present.

Moved by: _____

Seconded by: _____

That Council rise at ____ PM and goes into Closed Session pursuant to Section 239(2)(h), (i), (j);

And Further That Chief Administrative Officer, Janice Hallahan, Director of Legislative Services/Clerk, Andrea Fisher, Director of Corporate Services/Treasurer, Deanna Hastie, Director of Community Services, Infrastructure, and Operations, Sean Thomas, and Deputy Clerk (Records Management Clerk), Amanda Banting, remain in attendance.

14.1 Jimmy Trieu, President and Chief Executive Officer, Huron Health Systems and Gwen Devereaux, President Board of Directors, Gateway Rural Health Institute re: Physician Recruitment
(h) information explicitly supplied in confidence to the municipality or local board by Canada, a province or territory or a Crown agency of any of them;

(i) a trade secret or scientific, technical, commercial, financial or labour relations information, supplied in confidence to the municipality or local board, which, if disclosed, could reasonably be expected to prejudice significantly the competitive position or interfere significantly with the contractual or other negotiations of a person, group of persons, or organization;

(j) a trade secret or scientific, technical, commercial or financial information that belongs to the municipality or local board and has monetary value or potential monetary value.

14.2 ERTH Shareholder Special Meeting Materials
(i) a trade secret or scientific, technical, commercial, financial or labour relations information, supplied in confidence to the municipality or local board, which, if disclosed, could reasonably be expected to prejudice significantly the competitive position or interfere significantly with the contractual or other negotiations of a person, group of persons, or organization.

14.3 Minutes of the Previous Closed Session
• July 28, 2025, Closed Session Minutes

Moved by: _____

Seconded by: _____

That Goderich Town Council rise and come out of Closed Session at PM.

15. REPORTING OUT OF CLOSED SESSION

16. PUBLIC FORUM

17. CONFIRMING BY-LAW

Moved by: _____

Seconded by: _____

That leave be given to introduce By-Law No. 120 of 2025, being a By-Law to confirm the proceedings of the Goderich Town Council meeting held on August 11, 2025, and that it now be read a first, second, and third time, and finally passed this August 11, 2025.

18. ADJOURNMENT

Moved by: _____

Seconded by: _____

That Goderich Town Council does now adjourn at PM to meet again at the Regular Meeting of Council scheduled for September 8, 2025.



Council Minutes

**Monday, July 28, 2025
4:00 PM**

Present	Trevor Bazinet, Mayor Leah Noel, Deputy Mayor Allison Segeren, Councillor John Thompson, Councillor Randy Carroll, Councillor Liz Petrie, Councillor Vanessa Kelly, Councillor (Electronic participation)
Staff Present	Janice Hallahan, Chief Administrative Officer Amanda Banting, Deputy Clerk (Records Management Clerk) Deanna Hastie, Director of Corporate Services/Treasurer Sean Thomas, Director of Community Services, Infrastructure and Operations Jess Stoecker, Administrative Assistant to the Director of Legislative Services/Clerk
Staff Absent	Andrea Fisher, Director of Legislative Services/Clerk
Others Present	Matt Hoy, Goderich Legion Mike Dawson, Menesetung Bridge Association Rhea Seeger, Goderich & District Horticulture Society Laurie Moore, Public Forum

1. CALL TO ORDER

Goderich Town Council meets in Regular Session on July 28, 2025.

2. DISCLOSURE OF PECUNIARY INTEREST

2.1 Councillor Petrie

Councillor Petrie declares a pecuniary interest on agenda item 5.1, regarding the Goderich Memorial (Arena) Complex Service Club Group Proposal, as she sits on the executive of the Legion Ladies Auxiliary, which is one of the service groups that has a financial interest in the matter before Council.

2.2 Councillor Carroll

Councillor Carroll declares a pecuniary interest on agenda item 5.1, regarding the Goderich Memorial (Arena) Complex Service Club Group Proposal, as he is the Chair of the Service Club Group that is making the memorial (Arena) Complex proposal and President of the Goderich Legion.

2.3 Deputy Mayor Noel

Deputy Mayor Noel declares a pecuniary interest on agenda item 5.1, regarding the Goderich Memorial (Arena) Complex Service Club Group Proposal, as she is a member of the Rotary Club of Goderich.

2.4 Mayor Bazinet

Mayor Bazinat declares a pecuniary interest on agenda item 6.11(3), regarding the Don Johnston Memorial Baseball Tournament as he is the event organizer of the tournament to help raise funds for Goderich Minor Hockey.

3. CONFIRMATION OF THE AGENDA AND ADOPTION OF MINUTES

3.1 Approval of Agenda

Deputy Clerk Amanda Banting provides amendments to the agenda as follows:

The Mayor's and Councillors' remarks have been moved to follow today's presentations.

The presenter for the Memorial (Arena) Complex Service Club Group proposal has requested an additional 10 minutes. This request was approved.

Captain Brill's sign permit application demonstrates the size of the banners as 30" x 96", with a quantity of 3 banners on the black chain link fence at the harbour. However, Captain Brill has made a request for Council's consideration to approve a new banner size of 84" x 96" with the name of the business and phone number, as well as a picture of the boat so the public knows what size of boat to expect for the boat cruise.

Moved By: Deputy Mayor Noel

Seconded By: Councillor Thompson

That Goderich Town Council hereby accepts the July 28, 2025, Regular Council Agenda, as amended.

CARRIED

3.2 Adoption of Minutes

Moved By: Councillor Petrie

Seconded By: Councillor Carroll

That Goderich Town Council hereby adopts the July 7, 2025, Regular Council Minutes, as printed.

CARRIED

4. PUBLIC MEETING(S)

5. DELEGATIONS AND PRESENTATIONS

5.1 Matt Hoy, Goderich Legion re: Goderich Memorial (Arena) Complex Service Club Group Proposal

Deputy Mayor Noel declared a conflict on this item.

Councillor Carroll declared a conflict on this item.

Councillor Petrie declared a conflict on this item.

Following discussion;

Moved By: Councillor Segeren

Seconded By: Councillor Thompson

That Goderich Town Council receives the presentation from the Goderich Memorial Complex Service Club Group surrounding their Letter of Intent, for information;

And Further That Council directs the Mayor and staff to begin negotiations regarding a long-term and operational agreement for the day-to-day management of the Goderich Memorial Complex, as outlined in the Letter of Intent.

CARRIED

- 5.2 Mike Dawson and Rhea Seeger re: Proposal for a Pollinator Friendly Garden and a Trail Head for the Tiger-Dunlop Heritage Trail, Maitland Trail, G2G Rail Trail and the Trans Canada Trail

Following discussion;

Moved By: Deputy Mayor Noel

Seconded By: Councillor Carroll

That Goderich Town Council supports in principle the Goderich Horticultural Society's proposal for a Pollinator Friendly Garden at the Mineral Springs;

And That the Goderich Horticultural Society works with Town staff on native perennial plantings at the Mineral Springs;

And Further That the matter be referred to the Municipal Marine and Heritage Committee at their September 24, 2025, meeting.

CARRIED

Moved By: Councillor Petrie

Seconded By: Councillor Thompson

That Goderich Town Council receives the Trail Head proposal for information;

And That the Town staff facilitates a meeting in the fall of 2025 with representatives from the Municipal Marine & Heritage Committee, Menesetung Bridge Association, Maitland Trail, G2G Rail Trail, and Trans Canada Trail stakeholders to review the Trail Head proposal.

CARRIED

- 5.3 Mayor's Remarks

- 5.4 Councillors' Remarks

6. STAFF REPORTS

Moved By: Councillor Petrie

Seconded By: Councillor Segeren

That the Staff Reports be received for information and the noted action be approved.

CARRIED

- 6.1 Andrea Fisher, Director of Legislative Services/Clerk re: Telephone and Internet Voting Service Provider for the 2026 Election - Request for Proposal Results

Staff Recommendation: Concur

- 6.2 Deanna Hastie, Director of Corporate Services/Treasurer re: Waterfront Revenue to June 30, 2025

Staff Recommendation: Receive for information

- 6.3 Deanna Hastie, Director of Corporate Services/Treasurer re: Hydro Investment Reserve

Staff Recommendation: Concur

- 6.4 Deanna Hastie, Director of Corporate Services/Treasurer re: Letter of Credit Policy

Staff Recommendation: Concur and refer to By-Law 114 of 2025

- 6.5 Bonnie Hastings, Childcare Services Manager re: Childcare Closure - October 24, 2025

Staff Recommendation: Concur

- 6.6 Bonnie Hastings, Childcare Services Manager re: June Month-End Report

Staff Recommendation: Receive for information

- 6.7 Jason Dykstra, Building Services Manager/Chief Building Official re: June Month-End Report

Staff Recommendation: Receive for information

- 6.8 Jason Dykstra, Building Services Manager/Chief Building Official re: Heritage Permit Application No. 2025-014 - 61 Hamilton Street

Staff Recommendation: Concur

- 6.9 Jason Dykstra, Building Services Manager/Chief Building Official re: Signage for 270 Harbour Road - Captain Mike Brill

Staff Recommendation: Concur

- 6.10 Kyle Williams, Operations and Community Services Manager re: Ice Allocation Policy

Staff Recommendation: Concur and refer to By-Law 115 of 2025

- 6.11 Emma MacNeil, Tourism Events and Marketing Coordinator re: July Events

Staff Recommendation: Concur and refer to By-Laws 116 and 117 of 2025

Mayor Bazinet declared a conflict on item #3 of this report.

Moved By: Councillor Carroll

Seconded By: Deputy Mayor Noel

That Goderich Town Council concurs with Emma MacNeil's July Events report.

CARRIED

7. CORRESPONDENCE RECEIVED AND COPIED FOR WHICH THE DIRECTION OF COUNCIL IS REQUIRED

8. CORRESPONDENCE RECEIVED FOR INFORMATION

Moved By: Councillor Petrie
Seconded By: Councillor Segeren

That the correspondence be received for information.

CARRIED

- 8.1 Huron OPP Detachment Board - March 24, 2025 Minutes
- 8.2 Maitland Conservation Authority - April 16, 2025 Minutes
- 8.3 Mid-Huron Landfill Site Board - May 15, 2025 Minutes
- 8.4 Mid-Huron Recycling Centre Board - May 15, 2025 Minutes
- 8.5 Maitland Valley Conservation Authority - May 21, 2025 Minutes
- 8.6 Business Improvement Area Board of Management - June 12, 2025 Minutes
- 8.7 Township of Puslinch re: Support Resolution - Ban Nazi Swastika in Canada
- 8.8 Town of Aylmer re: Support Resolution - Advocacy for Increased Income Support Thresholds for Canadian Veterans
- 8.9 Hon. Rob Black, Standing Senate Committee on Agriculture and Forestry re: Support Resolution - Soil Health in Canada - refer to agenda item 12.1
- 8.10 Township of Otonabee-South Monaghan re: Support Resolution - Proceeds of Crime (Money Laundering) and Terrorist Financing Act
- 8.11 Community Living re: Insight Newsletter for July
- 8.12 Grey Bruce OPP Detachment Board re: Appeal to the Ministry of the Solicitor General for Reinstatement of Provincial Funding
- 8.13 Town of Kingsville re: Support Resolution - Opposition to Bill 17, Protect Ontario by Building Faster Act, 2025

Moved By: Councillor Petrie
Seconded By: Councillor Thompson

That Goderich Town Council supports the resolution from the Town of Kingsville regarding the opposition of Bill 17, Protect Ontario by Building Faster Act, 2025.

CARRIED

9. CORRESPONDENCE RECEIVED AND RECOMMENDED ACTION NOTED

Moved By: Councillor Carroll
Seconded By: Councillor Segeren

That the correspondence items be received for information and the noted action be approved.

CARRIED

- 9.1 Maitland Inlet Marina Ltd. re: 2026 Dredging Proposal

Staff Recommendation: That the Mayor and Clerk sign the Evidence of Notification for Dredging for 2026

- 9.2 Hanna Holman, Planner re: Part Lot Control Exemption Application GOD PLC02-2025 - 167-169 Elgin Ave E and GOD PLC03-2025 - 171-173 Elgin Ave E

Staff Recommendation: Concur and refer to By-Laws 112 and 113 of 2025

- 9.3 Michael Brill re: Boat Cruise Banners Sign Request

Staff Recommendation: Refer to Item 6.9

Moved By: Councillor Thompson

Seconded By: Councillor Segeren

That Goderich Town Council defers Michael Brill's additional banner sign requests regarding the approval of a new banner size of 84" x 96" with the name of the business and phone number, as well as a picture of the boat.

WITHDRAWN

Due to additional information provided by Chief Administrative Officer Hallahan, this motion was withdrawn.

10. UNFINISHED BUSINESS

- 10.1 Kyle Williams, Community Services and Operations Manager re: Ice Allocation Policy - refer to agenda item 6.10 and By-Law 115 of 2025 - remove
- 10.2 Jason Dykstra, Building Services Manager/Chief Building Official re: Digital sign installation at 411 Huron Road - pending
- 10.3 Frank Hurkmans, Goderich Port Management Corporation re: Request for a Port of Goderich Pick-up Truck - pending
- 10.4 Official Plan Amendment and Zoning By-Law Amendment Application GOD OPA 19 and Z04-25 - 110 Picton/Lawn Bowling (Town of Goderich) - pending
- 10.5 GSP Group Inc. re: Goderich Memorial Arena Comprehensive Plan: Future Use Recommendations and Financial Viability Report - pending - Refer to Item 5.3
- 10.6 Recommended Motion from the Memorial Arena Task Force - pending - Refer to Item 5.3
- 10.7 B. M. Ross and Associates Limited re: North Harbour Road Trail Stairs - Tender Review - pending

11. BY-LAWS

Moved By: Councillor Segeren

Seconded By: Councillor Thompson

That By-Laws 110, 111, 112, 113, 114, 115, 116 and 117 of 2025, be read a first, second, and third time, collectively.

CARRIED

- 11.1 By-Law 110 of 2025

Being a By-Law to authorize the Mayor and Clerk to execute and affix the Corporate Seal to a Confidentiality Agreement between Bluewater Office Equipment Limited and the Corporation of the Town of Goderich

- 11.2 By-Law 111 of 2025

Being a By-Law to authorize the Mayor and Clerk to execute and affix the Corporate Seal to a Heat Relief Strategy Policy for the Corporation of the Town of Goderich

11.3 By-Law 112 of 2025 - refer to agenda item 9.2

Being a By-Law to declare that certain land is not subject to Part Lot Control (Parts 1 and 2, Plan 22R-7504, Town of Goderich, County of Huron)

11.4 By-Law 113 of 2025 - refer to agenda item 9.2

Being a By-Law to declare that certain land is not subject to Part Lot Control (Parts 1 and 2, Plan 22R-7503, Town of Goderich, County of Huron)

11.5 By-Law 114 of 2025 - refer to agenda item 6.4

Being a By-Law to authorize the Mayor and Clerk to execute and affix the Corporate Seal to a Letter of Credit Policy for the Corporation of the Town of Goderich

11.6 By-Law 115 of 2025 - refer to agenda item 6.10

Being a By-Law to authorize the Mayor and Clerk to execute and affix the Corporate Seal to an Ice Allocation Policy for the Maitland Recreation Centre for the Corporation of the Town of Goderich

11.7 By-Law 116 of 2025 - refer to agenda item 6.11

Being a By-Law to authorize the Mayor and Clerk to execute and affix the Corporate Seal to a Standard Rental Agreement between The Corporation of the Town of Goderich and Grand River Party Rentals Incorporated for entertainment at the Salt and Harvest Festival

11.8 By-Law 117 of 2025 - refer to agenda item 6.11

Being a By-Law to authorize the Mayor and Clerk to execute and affix the Corporate Seal to a 2025 Rental Agreement between the Corporation of the Town of Goderich and Mildmay Tent Rentals Limited for the purpose of a tent rental for the Salt and Harvest Festival

12. MOTIONS AND NOTICE OF MOTIONS

12.1 Councillor John Thompson, Notice of Motion re: Standing Senate Committee on Agriculture and Forestry published a report in 2024 titled "Critical Ground: Why Soil is Essential to Canada's Economic, Environmental, Human and Social Health"

Whereas the agricultural sector of Huron County depends on the health of the soils in Huron County;

And Whereas soil erosion poses a very significant threat to the long-term health of the soils in Huron County;

And Whereas the Town of Goderich owns some agricultural land which is an asset for the Town;

And Whereas the Town of Goderich is committed to protecting the assets of the Town from preventable harm;

And Whereas the Standing Senate Committee on Agriculture and Forestry published a report in 2024 titled "Critical Ground: Why Soil is Essential to

Canada's Economic, Environmental, Human and Social Health" (the Report) that contained twenty-five (25) recommendations in total for the federal government;

And Whereas, Recommendation 7 of Critical Ground stated that "The Government of Canada encourage provinces, territories, and municipalities to develop measures—as a form of land use planning—that best preserve and protect agricultural land in their jurisdictions;"

Therefore, be it resolved that the Town of Goderich urge the Government of Canada and the Province of Ontario to commit to recognizing a sense of urgency and act accordingly in order to protect and conserve soil as per Recommendation 25;

And Further That this motion be circulated to the following parties:

Robert Black, Senate Standing Committee on Agriculture and Forestry
All local municipalities within Huron County
Lisa Thompson, Minister of Rural Affairs
Todd McCarthy, Minister of Environment, Conservation and Parks
Trevor Jones, Minister of Agriculture, Food and Agribusiness
Ben Lobb, Huron-Bruce MP
Julie Dabrusin, Federal Minister of Environment and Climate Change
Heath MacDonald, Federal Minister of Agriculture and Agri-Food and Rural Economic Development

13. NEW BUSINESS

Upcoming Meetings:

- Monday, August 11, 2025, at 4 PM, Council

14. CLOSED SESSION

In the event that Council enters into a possible Closed Session pursuant to Section 239 (2) of the Municipal Act, Council will reconvene following the Closed Session at which time the public and press may be present.

Moved By: Councillor Carroll

Seconded By: Councillor Petrie

That Goderich Town Council rise at 5:36 PM and go into Closed Session pursuant to Section 239(2)(d);

And Further That the Chief Administrative Officer, Janice Hallahan, Director of Corporate Services/Treasurer, Deanna Hastie, Director of Community Services, Infrastructure, and Operations, Sean Thomas, Deputy Clerk (Records Management Clerk), Amanda Banting, and Administrative Assistant to the Director of Legislative Services/Clerk, Jess Stoecker, remain in attendance.

CARRIED

14.1 Collective Bargaining Minutes of Settlement

Section 239(d) labour relations or employee negotiations.

14.2 Minutes of the Previous Closed Session

- July 7, 2025, Closed Session Minutes

Moved By: Councillor Carroll

Seconded By: Councillor Petrie

That Goderich Town Council rise and come out of Closed Session at 5:51 PM.

CARRIED

15. REPORTING OUT OF CLOSED SESSION

Chief Administrative Officer, Janice Hallahan, reports out of Closed Session regarding agenda items 14.1 and 14.2. The minutes of July 7, 2025, were approved, and Council discussed information surrounding the collective bargaining negotiations, along with the corresponding Minutes of Settlement. CAO Hallahan asked Deputy Clerk, Amanda Banting, to bring forward a suggested motion on this matter for Council’s consideration.

Deputy Clerk Amanda Banting reads the following motion;

Moved By: Councillor Petrie
Seconded By: Councillor Segeren

That the negotiated 4-year Collective Agreement for the period of May 1, 2025, to April 30, 2029, between CUPE and its Local 4907 and the Town of Goderich be approved.

CARRIED

16. PUBLIC FORUM

Laurie Moore comments on the Goderich Memorial (Area) Complex Service Club Group proposal.

17. CONFIRMING BY-LAW

Moved By: Councillor Segeren
Seconded By: Councillor Carroll

That leave be given to introduce By-Law No. 118 of 2025 being a By-Law to confirm the proceedings of the Goderich Town Council Meeting held on July 28, 2025, and that it now be read a first, second, and third time, and finally passed this July 28, 2025.

CARRIED

18. ADJOURNMENT

Moved By: Councillor Petrie
Seconded By: Deputy Mayor Noel

That Goderich Town Council does now adjourn at 5:57 PM to meet again at the Regular Meeting of Council scheduled for August 11, 2025.

CARRIED

MAYOR, Trevor Bazinet

DEPUTY CLERK, Amanda Banting

Newcomer experiences of housing in **Huron & Perth**

A research study

 County of Huron | Immigration Partnership
Email: home@huroncounty.ca
www.HuronCounty.ca/immigration-partnership

Funded by:  Immigration, Refugees and Citizenship Canada
Financé par : Immigration, Réfugiés et Citoyenneté Canada



 Perth County
Cultivating Opportunity

A Research Working Group project of the
Huron County Immigration Partnership



Why study newcomer experiences of housing?

- No fall-back, they don't have family/friends to go back to.
- Lack of credit or rental history
- Understanding experiences of diverse groups allows decision-makers to keep things in mind like development, infill planning
- Representation from different groups is important to break down barriers to enhance people settling in a community
- Lack of knowledge of local rental market or housing support available
- Rural areas often rely on social connection referrals for rentals. Newcomers may not have those networks.
- Newcomers may face housing barriers (xenophobia/racism) that others don't

Study background

- Finding an affordable place to live was a top challenge for immigrants - 2023 Huron-Perth Immigrant Survey
- Little information available about rural immigrant experiences of housing across Canada
- Housing has significant impact on overall settlement outcomes

Designed a qualitative study

Dr. Rana Telfah designed & conducted a focus group research project

Research questions:

- Is housing adequate, accessible, and affordable for immigrant and newcomer families in Huron and Perth counties?
- How is housing information and resources accessed?
- How do housing experiences increase newcomers' feelings of belonging and being part of the community?

Designed a qualitative study

Organized:

- 4 Focus groups
- In 4 communities
- Goal of 30-50 participants

Developed 13 questions, 1.5 hours each

Questions designed in partnership with
Research Working Group

Inclusion/exclusion criteria for participants

Include specifically:

- Newcomers – people who arrived in Canada in 2018 or after
- Live in Huron or Perth
- Live in a community of less than 10,000

Participants



40 people participated in focus groups

- 17 Listowel
- 10 Goderich
- 8 St. Marys
- 5 Exeter

63% female | 38% male

Country of origin

- | | |
|-----------------|-----------------|
| • 15 Ukraine | • 3 Ghana |
| • 5 Philippines | • 2 Guatemala |
| • 5 Mexico | • 1 Iran |
| • 4 Syria | • 1 Russia |
| • 3 India | • 1 Ivory Coast |

Participants



All participants rented

- **23** in houses
- **17** in apartment buildings

31 participants live with children in their home

Year arrived in Canada

- | | |
|-----------|---------------------|
| • 3 2024 | • 1 2019 |
| • 16 2023 | • 1 2018 |
| • 7 2022 | • 1 2017 |
| • 3 2021 | • 4 Didn't disclose |
| • 4 2020 | |

Finding 1: Housing is just one part of settlement experiences

- Entwined with employment & transportation

Other connections impacting housing for newcomers

- English language classes
- Education for children
- Access to health care
- Applicable programs community libraries
- Proximity of grocery stores

Finding 1: Housing is linked to transportation and employment

“Since I do not drive, I cannot move around easily. After searching, I found a one-bedroom apartment in Goderich that cost \$1,400. As a foreign worker with a limited salary, that is just too much for me. Thankfully, a family offered a room in their home which is much more affordable than the other places in Goderich. While renting in the town itself is expensive, options outside of it are significantly cheaper and more reasonable.” - Goderich participant

Finding 2: Newcomers face multiple barriers to housing

- 48% paid more than 30% of their monthly income on rent
- Worst impacted are people fleeing war (many pay 40-80% of income) on housing

“60% of my income goes to rent. It varies depending on how many hours I worked in the previous month.”

- Exeter participant

Finding 2: Newcomers face multiple barriers to housing

Lack of credit history in Canada limits options

- Canadian guarantor required for many rentals, requires newcomers to rely on Canadian contacts

Lengthy wait times after submitting application

- Often wait 2-4 months to find out if application is successful or rejected

Larger families struggle to find a place to rent


Finding 2: Solution to housing barriers

Shared housing to save money

- Living with roommates allowed 8 participants to allocate only 20-30% of their monthly income to housing

Employers who assist newcomers find a place to live help them reduce stress

Finding 3: Multiple moves



Finding 4: Suitable housing determinants

- ☐ Enough bedrooms
- ☐ Enough bathrooms
- ☐ Place where everyone has privacy
- ☐ People can express themselves freely

Finding 5:

Housing conditions vary

- 7 participants lived in houses that were in good condition and renovated
- 4 participants highlighted challenges with older buildings
- Repair requests can meet delays
- Shared laundry can be difficult to access, with equipment in various states of repair

Finding 6: Landlord-tenant relationships vary


- Responsiveness to requests is considered a hallmark of a good landlord
- Concern about some landlord's views about immigrants

“My husband found a house and he paid the first and the end of the rent. After two days they called my husband and said just you are welcome in there (not me or my child). They said ‘We are not sure you can afford this or manage all of the costs’. So we couldn’t rent the house, even though my husband offered to pay for six months of the rent.”

– Goderich participant

Finding 7: Finding a place to live – information sources

- In person connections
- Using social media and the internet
- Real estate agents




Finding 7: Finding a place to live – information gaps

- No access of official information sources
- Not familiar with government supports for affordable housing
- Lack of knowledge of tenant rights
- 22 people stated there was **not** enough information about housing in Huron and Perth for newcomers


Finding 8: Newcomers appreciate small communities

- 33 out of 40 felt accepted
- Slower pace, connection to nature, feeling safe appreciated




Finding 9: Newcomers find local residents helpful & friendly

- Described locals as welcoming, generous, empathetic and willing to help by sharing information
- Praised volunteers and neighbours who supported their adjustment to their new surroundings



Finding 10: People unsure if they will stay

- Housing affordability and proximity to essential services a key deciding factor
- Many who wished to stay hoped to purchase their own home
- Need for permanent residency required
- Limited job options also a factor in people hoping to stay



Now that we know...

- Organized meetings with immigrant service providers, community organizations and housing focused organizations to identify solutions
- Planning consultations with newcomers to share research findings and identify additional solutions
- Working towards developing a second publication to highlight ways newcomer experiences of housing can be strengthened locally

Community conversations

- Reviewing the findings
- Sharing experiences
- Brainstorming ideas

Community conversation dates:

- July 22: Goderich library
- August 7: North Perth library, Listowel
- August 13: Exeter library
- St. Marys still being confirmed

Aladaco Consulting Inc.

Town of Goderich GHG Reduction Pathway Feasibility Study



Agenda



GHG REDUCTION
PATHWAYS AND TARGETS



STUDY REVIEW PROCESS
AND STAFF ENGAGEMENT



DECARBONIZATION
MEASURES ANALYZED



PATHWAY SELECTIONS, KEY
METRICS, AND RESULTS



GHG Reduction Pathways

A FCM Funded Study to identify a sequence of GHG reduction measures that reduce GHG emissions for municipally owned facilities. Funding requires that the pathways achieve the following targets from the 2019 baseline regardless of capital or operating cost constraints:

- **Minimum Performance:** 50% reduction in 10 years, 80% in 20 years
- **Aggressive Deep Retrofit:** 50% reduction in 5 years, 80% in 20 years
- **Business-As-Usual:** Like-for-like replacements with existing specs




GHG Reduction Pathways




Decarbonization Measures include efficiency improvements, air & water source heat pumps (ASHP/WSHP), Electrification of fossil fuel heating equipment, and renewable energy.

Study Review Process



Grid Emissions Factor: A Key Assumption

Ontario Average Emissions Factors
(gCO₂e/kWh)




MRC Decarbonization Measures

Measures	Annual Utility Savings	GHG Savings (tCO ₂ e)	Implementation Cost	Net-Present Value	Simple Payback
Geothermal System Recommissioning	\$5,124	2.9	\$21,500	\$21,705	4.4
BAS Recommissioning	\$7,016	10.8	\$18,060	\$47,264	2.9
ASHP HRUs & MUA	-\$13,265	52.1	\$603,909	-\$746,191	-45.8
ASHP Dehumidifier (DH-3)	-\$41,125	65.3	\$1,037,910	-\$1,593,429	-25.3
WSHP Boilers	-\$32,464	121.2	\$2,721,424	-\$2,582,732	-84.0
Electrification of Unit Heaters	-\$2,238	4.2	\$20,996	-\$48,470	-9.4
Solar PV Panels	\$60,000	33.8	\$756,225	\$410,923	12.7



MRC GHG Reduction Pathways



MRC Pathway Metrics

Metric	Minimum Performance	Aggressive Deep Retrofit	BAU (Baseline)
Capital Cost	\$6,313,490	\$5,532,788	\$2,208,394
External Funding	\$1,294,266	\$1,383,197	-
BAU Avoided Costs	\$2,208,394	\$2,208,394	
Residual Value at Study End	\$1,757,764	\$707,148	\$397,994
Incremental Costs	\$2,810,831	\$1,941,196	-
Operating Costs	\$11,572,724	\$11,725,763	\$10,472,299
5-year GHG Reduction (tCO ₂ e)	-23 (-5.7%)	202 (50.9%)	-
10-year GHG Reduction (tCO ₂ e)	203 (51.3%)	299 (75.3%)	-
20-year GHG Reduction (tCO ₂ e)	330 (83.3%)	345 (86.9%)	-
Incremental LC Cost (20-year)	\$2,551,485	\$2,885,506	-
Cost per tonne CO ₂ e abated (\$ILCC/tCO ₂ e)	\$386	\$419	-

Measure Description	Min Performance Year	Aggressive Deep Retrofit Year
Geothermal Recommissioning	2025	2025
Water-Source Heat Pump Boilers	2034	2029
BAS Recommissioning	2025	2026
Air-source Heat Pump HRUs & MAU	2028	2027
Air-source Heat Pump DH3	2044	2028
Electrify UHs		2044
Solar PV Panels	2032	2027




WWTP Decarbonization Measures

Measures	Annual Utility Savings	GHG Savings (tCO _{2e})	Implementation Cost	Net-Present Value	Simple Payback
Reduce Exhaust Area for Filter Press	\$1,218	0.6	\$2,668	\$1,256	3.0
Replace Aerators with Aeration Blowers	\$15,425	7.5	\$265,936	-\$49,307	17.5
Thermostat Upgrades	\$5,119	6.7	\$4,290	\$97,464	0.9
Electrification of MUA	-\$523	0.2	\$36,681	-\$69,316	-73.0
Electrification of Tube Heaters	-\$3,254	9.2	\$155,595	-\$190,014	-47.8
Solar PV Panels 260 kW DC	\$48,000	25.3	\$645,725	\$228,373	13.5
Solar PV Panels 510 kW DC	\$96,000	50.6	\$1,266,038	\$485,131	13.3



WWTP GHG Reduction Pathways

WWTP - GHG Reduction Pathways



WWTP Pathway Metrics

Metric	Minimum Performance	Aggressive Deep Retrofit	BAU (Baseline)
Capital Cost	\$1,190,016	\$1,525,183	-
External Funding	\$297,504	\$381,296	-
Residual Value at Study End	\$162,161	\$116,042	-
Operating Costs	\$1,733,395	\$679,080	\$2,836,827
20-Year Operational Cost Savings	\$1,103,432	\$2,157,747	-
20-Year LCC	\$2,463,747	\$1,706,924	-
5-year GHG Reduction (tCO ₂ e)	0 (0%)	20 (55.5%)	-
10-year GHG Reduction (tCO ₂ e)	24 (67.1%)	24 (67.2%)	-
20-year GHG Reduction (tCO ₂ e)	29 (81.5%)	32 (91.3%)	-

Measure Description	Min Performance Year	Aggressive Deep Retrofit Year
WWTP MUA Area Reduction	2026	2027
Solar PV 510 kW DC	-	2026
Aeration Blower	2030	-
Thermostat Upgrades	2026	2026
Electrification of MUA	2035	-
Electrification of Tube Heaters	2034	2044
Solar PV 260 kW DC	2026	-



RESULTS SUMMARY

Facility	Pathway Selected	Capital Cost	Operational Cost Change	Funding Available	20-Year GHG Reduction
Maitland Recreation Centre	Minimum Performance Scenario	\$6,313,490	+\$1,100,425	\$1,294,266	330 tCO ₂ e (83.3%)
Pollution Control Plant (WWTP)	Aggressive Deep Retrofit Scenario	\$1,525,183	-\$2,157,747	\$381,296	32 tCO ₂ e (91.3%)





Thank You

Questions?



Powering Progress with
Sustainable Solutions





ALADACO

Powering Progress with
Sustainable Solutions

GHG REDUCTION FEASIBILITY STUDY

Prepared For: Town of Goderich

Date: July 28, 2025

ALADACO CONSULTING INC.

6-425 Hespeler Road, Suite 378
Cambridge, ON N1R 8J6

aladaco.com

Table of Contents

Executive Summary	1
1. Introduction.....	4
1.1 Key Terms	5
2. Facility Descriptions	9
2.1 Maitland Recreation Centre	9
2.2 Building Schedule	10
2.2.1 Building Envelope.....	10
2.2.2 Ground Source Heat Pump System and Arena Refrigeration	11
2.2.3 Ventilation and Dehumidification Systems	13
2.2.4 Domestic Hot Water and Pool Water Heating	13
2.2.5 Lighting.....	13
2.2.6 Process and plug loads	14
2.3 Goderich Wastewater Treatment Plant	14
2.3.1 Building Schedule.....	15
2.3.2 Building Envelope.....	15
2.3.3 HVAC	15
2.3.4 Ventilation Systems	16
2.3.5 Domestic Hot Water Heating.....	16
2.3.6 Lighting.....	16
2.3.7 Process Loads	16
3. Historical Utility Data.....	19
3.1 Energy and GHG Factors	19
3.1.1 Future Grid Emission Factors.....	19
3.2 Maitland Recreation Centre	20
3.2.1 Electricity	22
3.2.2 Natural Gas.....	22
3.2.3 Utility Rate Structures	23
3.2.4 Benchmarking	24
3.2.5 Target and Savings Estimate.....	25
3.2.6 End-use breakdown.....	27

3.3	Goderich Wastewater Treatment Plant	28
3.3.1	Electricity	29
3.3.2	Natural Gas.....	30
3.3.3	Utility Rate Structures	31
3.3.4	Benchmarking	31
3.3.5	Target and Savings Estimate.....	32
3.3.6	End-use breakdown.....	34
4.	Workshop Summaries	35
4.1	Design Workshop	35
4.2	Decision-making Workshop	35
5.	Measures Level Analysis.....	36
5.1	Maitland Recreation Centre Recommended Measures	37
5.1.1	ECM – Recommissioning of the Geothermal Systems.....	37
5.1.2	ECM – Recommissioning of the BAS and Related Systems	39
5.1.3	ECM – Install Water-Source Heat Pump Boilers.....	42
5.1.4	ECM – Electrification of HRU's and MAU	43
5.1.5	ECM – Electrification of DH3	45
5.1.6	ECM – Electrification of Unit Heaters.....	46
5.1.7	ECM – Install Rooftop Solar PV System.....	48
5.2	Goderich Wastewater Treatment Plant Recommended Measures	50
5.2.1	ECM – Thermostat Upgrades	50
5.2.2	ECM – Electrification of the MAU	52
5.2.3	ECM – Electrification of Tube Heaters.....	54
5.2.4	ECM – Reduce Exhaust Area for Filter Press	56
5.2.5	ECM – Install Aeration Blower	58
5.2.6	ECM – Install Ground Mount Solar PV System 260 kW DC	60
5.2.7	ECM – Install Ground Mount Solar PV System 510 kW DC	61
5.2.8	Low or No-Cost Additional Recommendations.....	62
5.3	Energy modelling approach	63
5.4	Embodied Carbon Impacts.....	64
6.	GHG Reduction Pathway Capital Plan	66
6.1	MRC Pathway Analyses	67
6.2	WWTP Pathway Analyses	69

6.3	Recommended Pathways for Implementation	71
6.3.1	Maitland Recreation Centre.....	71
6.3.2	Wastewater Treatment Plant	72
7.	Demand Forecasts	73
7.1	Maitland Recreation Centre	73
7.2	Wastewater Treatment Plant	73
8.	Conclusion	74
	Appendices.....	75
	Appendix A: Design Workshop Summary Report.....	75
	Appendix B: Calculations	76
	Appendix C: Disqualified ECMs.....	96
	Appendix D: Schematics	106
	Appendix E: Decision Making Workshop	108
	Appendix F: Sensitivity Analysis.....	109
	Appendix G: Energy Model Documentation	113
	Appendix H: References.....	135

Table of Figures

Figure 1: The Maitland Recreation Centre, 190 Suncoast Drive East	9
Figure 2: Water to Water Source Heat Pump Design Drawing	12
Figure 3: As-Built Pool Make Up Water Pre-Heat	12
Figure 4: The Goderich Wastewater Treatment Plant, 211 Sunset drive	14
Figure 5: WWTP Process Schematic	17
Figure 6: Grid Emission Factors	20
Figure 7: MRC 2023 Utility Costs	21
Figure 8: MRC 2023 Emissions.....	21
Figure 9: MRC Annual Electrical Consumption.....	22
Figure 10: MRC Annual Natural Gas Use	23
Figure 11: Maitland Recreation Centre Benchmarking.....	24
Figure 12: MRC Energy End-use Breakdown	27
Figure 13: WWTP 2023 Utility Costs	28
Figure 14: WWTP 2023 Emissions.....	29
Figure 15: WWTP Annual Electrical Consumption	29
Figure 16: WWTP Annual Natural Gas Use	30
Figure 17: Goderich WWTP Benchmarking	31
Figure 18: WWTP Energy End-use Breakdown.....	34
Figure 19: MRC BAS Ground Temperature Reading	41
Figure 20: WWTP Existing HVAC Controls	51
Figure 21: MRC Pathways Results	67
Figure 22: WWTP Pathways Results	69
Figure 23: Pool Circulation Pump Control Valve	97
Figure 24: WWTP Control Room Curtain Wall.....	104

Table of Tables

Table 1: MRC Occupancy Schedules	10
Table 2: WWTP Occupancy Schedules	15
Table 3: 2023 MRC Energy Consumption Summary	21
Table 4: MRC Baseline and Target Emissions (tCO ₂ e)	25
Table 5: Baseline and Target GHGI for MRC	26
Table 6: 2023 WWTP Energy Consumption Summary	28
Table 7: WWTP Baseline and Target Emissions (tCO ₂ e)	33
Table 8: Baseline and Target GHGI for WWTP	33
Table 9: MRC Pathways Results	67
Table 10: MRC Recommended ECMs	68
Table 11: WWTP Pathways Results	69
Table 12: WWTP Recommended ECMs	70
Table 13: MRC Modelled Pathway Consumption Results	71
Table 14: WWTP Modelled Pathway Consumption Results	72
Table 14: MRC Current and Future Demand Forecasts	73
Table 15: WWTP Current and Future Demand Forecasts	73

Executive Summary


This Greenhouse Gas (GHG) Reduction Feasibility Study evaluates opportunities for reducing GHG emissions at two key municipal facilities within the Town of Goderich: the Maitland Recreation Centre (MRC) and the Goderich Wastewater Treatment Plant (WWTP). The study explores targeted retrofit strategies, assessing multiple pathways and meeting the targets prescribed by the Federation of Canadian Municipalities GHG Reduction Pathways feasibility study funding. The pathways studied include:

- **A Minimum Performance Scenario:** Achieve at least 50% GHG reduction by year 10 and at least 80% GHG reduction by year 2045, and
- **An Aggressive Deep Retrofit Scenario:** Achieve 50% GHG reduction within 5 years and at least 80% GHG reduction by 2045

Facility-specific benchmarking analyses provided context for energy performance. The MRC currently operates with an Energy Use Intensity (EUI) significantly above national benchmarks for similar recreation facilities, largely due to its year-round arena operation. The WWTP, in contrast, performs better than provincial benchmarks, with an EUI approximately 60% lower than comparable wastewater facilities in Ontario.

Maitland Recreation Centre

Both the Minimum Performance and Aggressive Deep Retrofit pathways assessed for the MRC meet or exceed the Town's 80% emissions reduction target by 2045. The Minimum Performance Scenario aligns capital investments closely with natural equipment replacement cycles, reducing upfront financial impacts, while the Aggressive Deep Retrofit Scenario accelerates the timeline for deeper short-term reductions, enhancing operational resilience and energy independence.



The following table highlights the key metrics related to the modeled GHG Reduction Pathways and the Business As Usual Scenario.


Metric	Minimum Performance	Aggressive Deep Retrofit	Business As Usual
Capital Cost	\$6,313,490	\$5,532,788	\$2,208,394
External Funding	\$1,294,266	\$1,383,197	-
Incremental Costs	\$2,810,831	\$1,941,196	-
Operating Costs	\$11,572,724	\$11,725,763	\$10,472,299
Incremental Life-Cycle Cost (20-year)	\$2,551,485	\$2,885,506	-

The primary measures contributing significantly to the GHG reductions at the MRC are:

- Installation of water-source heat pumps, leveraging the existing geothermal loop to offset natural gas consumption for space heating and domestic hot water.
- Electrification of air-handling equipment and unit heaters using air-source heat pumps.
- Recommissioning the existing geothermal system, a critical foundational measure enhancing system efficiency and enabling subsequent electrification projects.

Goderich Wastewater Treatment Plant

Both pathways assessed at the WWTP similarly meet or exceed the Town's GHG emissions reduction targets. The Minimum Performance Scenario achieves incremental reductions through gradual implementation of projects, while the Aggressive Deep Retrofit Scenario accelerates project timelines to achieve deeper, earlier reductions and greater operational cost savings.



The following table highlights the key metrics related to the modeled GHG Reduction Pathways and the Business As Usual Scenario.

Metric	Minimum Performance	Aggressive Deep Retrofit	Business As Usual*
Capital Cost	\$1,190,016	\$1,525,183	-
External Funding	\$297,504	\$381,296	-
Operating Costs	\$1,733,395	\$679,080	\$2,836,827
20-Year Operational Cost Savings	\$1,103,432	\$2,157,747	-
20-Year Life-Cycle Cost	\$2,463,747	\$1,706,924	-

*WWTP analysis does not contain incremental cost analysis due to the absence of a BCA

The primary measure for achieving substantial emissions reductions at the WWTP is the installation of a large-scale ground-mounted solar photovoltaic (PV) system. Additional impactful measures include electrifying natural gas-fired heating equipment with air-source heat pumps and targeted efficiency upgrades to process equipment.

Pathways Recommendations

Both the Minimum Performance and Aggressive Deep Retrofit pathways identified for the MRC and WWTP are technically viable and financially feasible, and they effectively achieve the Town's decarbonization objectives. At the MRC, operational costs are projected to increase moderately due to the focus on fuel-switching heating systems from natural gas to electricity, a cleaner but currently higher-cost energy source. This reflects the facility's already efficient operation, where further improvements primarily involve electrification rather than reduced energy usage. For the MRC, the Minimum Performance scenario is recommended, as it provides a lower life-cycle cost and moderates operating cost impacts. Conversely, for the WWTP, predominantly an electricity-consuming facility, the Aggressive Deep Retrofit scenario is recommended, as it maximizes operational cost savings through efficiency improvements and renewable energy generation.

Aladaco extends sincere gratitude to the Town of Goderich staff for their active involvement and valuable contributions throughout this project. Their practical insights, operational knowledge, and collaborative approach greatly enhanced the development of actionable and realistic solutions. We also applaud the Goderich Town Council for their continued support, leadership, and commitment to advancing sustainability and climate resilience. This feasibility study provides a robust foundation to guide informed decisions and support the Town in meeting its long-term GHG reduction and sustainability goals.

1. Introduction

This GHG Reduction Pathway Feasibility Study assesses viable strategies for reducing on-site GHG emissions from the Town of Goderich's municipal buildings. The study follows the guidance provided by the Federation of Canadian Municipalities (FCM) Community Buildings Retrofit (CBR) Initiative, which aims to help municipalities integrate energy efficiency and GHG reductions into long-term capital planning. This feasibility study is made possible through grant funding provided by the FCM CBR initiative.

The study was conducted on two buildings: the Maitland Recreation Centre (MRC) located at 190 Suncoast Drive East, Goderich, ON, and the Goderich Wastewater Treatment Plant (WWTP) located at 211 Sunset Drive, Goderich, ON. These two facilities were selected by the Town of Goderich due to their significant GHG emissions. In 2019, the Town conducted a Community and Corporate-level GHG inventory as part of FCM's Partners for Climate Protection (PCP) program Milestone 1. The results of this initiative identified the MRC and WWTP as the two largest sources of GHG emissions from municipally owned facilities. For the purposes of this report, the GHG emissions baseline values align with the 2019 emissions inventory.

The study explores multiple pathways to achieving significant GHG reductions while balancing capital investment and operational efficiency. It includes the evaluation of different retrofit scenarios to reduce on-site emissions, aligning with CBR initiative targets. Specifically, the selected pathways analyzed in this study include:

1. **Minimum Performance Scenario:**

- A 10-year roadmap achieving a minimum of **50% GHG reduction** compared to the facility's baseline emissions.
- A 20-year roadmap achieving a minimum of **80% GHG reduction** compared to baseline emissions.

2. **Aggressive Deep Retrofit Scenario:**

- Achieves 50% GHG reduction within the first 5 years, followed by additional measures to meet or exceed the 80% reduction target within 20 years.

3. **Business-As-Usual Scenario:**

- A scenario with "like-for-similar" upgrades based on the site-specific requirements of the building condition and equipment replacement schedule.

The feasibility study includes a systematic evaluation of energy conservation measures (ECMs) through the development of several energy models for each facility. It also includes capital planning considerations, operational impacts, and life cycle cost implications. Additionally, the study integrates funding opportunities to optimize project feasibility.

Throughout the study process, the Town of Goderich has been an active participant in guiding the project scope, direction, and selected pathways. Several engagement

sessions were conducted over the life of this project, beginning in October 2024, including monthly meetings between Aladaco and the Town of Goderich project leads, Design Workshops, and Decision-Making Workshops. These sessions provided a forum for in-depth discussions, technical evaluations, and alignment of the proposed strategies with municipal priorities.

Relevant stakeholders, including municipal executives and operations personnel, were actively involved in these sessions to ensure a comprehensive approach to decision-making. Their input has been incorporated into the results of this report to ensure the selected measures and pathways align with the Town's sustainability goals, operational objectives, and budgetary constraints. These discussions also helped to identify key challenges and opportunities related to implementation, ensuring that the recommendations presented in this study are both practical and effective in achieving long-term GHG reductions.

The findings will support the Town of Goderich in making informed investment decisions that contribute to its long-term sustainability goals while ensuring alignment with municipal capital planning and funding opportunities. By integrating industry best practices and aligning with national GHG reduction targets, this study provides a structured framework for achieving measurable emissions reductions and improving overall energy performance.

1.1 Key Terms

Building Automation System (BAS)

An integrated network of hardware and software that automatically monitors and controls a building's mechanical and electrical systems such as heating, ventilation, and air conditioning (HVAC), lighting, security, and energy management. Its primary goal is to optimize occupant comfort, system performance, and energy efficiency.

Building Commissioning

A systematic process that ensures a building's systems, such as HVAC, BAS, lighting, electrical, and plumbing, are designed, installed, tested, and operated according to the owner's requirements and performance expectations. The goal is to optimize the building's energy efficiency, functionality, and comfort while minimizing operational issues. Commissioning typically occurs during the design, construction, and post-construction phases and includes verification of system performance, documentation, and training for building operators. It can also be applied retroactively in existing systems.

Building Condition Assessment (BCA)

A comprehensive evaluation of the physical condition and performance of a building's structure, systems, and components. It typically involves inspecting key elements such as the foundation, roof, electrical, plumbing, HVAC systems, and interior finishes to identify any deficiencies, required repairs, or upgrades. The assessment helps in understanding

the building's current state, estimating maintenance costs, and planning for future improvements or renovations.

Business-As-Usual (BAU) Avoided Costs

Costs that would be incurred under the Business-as-Usual capital renewal plan but are avoided by selecting alternative replacement options.

Capital Cost

Refers to the initial expenditure required to acquire, construct, or set up an asset or project, such as buildings, equipment, or infrastructure. It includes all costs associated with the development or purchase, excluding ongoing operational or maintenance expenses.

Discount Rate

The interest rate used to calculate the present value of future cash flows or investments. It reflects the time value of money.

Energy Use Intensity (EUI)

Refers to the amount of energy consumed per unit of output, such as per square meter of building space or per unit of product produced. It is used to assess the energy efficiency of buildings, industries, or processes, helping to track and reduce energy consumption.

Equivalent Energy (ekWh)

A standardized unit used to compare energy consumption from different sources, typically electricity and natural gas, on a common basis. It expresses all energy use as the amount of electricity (in kilowatt-hours) that would provide the same energy content.

GHG Baseline

Refers to the measurement of greenhouse gas emissions over a specified period, representing the level of emissions before any reduction efforts are implemented. It serves as a reference point to evaluate the effectiveness of mitigation strategies and track progress toward emission reduction goals.

Greenhouse Gas Intensity (GHGI)

A metric that quantifies the amount of greenhouse gas (GHG) emissions produced per unit of building area, typically expressed in tonnes of carbon dioxide equivalent per square meter (tCO₂e/m²). It allows for a normalized comparison of emissions performance across buildings of different sizes and types.

Peak Electricity Demand (kW)

The highest rate of electricity consumption, measured in kilowatts (kW), recorded over a 15-minute period within a billing month. In Ontario, this value is shown on utility bills as the monthly peak demand and is a critical metric in determining demand charges.

Tonne of Carbon Dioxide Equivalent (tCO_{2e})

A unit of measurement used to compare the emissions of various greenhouse gases based on their global warming potential. It represents the amount of carbon dioxide that would have the same warming effect as one tonne of another greenhouse gas, such as methane or nitrous oxide.

Thermal Energy Demand Intensity (TEDI) (kWh/m²)

The annual heat loss from a building's envelope and ventilation after accounting for all passive heat gains and losses, measured in kilowatt-hours per unit of modelled floor area (kWh/m²).

Incremental Cost

The increase or decrease in the cost of construction, relative to the baseline costs outlined by the facility BCA.

Incremental Life Cycle Cost (ICCL)

The additional costs incurred when comparing two or more alternatives over their entire lifespan. It includes the extra costs of owning, operating and maintaining one option versus another, helping to evaluate the financial impact of choosing a particular solution or investment over time.

Incremental Life Cycle Cost per Tonne of Carbon Abated (\$ILCC/tCO_{2e})

The additional cost incurred to reduce one tonne of carbon dioxide (or its equivalent) emissions through a specific mitigation measure or pathway.

International Protocol for Measurement and Verification (IPMVP)

A globally recognized framework for evaluating and verifying the energy savings and performance of energy efficiency projects. Developed by the Efficiency Valuation Organization (EVO), it provides standardized methods for measuring and confirming the impact of energy conservation measures, ensuring consistency, transparency, and accuracy in reporting energy savings across different regions and sectors.

IPMVP Option A

Under IPMVP Option A, commonly called Retrofit Isolation with Key Parameter Measurement, energy savings are calculated using a mix of measured and estimated parameters. Estimates are acceptable only if their combined uncertainty is minimal or agreed upon by all parties.

IPMVP Option B

IPMVP Option B, or Retrofit Isolation with All Parameter Measurement, requires measuring all energy or demand quantities, or all key parameters used to calculate them. It is suitable for most energy efficiency measures, though complexity and cost increase with more comprehensive metering.

IPMVP Option C

IPMVP Option C uses utility, whole-facility, or sub-meter data along with independent variables to assess overall facility energy performance. It captures the combined impact of all implemented measures within the measurement boundary, including any unrelated changes that may affect energy use.

IPMVP Option D

IPMVP Option D (Calibrated Simulation) uses energy modeling software to estimate energy use when baseline data is unavailable. Savings are calculated from detailed simulations of physical systems. Accuracy depends on model quality, calibration level, and user expertise.

Life Cycle Cost (LCC)

The total cost of owning, operating, maintaining, and disposing of an asset over its entire lifespan. It includes initial capital costs, as well as ongoing expenses like maintenance and energy use, helping to assess the long-term financial impact of a project or investment.

Measurement and Verification (M&V)

A process used to quantify and confirm the actual energy savings or emission reductions achieved by a project or initiative. It involves measuring the performance of systems or processes and verifying that the claimed benefits, such as energy efficiency improvements or carbon reductions, have been realized in practice, often using established standards or protocols.

Net-Present Value (NPV)

A financial metric used to evaluate the profitability of an investment or project. It calculates the difference between the present value of cash inflows and the present value of cash outflows over a specified period, discounted at a particular rate. A positive NPV indicates a profitable investment, while a negative NPV suggests a loss.

Residual Value

The estimated amount that an asset is worth at the end of its useful life, after accounting for depreciation or wear and tear.

Simple Payback Period

The period it takes for an investment to recover its initial cost through savings or profits. It is calculated by dividing the initial investment by the annual cash inflows or savings generated by the investment.

2. Facility Descriptions

This section provides a detailed description of the Maitland Recreation Centre (MRC) and the Goderich Wastewater Treatment Plant (WWTP). The data and information presented here was either provided by the Town of Goderich or collected on-site by Aladaco staff during several site visits.

The descriptions cover key aspects relevant to energy performance and GHG reduction potential, addressing building envelope characteristics, HVAC systems, water heating, lighting, and energy-intensive equipment. These components are crucial in establishing a baseline energy model and identifying opportunities for energy efficiency improvements.

Site investigations included walkthroughs, interviews with facility staff, and a review of mechanical and electrical documentation, maintenance records, and historical utility data. This information was used to calibrate the energy models and support the evaluation of energy-saving measures. Further details on the site investigations can be found in Appendix A: Design Workshop Summary Report.

2.1 Maitland Recreation Centre

The Maitland Recreation Centre (MRC) was constructed in 2003 and is approximately 75,000 ft² (5,000 m²) in size. It is a 2-story structure containing a single ice pad arena, public pool, gymnasium, fitness centre, and community spaces. Access to the pool, gymnasium, and arena is from the main level. The upper level houses the fitness centre, a walking track, and areas for community use.

Figure 1: The Maitland Recreation Centre, 190 Suncoast Drive East



A Building Condition Assessment (BCA, 2015) was supplied to Aladaco for this facility. The BCA was leveraged to supply the expected remaining useful life (EUL) of several of the facility's components and assets. Additionally, an Asset Inventory, created and maintained by the Town of Goderich staff, was supplied to provide information about EUL and expected like-for-similar replacement costs.

2.2 Building Schedule

In consultation with site staff, the following occupancy schedules were determined for each space. It was confirmed that the facility's BAS accurately reflects these schedules, and our energy model has been calibrated to match the following:

Table 1: MRC Occupancy Schedules

Arena & Common Areas		
	Open	Close
Weekdays	5:30 AM	11:30 PM
Weekends	7:30 AM	10:00 PM
YMCA, Gymnasium, and 2 nd Level Fitness Centre		
	Open	Close
Weekdays	6:00 AM	10:00 PM
Saturdays	8:00 AM	6:00 PM
Sundays	8:00 AM	4:00 PM
Canteen		
	Open	Close
Wed-Fri Afternoons	12:00 PM	2:00 PM
Wed-Fri Evenings	4:00 PM	9:00 PM
Saturdays	8:00 AM	10:00 PM
Sundays	11:00 AM	8:00 PM

2.2.1 Building Envelope

The building construction is primarily concrete block with a brick façade which the BCA found to be in good condition. The replacement of exterior walls is expected to be outside the timeframe of this study.

Exterior windows are a double pane glazed construction with hollow metal frames. Main entrance doors are also hollow metal construction with glazing. The primary entrances

are controlled via automated openers and motion sensors. The BCA found the exterior windows and doors to be in good condition.

The roof structure is primarily open web joists with structural steel pan. Some areas of the roof are insulated 2-ply modified bitumen roofing. Some areas of the bitumen rooftop have small blisters in the roofing membrane and areas where moisture has penetrated the envelope. A Roof Condition Assessment was conducted in 2023 with destructive testing to determine the extent of the moisture ingress and damage. This assessment found that the roof requires repair in several small areas, however overall, the EUL of the existing roof will extend beyond the timeframe of this study. The Town of Goderich intends to conduct these repairs within the next 2 to 3 years of capital work and it is not expected that these repairs will result in efficiency savings.

2.2.2 Ground Source Heat Pump System and Arena Refrigeration


The HVAC system consists of 22 water-source heat pumps (WSHPs) distributed throughout the facility; all connected to a ground loop for heat rejection. This ground loop also supports the modular refrigeration system (Ice Kube heat pumps) for the arena. To supplement this system, a boiler and cooling tower are available to provide additional heating and heat rejection from the ground loop as required. The ground loop also provides in-floor heating throughout much of the facility.

The ground loop system at this facility does not operate as would be expected of a typical geothermal heating and cooling system. This is largely due to the inclusion of the Ice Kube heat pumps, which are a significant source of high-grade heat. Due to the yearlong operation of the arena and ice making equipment, a consistent supply of heat is available.

Aladaco installed independent energy meters on the Ice Kube heat pumps and the primary ground loop pumps. The existing BAS was also leveraged to provide trend data on numerous variables related to the ground loop system. The results of this analysis showed that even in the most extreme conditions (OAT < -20°C), the ground loop system continues to reject heat into the ground (i.e. the system continues to have surplus heat energy even during the coldest temperatures). A typical geothermal heating system would charge the ground source during the summer months and extract the heat energy during the heating season. Since this system always has an excess of heat, the ground serves only as a heat sink. This presents a significant opportunity to leverage more of this heat source when decarbonizing the remaining heating loads within the facility.


Additionally, when comparing the design drawings for the ground loop system and the equipment observed on-site, there are significant deviations from the original planned installation. Notably, there are four (4) water-to-water source heat pumps included in the design drawings which are absent from the built facility. These heat pumps were intended to support the heating of the domestic hot water (DHW) and the pool make-up water. An example of a missing heat pump is shown below, the equipment in this drawing does not exist.

Figure 2: Water to Water Source Heat Pump Design Drawing



The BAS screenshot below shows the as-built configuration. The ground loop has been connected directly to a heat exchanger, providing limited pre-heating of the pool make up water. BAS trending of the pre-heat temperatures (HX-01 Load-In and Load-Out) is not enabled within the system and Aladaco was unable to quantify the amount of energy supplied by HX-01.

Figure 3: As-Built Pool Make Up Water Pre-Heat



Additionally, pumps P107 and P108 were observed to be non-operational during this study. Without these pumps the efficacy of the heat exchanger is severely limited and,

for the purposes of the energy model, the energy recovery for HX-01 was considered negligible.

From engagement sessions held with Town of Goderich staff and facility operators, the reasoning for the exclusion of the additional WSHPs is not clear. It does appear, however, that the existing ground source system is likely over-sized based on the amount of excess heat energy being dissipated into the ground.

2.2.3 Ventilation and Dehumidification Systems

Ventilation air for the change rooms in both the arena (HRU-2) and pool (HRU-1) is supplied by roof-mounted air handling units equipped with DX cooling, gas heating, and exhaust air heat recovery. Mechanical details for HRU-2 were limited, as the equipment nameplate is too worn to be legible. HRU-2 was assumed to be of the same nameplate information as HRU-1 as they serve similar locations and were installed at the same time.

A dedicated roof-mounted Pool Dehumidification Unit is responsible for controlling humidity in the pool area, ensuring proper air quality and comfort levels. This unit was replaced in early 2025 and is equipped with DX cooling, natural gas heating, and a pool water reheat coil. The dehumidifier uses the waste heat from the DX cooling to aid in reheating the dehumidified air, increasing the unit's efficiency.

For the arena, two Dectron mechanical dehumidifiers manage humidity, while ventilation is facilitated through two large exhaust fans interlocked with dampers that introduce fresh air when the exhaust system is in operation. The exhaust fans operate when CO₂ levels rise above the setpoint of 650 PPM in the arena. One Dectron unit is original to the facility while the second was replaced in 2023. The newer unit is only marginally more efficient than the previous unit as the system only requires cooling of the air, with no reheat capabilities. Thus, the only efficiencies gained are found in the motor and compressor efficiencies of the new unit.

The concession stand/canteen is served by a small make-up air unit interlocked with a kitchen exhaust hood, ensuring proper ventilation during food preparation.

2.2.4 Domestic Hot Water and Pool Water Heating

The pool water is pre-heated through the ground loop but also has a dedicated boiler as a backup. A separate boiler provides heat for the whirlpool and is not connected to the ground loop. Domestic cold water is pre-heated via the ground loop and a heat exchanger prior to entering the Domestic Hot Water (DHW) boilers. One DHW boiler, B-1, is a conventional mid-efficiency atmospheric boiler, and the second, B-2, is a high-efficiency instantaneous hot water boiler. All boilers operate on natural gas to facilitate water heating.

2.2.5 Lighting

The facility's lighting consists of a mix of LED, fluorescent, and compact fluorescent fixtures. While some fixtures remain from the original 2003 construction, others have been recently upgraded. Lighting in the arena, the pool, and the gymnasium have all been

upgraded to LED models. Additionally, much of the exterior lighting has also been upgraded to LEDs, including wallpacks and parking lot lamps. The remaining fluorescent fixtures at the facility are planned to be replaced by attrition over the coming years.

2.2.6 Process and plug loads

Plug loads at MRC include common appliances found within office spaces and include refrigerators, computers and printers, televisions, and other small loads. There are several pieces of fitness equipment in the fitness centre that require power; however these are not considered significant sources of energy usage. Overall, plug-loads do not represent a significant portion of the building's total energy usage.

2.3 Goderich Wastewater Treatment Plant

The Goderich Wastewater Treatment Plant is an enclosed 367,000 square foot Class III Treatment Facility with a Class II Collection System. The wastewater treatment system was originally constructed in 1967 and has undergone many expansions. The latest expansion completed in 2009 saw the installation of the ultraviolet light (UV) disinfection system.

There are seven building structures located at the Plant, consisting of one Main Building (4,392 ft²) and 5 Auxiliary Buildings. These Auxiliary Buildings are the Blower Building (291 ft²), Primary Pumphouse #1 (592 ft²), Primary Pumphouse #2 (398 ft²), Raw Activated Sludge (RAS) Pumphouse #1 (323 ft²), RAS Pumphouse #2 (334 ft²), and Screening Building (334 ft²).

The wastewater treatment facility is owned by the Town of Goderich and operated by the Town's Operating Authority, Veolia Water. There is no BCA available for this facility.

Figure 4: The Goderich Wastewater Treatment Plant, 211 Sunset drive



2.3.1 Building Schedule

In consultation with site staff, the following occupancy schedules were determined for the WWTP.

Table 2: WWTP Occupancy Schedules

Main Building		
	Occupied	Unoccupied
Weekdays	7:00 AM	3:30 PM
Weekends	Intermittent Inspections Only	
Auxiliary Buildings		
	Open	Close
Weekdays	Intermittent Inspections Only	
Weekends		

2.3.2 Building Envelope

The Main Building at the WWTP is a mixture of concrete block construction and brick façade walls. There are several large, windowed sections on the eastern side of the building. Windows are aged and several need repairs. The primary entrance is a vestibuled single door entry. There are additional exit doors located on all sides of the building. On the northern wall is a roller bay door which allows for truck access to the interior for hauling of solid waste.

The Auxiliary Buildings vary in age and size however they are all similar constructions. The building walls are concrete block construction with several small windows and a single door. The windows are double pane and generally are in good condition, as are the doors. The roofs are flat and ballasted, except for the Screening Building which has a sloped roof with steel sheeting.

2.3.3 HVAC

The Main Building is equipped with natural gas radiant tube heaters, a make-up air unit (MAU), and a two-speed exhaust unit with an activated carbon filter (ACA Exhaust). There are also several smaller exhaust fans throughout. The radiant tube heaters provide heating throughout the Main Building and operate on wall mounted manual thermostats. The ACA Exhaust unit is primarily used to exhaust odours from the Belt Filter Press area by operating continuously at low speed. When the Belt Filter Press is in operation the ACA Exhaust operates at high speed and the MAU replenishes the exhausted air. The MAU is equipped with a natural gas heating coil. There is one small window-mounted air

conditioning unit in the Chlorine Room of the Main Building which is the only source of cooling in the facility.

All Auxiliary Buildings are heated via suspended electric unit heaters which operate on wall mounted manual thermostats. Each building has at least one small exhaust fan that operates when the interior temperature is above a specified setpoint manually set by the building staff. There are no cooling capabilities in the Auxiliary Buildings.

2.3.4 Ventilation Systems

As described in the previous section, the MAU and the ACA Exhaust systems are the primary ventilation equipment on site at the WWTP. All Auxiliary Buildings have small exhaust fans. The MAU and ACA Exhaust are controlled automatically by the WWTP's SCADA system. The ACA Exhaust operates continuously at low speed unless the Belt Filter Press is in operation. At that time the ACA Exhaust begins operating at high speed and the MAU also operates to replenish the exhaust air.

2.3.5 Domestic Hot Water Heating

There is one 38-Gal electric conventional tank hot water heater located in the Locker Room of the Main Building that is the sole source of hot water at the WWTP. The heater was installed in 2023 and is in good condition.

2.3.6 Lighting

Interior lighting in all buildings at the WWTP is a mixture of LED tubes and T8 lamps. Staff have reported an on-going initiative to replace all interior lighting with LED tubes over the next 3-5 years. Our business-as-usual scenario captures this ongoing retrofit.

Exterior lighting is a mixture of wallpacks and post lamps which have all been retrofitted to LED models.

2.3.7 Process Loads

The wastewater treatment system consists of the following primary components: a course fixed bar screen, an aerated grit tank and grit removal system, an inclined mechanical fine screen and compactor, four (4) primary clarifiers, two (2) raw sludge pumps, one (1) waste return pump, three (3) aeration tanks with two (2) mechanical aerators in each, four (4) secondary clarifiers, six (6) return activated sludge pumps, a UV disinfection system, a belt filter press, a by-pass diversion chamber and two (2) combined sewer outflow (CSO) tanks. The following schematic provides an overview of these systems.

The treatment process is controlled by the on-site SCADA system which was recently upgraded to increase control capabilities. The system responds dynamically to wastewater flows and the RAS pumps are equipped with VFDs to further modulate their operation to match system requirements. The mechanical aerators provide oxygen to the aeration tanks and operate continuously. The aerators use two speed motors which allow them to operate at either high or low speed. Speed settings are manually adjusted by site staff to meet the demands of the treatment process, which varies depending on the biological properties of the wastewater and temperature.

Aladaco has worked with site staff to collect SCADA trend data and to install on-site real-time energy metering to better understand and model these process demands.

3. Historical Utility Data

Aladaco has reviewed 36 months of utility data from the Town of Goderich for both the MRC and the WWTP. The data spans 2021 to 2023 and includes electrical and natural gas consumption and costs. The monthly data has been used to determine utility rates and to benchmark the facilities. Additionally, hourly interval data for electrical energy consumption was provided for both facilities covering all of 2023. This hourly data was used in calibrating the energy models and in determining the peak and average power consumption of the facilities.

3.1 Energy and GHG Factors

Current and future energy and GHG emission factors are unique to Ontario and have been sourced from the Canada Green Building Council's Zero Carbon Building Workbook, Version 4 (ZCB v4). The following factors are applied to 2023 annual energy consumption:


- Electricity: 0.038 kgCO₂e/kWh
- Natural Gas: 1.921 kgCO₂e/m³

3.1.1 Future Grid Emission Factors

Like the method applied to the 2023 emissions calculations, future grid emission factors are sourced from the ZCB v4 workbook. In all calculations, the date of implementation is referenced to apply the appropriate future Ontario grid emission factor.

During the Design Workshop the Town of Goderich and Aladaco staff discussed varying sources of projections for future grid emissions, and how the range of these projections could affect meeting their decarbonization goals. The chart below is a comparison between the ZCB v4 projections and those released by The Atmospheric Fund (TAF) in a 2024 study published for the IESO.

Figure 6: Grid Emission Factors



(The Atmospheric Fund, June 2024)

There is significant variation between these estimates, particularly in the first ten years, and this variation could have a significant impact on future emissions for both facilities. Included within Appendix F: Sensitivity Analysis, is a recalculation of the pathways using TAF emission factors to better understand these impacts.

At the conclusion of the Design Workshop, the decision was jointly made to adopt the ZCB v4 projections for use in the final pathways analysis due to the longer-term forecasts available from this reference. The Town of Goderich does however acknowledge that Ontario's grid emissions are likely to see significant increases in the short term, and that the magnitude of these increases is uncertain. When reviewing progress towards the decarbonization goals outlined in this report, the Town of Goderich will need to monitor these factors and may need to adjust the final pathways to achieve their goals.

3.2 Maitland Recreation Centre

Monthly utility data for the MRC was analyzed over a 36-month period, spanning 2021 to 2023. The 36-month period was analyzed to identify trends or anomalies prior to the on-site investigations. Included in this section are both the 3-year analyses, as well as a presentation of the 2023 energy consumption used to calibrate the energy model.

Table 3: 2023 MRC Energy Consumption Summary

	2023 Billed Consumption	2023 GHG Emissions	2023 Billed Cost
Electricity	2,471,575 kWh 8,897 GJ	94 tCO ₂ e	\$356,545
Natural Gas	167,123 m ³ 6,423 GJ	321 tCO ₂ e	\$82,974
Totals	4,255,780 ekWh 15,320 GJ	415 tCO ₂ e	\$439,519

Figure 7 and Figure 8 are visual representations of the utility costs and emissions by source.

Figure 7: MRC 2023 Utility Costs





Figure 8: MRC 2023 Emissions




3.2.1 Electricity

Electricity consumption constitutes approximately 58% of the total energy consumed by the MRC in 2023. It accounts for approximately 23% of the facility's total greenhouse gas (GHG) emissions.

Monthly billing data was analyzed and a graphical representation of the facility's monthly consumption covering a period of 2021 to 2023 is presented in Figure 9.

Figure 9: MRC Annual Electrical Consumption




As can be observed, the MRC experienced significant decreases to overall energy consumption during 2021 and 2022 due to the on-going impacts of the COVID-19 pandemic. The MRC is somewhat unique in that the indoor arena operates year-round, resulting in a significant base electrical requirement. Additional loads are observed during the summer periods, which reflects these additional cooling requirements.

3.2.2 Natural Gas

Natural gas use constitutes approximately 42% of the total energy consumed by the MRC in 2023. It accounts for approximately 77% of the facility's total greenhouse gas (GHG) emissions.

Monthly billing data was analyzed, and a graphical representation of the facility's monthly consumption is presented in the figure below. The data covers the periods of 2021 to 2023.

Figure 10: MRC Annual Natural Gas Use



Natural gas use at the MRC is strongly related to heating demands as can be observed in the above figure. Usage peaks during the cold winter months and drops significantly in the summer periods. Deviations from this trend can largely be attributed to estimated meter readings in the utility billing data. The smaller baseload of gas consumption during the summer months represents the proportion of natural gas required to provide domestic hot water heating and some of the pool heating requirements.

3.2.3 Utility Rate Structures

Electricity

The Town of Goderich purchases electricity for the MRC from Erie Thames Power Corporation under a General Service >50 kW rate structure. The facility Power Factor was noted as consistently being lower than 90%, resulting in additional fees on all monthly bills in 2023.

- Blended Electricity Rate: \$0.15/kWh
- Demand Rate: \$9.95/kW

Natural Gas


Natural gas for the MRC is supplied by Enbridge Gas under a commercial rate structure, Rate M2 Union South. The blended rate includes all pre-tax charges from the utility bills, with the exception of the Carbon Tax charge, which has been calculated separately from this rate.

- Blended Natural Gas Rate: \$0.38/m³

All utility rates are calculated as averages using monthly billing data for 2023, as supplied by the Town of Goderich.

3.2.4 Benchmarking

Figure 11: Maitland Recreation Centre Benchmarking



The above figure compares Maitland Recreational Centre's annual energy use intensity (EUI) from 2021 to 2023 to benchmark EUI's for Recreation Centre's and Ice Rinks. These benchmarks are sourced from publicly available national median values (Energy Star Portfolio Manager, 2023). As none of the published Primary Function categories exactly match the primary uses of the MRC, both the Recreation Centre and Ice Rinks EUI's are included in this benchmark analysis.

For all three years analyzed, the MRC had an EUI greater than either of the benchmark values. In 2021, the facility's EUI was approximately 80% above the average benchmark, and this difference increased significantly to 150% by 2023. A key reason for this discrepancy is that the benchmark provided for ice rinks assumes seasonal operation during winter months only, whereas the MRC operates its rink year-round.

Additionally, Figure 11 clearly illustrates the operational impact of Covid-19, with substantial shutdowns and activity restrictions between 2020 and 2022. Normal facility operations resumed in late 2022, making the 2023 EUI a more accurate representation of typical energy use at the MRC. Notably, the facility's EUI in the 2019 baseline was 2.21 GJ/m², closely aligning with its 2023 performance.

3.2.5 Target and Savings Estimate

In alignment with the FCM CBR Guidance Document, the GHG Reduction targets for the MRC are defined as follows:

1. **Minimum Performance Scenario:**

- A 10-year roadmap achieving a minimum of **50% GHG reduction** compared to the facility's baseline emissions.
- A 20-year roadmap achieving a minimum of **80% GHG reduction** compared to baseline emissions.

2. **Aggressive Deep Retrofit Scenario:**

- Achieves **50% GHG reduction within the first 5 years**, followed by additional measures to meet or exceed the 80% reduction target within 20 years.

In 2019, the Town of Goderich conducted a Community and Corporate-level GHG inventory as part of FCM's Partners for Climate Protection (PCP) program Milestone 1. The Town has elected to use the results of this inventory as the baseline for this study, aligning baseline emissions with 2019 energy usage.

Table 4: MRC Baseline and Target Emissions (tCO₂e)

2019 Electrical Consumption	2,505,070 kWh
2019 Natural Gas Use	168,570 m ³
2019 Baseline Emissions	396.5 tCO ₂ e
Target 1: 50% of Baseline Emissions	198.3 tCO ₂ e
Target 2: 80% of Baseline Emissions	79.3 tCO ₂ e

Achieving an 80% reduction in facility GHG emissions at MRC would result in a savings of 317.2 tCO₂e annually.

Based on the data used to generate the 2019 baseline emissions, the following table represents the baseline and target greenhouse gas intensity (GHGI) for MRC.


Table 5: Baseline and Target GHGI for MRC

Baseline GHGI	56.6 kgCO ₂ e/m ²
Target 1 GHGI: 50% of Baseline Emissions	28.3 kgCO ₂ e/m ²
Target 2 GHGI: 80% of Baseline Emissions	11.3 kgCO ₂ e/m ²

3.2.6 End-use breakdown

The following figure details the energy end-use breakdown for the MRC. The distribution is based on the total energy consumed by each end-use category as determined through calibrated energy model, on-site investigation, sub-metered data, and engineering calculations.

Figure 12: MRC Energy End-use Breakdown



3.3 Goderich Wastewater Treatment Plant

Monthly utility data for the WWTP was analyzed over a 36-month period, spanning 2021 to 2023. The 36-month period was analyzed to identify trends or anomalies prior to the on-site investigations. Included in this section are both the 3-year analyses, as well as a presentation of the 2023 energy consumption used to calibrate the energy model.

Table 6: 2023 WWTP Energy Consumption Summary

	Billed Consumption	GHG Emissions (tCO ₂ e)	Billed Cost
Electricity	699,928 kWh 2,520 GJ	27 tCO ₂ e	\$111,592
Natural Gas	6,408 m ³ 246 GJ	12 tCO ₂ e	\$3,702
Totals	768,340 ekWh 2,766 GJ	39 tCO ₂ e	\$115,294

Figure 7 and Figure 8 are a visual representation of the utility costs and emissions by source.

Figure 13: WWTP 2023 Utility Costs





Figure 14: WWTP 2023 Emissions




3.3.1 Electricity

Electricity consumption constitutes approximately 91% of the total energy consumed by the WWTP in 2023. It accounts for approximately 68% of the facility's total greenhouse gas (GHG) emissions.

Monthly billing data was analyzed and a graphical representation of the facility's monthly consumption covering a period of 2021 to 2023 is presented in Figure 14.

Figure 15: WWTP Annual Electrical Consumption




The above figure demonstrates the relatively high electrical baseload at the WWTP. Monthly consumption shows little correlation to wastewater flowrates despite SCADA programming to vary equipment operation in response to influent flows. This may be due to some equipment operating in step-wise or on/off configurations, however it is also likely due to the influent storage capabilities at the WWTP. With significant on-site overflow capacity, the WWTP can control the flow of influent to the processing equipment, this control normalizes the amount of water processed over time and reduces the variability in process energy use.

3.3.2 Natural Gas

Natural gas use constitutes approximately 9% of the total energy consumed by the WWTP over the past 12 months. It accounts for approximately 68% of the facility's total greenhouse gas (GHG) emissions.

Monthly billing data was analyzed, and a graphical representation of the facility's monthly consumption is presented in the figure below. The data covers the periods of 2021 to 2023.

Figure 16: WWTP Annual Natural Gas Use



Natural gas use at the WWTP is strongly related to heating demands as only the radiant tube heaters and the MAU utilize natural gas. Minor amounts of natural gas consumption during the summer months may be representative of overnight heating of the interior space as a result of using manual thermostats.

3.3.3 Utility Rate Structures

Electricity

The Town of Goderich purchases electricity for the WWTP from Erie Thames Power Corporation under a General Service >50 kW rate structure. The facility Power Factor was noted as consistently being lower than 90%, resulting in additional fees on all monthly bills in 2023.

- Blended Electricity Rate: \$0.16/kWh
- Demand Rate: \$9.73/kW

Natural Gas


Natural gas for the MRC is supplied by Enbridge Gas under a commercial rate structure, Rate M2 Union South. The blended rate includes all pre-tax charges from the utility bills, with the exception of the Carbon Tax charge which has been calculated separately from this rate.

- Blended Natural Gas Rate: \$0.72/m³

All utility rates are calculated as averages using monthly billing data for 2023, as supplied by the Town of Goderich.

3.3.4 Benchmarking

Figure 17: Goderich WWTP Benchmarking



The WWTP's energy use intensity (EUI) was measured against a Benchmark EUI (Posterity Group, 2018) for wastewater treatment plants in Ontario based on effluent flow. The facility's EUI was measured for the years of 2021, 2022, and 2023. The results show

consistent energy consumption in all three years. The WWTP is overperforming when compared to the benchmark, using less than 40% of the energy used in the benchmark case for all observed years.

The consistency in the years examined can present an issue despite good performance indicators such as being under the benchmark in EUI. Having a consistent energy use intensity when measured against flow can mean that the facility operations are always running regardless of other variables. When looking at the electricity consumption graphs in Section 3.3.1, it is clearer that the usage is not entirely correlated to the volume of flow that is being processed. As an example, in 2022 there was 13% less flow processed at the facility than in 2023, however 2022 has a higher EUI. This may represent additional conservation opportunities in the processing of wastewater.

The relationship between this facility's performance compared to other Ontario facilities is perhaps not a great indicator of the facility's overall efficiency. This is due to the benchmark value being pulled from a wide variety of treatment sites around the province. Outlier sites with greater flow rates or unique processes will skew the median value. There is also little oversight into the self-reported values in the Broader Public Sector data used in the benchmark analysis. This could lead to confusion as to what constitutes a "Wastewater Treatment Plant" by those who submit the data, potentially incorporating pumping stations and other low consumption facilities into the database.

As the impacts of WWTP's continue to grow in importance to municipal owners, it is expected that more valuable and realistic benchmarks for WWTPs in general, or for specific sub-types, will become available and allow for more valuable insight into the energy performance of wastewater plants.

3.3.5 Target and Savings Estimate

In alignment with the FCM CBR Guidance Document, the GHG Reduction targets for the WWTP are defined as follows:

3. Minimum Performance Scenario:

- A 10-year roadmap achieving a minimum of **50% GHG reduction** compared to the facility's baseline emissions.
- A 20-year roadmap achieving a minimum of **80% GHG reduction** compared to baseline emissions.

4. Aggressive Deep Retrofit Scenario:

- Achieves **50% GHG reduction within the first 5 years**, followed by additional measures to meet or exceed the 80% reduction target within 20 years.

In 2019, the Town of Goderich conducted a Community and Corporate-level GHG inventory as part of FCM's Partners for Climate Protection (PCP) program Milestone 1. The Town has elected to use the results of this inventory as the baseline for this study, aligning baseline emissions with 2019 energy usage.

Table 7: WWTP Baseline and Target Emissions (tCO₂e)

2019 Electricity Consumption	750,797 kWh
2019 Natural Gas Use	6,480 m ³
2019 Baseline Emissions	35.2 tCO ₂ e
Target 1: 50% of Baseline Emissions	17.6 tCO ₂ e
Target 2: 80% of Baseline Emissions	7.0 tCO ₂ e

Achieving an 80% reduction in facility GHG emissions at WWTP would result in a savings of 28.2 tCO₂e annually.

Based on the data used to generate the 2019 baseline emissions, the following table represents the baseline and target greenhouse gas intensity (GHGI) for the WWTP.

Table 8: Baseline and Target GHGI for WWTP


Baseline GHGI	18.1 kgCO ₂ e/ML
Target 1 GHGI: 50% of Baseline Emissions	9.0 kgCO ₂ e/ML
Target 2 GHGI: 80% of Baseline Emissions	3.6 kgCO ₂ e/ML

As noted in the previous section, performance indicators for the WWTP are normalized using Mega Litres of annual flow value, rather than on a floor area basis, as was conducted for the MRC. This follows industry standards for the normalization of WWTP energy consumption and emission values.

3.3.6 End-use breakdown

The following figure details the energy end-use breakdown for the WWTP. The distribution is based on the total energy consumed by each end-use category as determined through calibrated energy model, on-site investigation, sub-metered data, and engineering calculations.

Figure 18: WWTP Energy End-use Breakdown



The above figure details the energy end-use breakdown for the WWTP. The distribution is based on the total energy consumed by each end-use category as determined through calibrated energy model, on-site investigation, sub-metered data, and engineering calculations.

4. Workshop Summaries

4.1 Design Workshop

On February 5, 2025, Aladaco conducted Design Workshops for each of the facilities. The in-person workshops took place at the Town of Goderich offices located at 57 West St, Goderich. The intent of the Design Workshops was to gather all relevant stakeholders to review preliminary decarbonization measures and their feasibility, while also encouraging engagement and discussion on the challenges and opportunities at each facility. At the conclusion of the Workshop consensus was formed on the selected ECMs for further analysis in the Measure Level Analysis phase of the Feasibility Study. See the Design Workshop Summary Report in Appendix A for more details.

4.2 Decision-making Workshop

On June 2, 2025, Aladaco conducted an in-person Decision-making workshop with the Town of Goderich. The workshop took place at Town's offices located in Goderich ON and was attended by key stakeholders from finance and operations department, as well as facility operators. The workshop included the selection of specific ECMs to form each of the GHG Reduction Pathways for both facilities, and consensus was formed on the appropriate implementation dates for each selected ECM. At the end of the workshop, each facility had both the Minimum Performance and Aggressive Deep Retrofit Pathways defined, along with an understanding of the financial metrics of each path. For further details on the workshop and its attendees, please see the Decision-making Workshop slide decks in Appendix E.

5. Measures Level Analysis

The following analyses represent the savings and GHG reductions for project implementations in 2025. Measure level analyses adjust future cashflows using the following variables as provided by the Town of Goderich.

- Inflation (Capital, Labour, Utilities): 2%
- Discount Rate: 4%
- **Utility rates:** As determined in Section 3 of this report.
- **Federal Carbon Tax:** \$95/tonne in 2025, increasing by \$15/tonne/yr until reaching a maximum of \$170/tonne in 2030.
- **Grid Emissions Factor:** Adjusted annually as defined in Appendix B.

The measure level analysis evaluates each energy conservation measure independently and does not account for interactive effects between measures. This means the energy savings, cost impacts, and GHG reductions are calculated in isolation, without considering how one measure may influence the performance or outcome of another. All measures within this section are presented as though implemented in 2025.

In contrast, the analyses used in the GHG Reduction Pathway Capital Plans incorporates interactive effects by integrating packages of measures into the calibrated energy model. This allows for a more comprehensive assessment, where combined impacts are captured. As a result, the values presented in the measure-level analysis may differ from the pathways due to the inclusion of measure interactions, fluctuating grid emissions factors, and inflationary adjustments applied within the long-term modeling framework.

Capital costs in the Measure-Level Analysis are generally equivalent to Class C estimates, which reflect a preliminary level of accuracy suitable for planning purposes. These estimates are based on a combination of technical data, RSMeans costing references, vendor-supplied quotes, and Aladaco's experience with similar projects. While care has been taken to ensure reasonable accuracy, current economic conditions, including supply chain volatility and material cost fluctuations, may significantly affect the actual costs at the time of implementation. Capital Costs shown in this report include all labour, materials, engineering, and contingency to fully implement the project.

Aladaco is unable to provide incremental cost analysis under the WWTP Measure Level Analysis due to the absence of a BCA for the Goderich WWTP. Additionally, there are no incremental cost analysis under the GHG Reduction Pathway Capital Plan for the WWTP.

5.1 Maitland Recreation Centre Recommended Measures

The following sections detail the ECMs analyzed by Aladaco for the MRC. These measures were developed through site investigations and analysis of energy data, and they were selected for inclusion in the GHG Reduction Pathways by the Town of Goderich through the collaborative Decision-making Workshop.

5.1.1 ECM – Recommissioning of the Geothermal Systems

Utility Savings		Financial Analysis	
Electricity (kWh)	34,157	Materials & Labour	\$21,500
Demand (kW)	0.0	Engineering & PM	\$ -
Natural Gas (m ³)	0.0	Contingency	\$ -
GHG (tCO ₂ e)	2.9	Total Capital Cost	\$21,500
GHG Baseline Reduction	1%	Utility Savings	\$5,124
EUI Reduction (ekWh/m ²)	4.9	Annual O&M	\$972
TEDI Reduction	0%	Simple Payback (yrs)	4.4
		Net-Present Value	\$21,706

Existing Conditions:

The facility's original geothermal system provides both heating and cooling through a network of water-source heat pumps and serves the ice-making system. Although the system remains operational, several indicators suggest that recommissioning is warranted. Observations during the site visit, combined with operational data trends, indicate that there may be untapped capacity within the geothermal field that could support additional thermal loads. For example, loop return temperatures observed on the BAS were notably high, implying that excess heat is being rejected without being effectively recovered, which suggests that the system may be underutilized.

A full assessment could not be completed for this report due to limitations in the available data. Annual and seasonal performance trends are not currently recorded, and the BAS does not provide reliable temperature readings for several key variables. In particular, geothermal field temperatures, which appear abnormally high and are likely the result of faulty sensors or calibration issues. Without accurate and continuous metering of loop temperatures, flow rates, and system loads across different times of the year, it is not possible to confirm the system's true capacity or evaluate the feasibility of expanding its use to displace existing fossil fuel-based heating systems.

Proposed Measure:

To address these issues and fully evaluate the capabilities of the geothermal system, Aladaco recommends conducting a detailed recommissioning study, in collaboration with qualified geothermal and controls specialists. This effort would include a thorough performance assessment of the entire system—including the geothermal field, circulation pumps, heat pump loops, and integration with the ice-making process. The primary objective will be to optimize system functionality, correct known BAS metering inaccuracies, and restore accurate sensor readings, control logic, and data trending capabilities. Special focus should be placed on heat pump loop temperatures, system balancing, and seasonal variations in performance.

The second objective of the study is to assess the system's available capacity to support additional thermal loads, specifically the potential to replace or offset heating currently provided by natural gas boilers. This information is essential to validate the assumptions made in Measure 6.1.6, which proposes the installation of additional water-source heat pumps. At present, that measure assumes a conservative approach due to the uncertainty surrounding geothermal capacity. As part of the recommissioning process, Goderich staff should confirm metering requirements with the selected commissioning agent to ensure that sufficient trending and seasonal data is captured moving forward. This will allow the Town to make informed, evidence-based decisions regarding system expansion and investment, and to maximize the use of existing infrastructure to reduce GHG emissions and operational costs.

Implementation and Non-Financial Considerations:

Recommissioning the geothermal system can be carried out with minimal disruption to facility operations, though some coordination will be needed to schedule short service interruptions. Town staff will need to support the process by assisting with data collection, system access, and responding to technical inquiries during the study.

Beyond energy savings, this measure will improve system reliability, extend equipment life, and enhance control accuracy. It will also support future planning by confirming the system's capacity to offset natural gas use.

Measurement and Verification:

M&V should follow IPMVP Option B – All Parameter Measurement. By conducting the recommissioning, it is expected that all parameters will be accurately measured. Pre and post project energy usage can be trended with weather related data to determine energy savings.

5.1.2 ECM – Recommissioning of the BAS and Related Systems

Utility Savings		Financial Analysis	
Electricity (kWh)	36,788	Materials & Labour	\$18,060
Demand (kW)	0.0	Engineering & PM	\$-
Natural Gas (m ³)	3,982	Contingency	\$-
GHG (tCO ₂ e)	10.8	Total Capital Cost	\$18,060
GHG Baseline Reduction	3%	Utility Savings	\$7,016
EUI Reduction (ekWh/m ²)	11.38	Annual O&M	\$1,944
TEDI Reduction	0%	Simple Payback	2.9
		Net-Present Value	\$47,264

Existing Conditions:

The facility is equipped with a BAS that provides control and monitoring of several key mechanical and electrical systems. While the BAS is operational, the current programming and control sequences have not been reviewed or updated in several years. Several areas were observed during the site visit where setpoints, schedules, and sensor calibration may be misaligned with actual operational needs. A detailed assessment and recommissioning of the BAS is recommended to address these issues and ensure systems are operating optimally.


System Controlled by BAS	Equipment Description	Notes
HVAC System	22 Water-source heat pumps	Occupied/unoccupied scheduling
Arena Refrigeration	Modular system w/ ground loop	Monitoring only
Pool Heating and Dehumidification	Pool boilers and dehumidifier	Temperature and humidity setpoints, heat recovery optimization
Change Room Ventilation	Roof-mounted AHUs with DX and gas heat	Exhaust air heat recovery present
Makeup Air Ventilation	Roof-mounted MAU with DX and gas heat	Occupied/unoccupied scheduling and fresh air rates
Arena Ventilation and Dehumidification	Exhaust fans and Dectron units	CO2 setpoints and verification
Domestic Hot Water System	Dedicated DHW boilers	Tank setpoint verification needed, heat recovery optimization

Proposed Measure:

Recommissioning of the BAS to restore optimal performance and energy efficiency is recommended. The scope will include testing and verification of all existing BAS points, updating control sequences, confirming time-of-day schedules, recalibrating sensors, and addressing any identified faults or overrides. Custom programming changes will be implemented based on operational needs and energy-saving opportunities discovered during the site investigation.

As an example, below is a screenshot from the BAS showing an erroneous ground loop temperature of 282.5 °F. Other similar items identified during a brief review of the BAS include extremely low DHW temperatures below 100 °F and sensors in adjacent or similar spaces showing greater variation than expected.

Figure 19: MRC BAS Ground Temperature Reading



Expected energy savings from this measure are approximately 3% of energy use from BAS controlled systems.

Implementation and Non-Financial Considerations:

Work can be completed with minimal disruption to operations if scheduled during off-hours or in coordination with facility staff. Operational staff may require minor training to sustain optimized performance after recommissioning.

Recommissioning often results in improved occupant comfort and reduced maintenance from more stable and predictable system behavior.

Measurement and Verification:

M&V should follow Option A – Retrofit Isolation with Key Parameter Measurement. Pre- and post-implementation BAS trend logs will be reviewed for critical control points such as temperature setpoints, scheduling adherence, and equipment cycling. Spot measurements and operational testing will verify improvements. Since recommissioning affects multiple systems, savings are recommended to be validated against historical energy consumption patterns using utility data normalized for weather and operational changes.

5.1.3 ECM – Install Water-Source Heat Pump Boilers

Utility Savings		Financial Analysis	
Electricity (kWh)	-243,811	Materials & Labour	\$2,177,139
Demand (kW)	-198	Engineering & PM	\$326,571
Natural Gas (m ³)	73,780	Contingency	\$217,714
GHG (tCO ₂ e)	121.2	Total Capital Cost	\$2,721,424
GHG Baseline Reduction	31%	Utility Savings	-\$32,464
EUI Reduction (ekWh/m ²)	78.05	Annual O&M	\$4,900
TEDI Reduction	0%	Simple Payback	-84
		Net-Present Value	-\$2,582,732

Existing Conditions:

The MRC currently relies on natural gas-fired boilers to provide hot water for the pool, whirlpool, and domestic hot water systems. These boilers are a significant source of fossil fuel consumption at the facility and contribute directly to its operational greenhouse gas emissions. The equipment is aging and represents an opportunity for both emissions reduction and operational efficiency improvement through electrification.

Existing Equipment	Heating Capacity (BTUh)
Pool Boiler B1	688,500
Domestic Hot Water Boiler B1	1,062,500
Whirlpool Water Heater	323,190

Proposed Measure:

This measure proposes replacing the existing gas boilers with water-source heat pumps (WSHPs) connected to the facility's existing geothermal system. The heat pumps are conservatively sized to match the existing equipment; however additional downsizing may be appropriate based on the results of 5.1.1 ECM Recommissioning of the Geothermal System. By utilizing the geothermal loop as a heat source, the new system will operate efficiently to meet the water heating demands of the facility.

Proposed Equipment	Heat Pump Capacity (BTUh)
Pool Boiler B1	760,900
Domestic Hot Water Boiler B1	1,014,600
Whirlpool Water Heater	507,300

Implementation and Non-Financial Considerations:

Installing the new WSHP units is expected to have a minimal impact on operations. Installation periods are short and can be aligned with regular maintenance activities to reduce downtime. WSHPs may take longer to reach setpoints than traditional boilers, this could impact occupant comfort if systems are not programmed with appropriate preheating schedules.

Measurement and Verification:

To measure the change in energy consumption IPMVP Option A or B is recommended, based on the availability of BAS data and energy meter data.

5.1.4 ECM – Electrification of HRU's and MAU

Utility Savings		Financial Analysis	
Electricity (kWh)	-173,044	Materials & Labour	\$455,780
Demand (kW)	-6.2	Engineering & PM	\$79,762
Natural Gas (m ³)	34,728	Contingency	\$68,367
GHG (tCO ₂ e)	52.1	Total Capital Cost	\$603,909
GHG Baseline Reduction	13%	Utility Savings	-\$13,265
EUI Reduction (ekWh/m ²)	28.38	Annual O&M	\$4,300
TEDI Reduction	0%	Simple Payback	-45.8
		Net-Present Value	-\$746,191

Existing Conditions:

The rooftop HVAC units at the MRC provide heating, cooling, and fresh air to the facility. These units are equipped with natural gas heating coils that significantly contribute to MRC's overall carbon emissions.

Existing Equipment	Cooling Capacity (Tons)	Heating Capacity (BTUh)
MAU-1	4	200,000
HRV-1	22	800,000
HRV-2	22	800,000

Proposed Measure:

The measure proposes replacing the existing HVAC equipment with modern heat pump equipped alternatives. The heat pumps are sized to meet the existing cooling loads and will operate to meet heating demand to an outdoor temperature of 2 °C. Below this temperature an electric resistive back-up heater will operate to provide heating during these low temperatures. Due to the increased size and weight of the heat pump units, an allocation has been made in the project pricing to provide for structural assessments prior to installation and the contingency has been increased to account for potential remediation actions.

Proposed Equipment	Heat Pump Capacity (BTUh)	Supplementary Electric Capacity (BTUh)
MAU-1	48,000	200,000
HRV-1	264,000	800,000
HRV-2	264,000	800,000

Implementation and Non-Financial Considerations:

Installing the new HVAC units is expected to have a minimal impact on operations. Installation periods are short and should be implemented during shoulder seasons when heating and cooling loads are lowest. This approach to scheduling will reduce impacts on occupant comfort.

Measurement and Verification:

To measure the change in energy consumption IPMVP Option A or B is recommended, based on the availability of BAS data and energy meter data.

5.1.5 ECM – Electrification of DH3

Utility Savings		Financial Analysis	
Electricity (kWh)	-383,662	Materials & Labour	\$783,328
Demand (kW)	-45.1	Engineering & PM	\$137,082
Natural Gas (m ³)	50,828	Contingency	\$117,499
GHG (tCO ₂ e)	65.3	Total Capital Cost	\$1,037,910
GHG Baseline Reduction	16%	Utility Savings	-\$41,125
EUI Reduction (ekWh/m ²)	22.82	Annual O&M	\$2,600
TEDI Reduction	0%	Simple Payback	-25.3
		Net-Present Value	-\$1,593,429

Existing Conditions:

The rooftop air handling unit, DH-3, provides fresh air, heating, cooling, and humidity control for the pool area. DH-3 is equipped with a natural gas burner to heat the fresh air and is a significant source of GHG emissions at the facility. The unit was installed in 2025 and has significant remaining useful life. To compensate for this, its replacement is deferred to as late as possible within the GHG Reduction Pathways while still achieving the required reduction targets.

Existing Equipment	Cooling Capacity (Tons)	Heating Capacity (BTUh)
DH-3	80	1,100,000

Proposed Measure:

The measure proposes replacing DH-3 with a modern heat pump equipped alternative. The heat pump is sized to meet the existing cooling loads and will operate to meet heating demand to an outdoor temperature of 2 °C. Below this temperature an electric resistive back-up heater will operate to provide heating during these low temperatures. Due to the increased size and weight of the heat pump units, an allocation has been made in the project pricing to provide for structural assessments prior to installation and the contingency has been increased to account for potential remediation actions.

Proposed Equipment	Heat Pump Capacity (BTUh)	Supplementary Electric Capacity (BTUh)
DH-3	446,000	1,100,000

Implementation and Non-Financial Considerations:

Installing the new HVAC units is expected to have a minimal impact on operations. Installation periods are short and should be implemented during shoulder seasons when heating and cooling loads are lowest. This approach to scheduling will reduce impacts on occupant comfort.

Measurement and Verification:

To measure the change in energy consumption IPMVP Option A or B is recommended, based on the availability of BAS data and energy meter data.

5.1.6 ECM – Electrification of Unit Heaters

Utility Savings		Financial Analysis	
Electricity (kWh)	-22,969	Materials & Labour	\$17,907
Demand (kW)	0.1	Engineering & PM	\$2,686
Natural Gas (m ³)	3,195	Contingency	\$403
GHG (tCO ₂ e)	4.2	Total Capital Cost	\$20,996
GHG Baseline Reduction	1%	Utility Savings	-\$2,238
EUI Reduction (ekWh/m ²)	1.60	Annual O&M	\$-
TEDI Reduction	0%	Simple Payback	-9.4
		Net-Present Value	-\$48,470

Existing Conditions:

Five (5) natural gas Unit Heaters are located throughout MRC's utility rooms. Providing heat to these areas through natural gas combustion these unit heaters are a source of GHG emissions for the facility.

Existing Equipment	Heating Capacity (BTUh)
UH-1 to UH-5	250,000

Proposed Measure:

The measure proposes replacing the existing Unit Heaters with new equivalent capacity electric models to significantly reduce GHG emissions.

Existing Equipment	Electric Heating Capacity (BTUh)
UH-1 to UH-5	250,000

Implementation and Non-Financial Considerations:

The measure is not expected to have any impact on occupant comfort or facility operations. Implementation of this measure is also not expected to impact operations.

Measurement and Verification:

To measure the change in energy consumption IPMVP Option A or B is recommended, based on the availability of BAS data and energy meter data.

5.1.7 ECM – Install Rooftop Solar PV System

Utility Savings		Financial Analysis	
Electricity (kWh)	400,000	Materials & Labour	\$582,250
Demand (kW)	0.0	Engineering & PM	\$115,750
Natural Gas (m ³)	0.0	Contingency	\$58,225
GHG (tCO ₂ e)	33.8	Total Capital Cost	\$756,225
GHG Baseline Reduction	9%	Utility Savings	\$60,000
EUI Reduction (ekWh/m ²)	57.41	Annual O&M	\$5,115
TEDI Reduction	0%	Simple Payback	12.7
		Net-Present Value	\$410,923

Existing Conditions:

The MRC currently purchases all electricity from the Local Distribution Company.

Proposed Measure:

The property has significant opportunity to accommodate a large number of solar panels on its Southern rooftop. This measure recommends installing a behind-the-meter system of 340 kW DC solar PV panels to offset 400,000 kWh of facility consumption.

Proposed Measure	Installed Capacity (kW DC)	Estimated Generation (kWh)
Roof Mount Solar PV System	340	400,000

Under a behind-the-meter scenario the energy generated by the panels is consumed on-site, with no excess energy exported to the grid. The energy generated offsets energy which would have been purchased from the grid and reduces overall utility costs.

A Solar PV System of the size above is sufficient to provide approximately 90% of the average baseload for the facility after all decarbonization measures have been implemented. This maximizes the amount of useable energy while minimizing over-generation which may not be useable onsite.

Implementation and Non-Financial Considerations:

Implementing a roof mounted solar PV system requires suitable electrical approvals, structural assessments, and coordination with local utility and ESA standards. Construction

may temporarily impact site access, but long-term disruption is minimal. Non-financial considerations include aesthetics and future roof-top use flexibility.

Measurement and Verification:

Renewable energy installations typically will meet IPMVP Option B M&V as independent metering of energy generation is commonly included with installation. This metering measures all energy generated, typically in real time, to allow for continuous monitoring and tracking of the Solar PV System's performance.

5.2 Goderich Wastewater Treatment Plant Recommended Measures

Aladaco is unable to provide incremental cost analysis under the WWTP Measure Level Analysis due to the absence of a BCA for the Goderich WWTP. Additionally, there are no incremental cost analysis under the GHG Reduction Pathway Analysis for the WWTP.

5.2.1 ECM – Thermostat Upgrades

Utility Savings		Financial Analysis	
Electricity (kWh)	20,371	Materials & Labour	\$3,900
Demand (kW)	0.0	Engineering & PM	\$-
Natural Gas (m ³)	2,597	Contingency	\$390
GHG (tCO ₂ e)	6.7	Total Capital Cost	\$4,290
GHG Baseline Reduction	19%	Utility Savings	\$5,119
EUI Reduction (ekWh/m ²)	1.41	Annual O&M	\$510
TEDI Reduction ¹	-66%	Simple Payback	0.9
		Net-Present Value	\$97,464

Existing Conditions:

The heating equipment at the WWTP is controlled via wall-mounted manual thermostats. This includes the electric heaters in the Pumphouses, Office, and Chemical Room, as well as the natural gas radiant tube heaters in the Administration Building and Workshop. This type of HVAC control often leads to excessive heating during unoccupied periods. The manual nature of these controls also increases the risk of over-heating the space if they are inadvertently set at a higher temperature for long periods.

¹ Note that TEDI is increasing for this measure due to the Occupied temperatures enabled through increased controls will be higher than current settings for many areas. While occupied energy consumption is increased, overall energy is reduced due to the lower and extended unoccupied periods enabled through this measure.

Figure 20: WWTP Existing HVAC Controls

Proposed Measure:

The measure proposes replacing the existing manual thermostats with programmable thermostats. Thermostats outside of the normally occupied areas of the Control Room and the Chlorine Room will be equipped with occupancy sensors to further reduce energy consumption.

Thermostats with on-board occupancy sensors will be set to occupied temperatures when movement is detected and will maintain that set point for a period of 2 hours before reverting to the unoccupied set point.

Thermostats in normally occupied areas will be programmed to follow an occupancy schedule of Monday to Friday, 7:00 AM to 3:30 PM, with setback temperatures enabled for unoccupied periods.

Implementation and Non-Financial Considerations:

The implementation of this proposed measure is not expected to impact facility operations. After initial installation, the occupancy schedules can be adjusted as required to maintain staff comfort. If the unoccupied setbacks are maintained, these minor variations in settings will not have a significant impact on energy savings estimates.

Measurement and Verification:

To measure the change in energy consumption IPMVP Option A is recommended to keep M&V costs in line with savings estimates.

5.2.2 ECM – Electrification of the MAU

Utility Savings		Financial Analysis	
Electricity (kWh)	-1,535	Materials & Labour	\$29,344
Demand (kW)	-3.5	Engineering & PM	\$4,402
Natural Gas (m ³)	186	Contingency	\$2,934
GHG (tCO ₂ e)	0.2	Total Capital Cost	\$36,681
GHG Baseline Reduction	1%	Utility Savings	-\$523
EUI Reduction (ekWh/m ²)	0.01	Annual O&M	\$1,500
TEDI Reduction	0%	Simple Payback	-73.0
		Net-Present Value	-\$69,316

Existing Conditions:

The MAU operates when the Belt Filter Press is in operation, providing fresh make-up air to the conditioned space. The make-up air is heated via natural gas combustion.

Existing Conditions	CFM	Heating Capacity (BTUh)
MAU-1	4,000	12,000

Proposed Measure:

The measure proposes replacing the existing MAU with a new model of equivalent capacity but equipped with an electric heating element to significantly reduce GHG emissions.

Proposed Measure	CFM	Electric Heating Capacity (BTUh)
MAU-1	4,000	12,000

Implementation and Non-Financial Considerations:

Installing the new MAU will have a minimal impact on operations. Due to the intermittent use of the MAU and the requirement for rapid heating of the outdoor air, a heat pump replacement for this unit is not appropriate to meet these operating criteria.

Measurement and Verification:

To measure the electrical energy savings IPMVP Option A or B is recommended, based on the availability of SCADA data and energy meter data.

5.2.3 ECM – Electrification of Tube Heaters

Utility Savings		Financial Analysis	
Electricity (kWh)	-36,278	Materials & Labour	\$124,476
Demand (kW)	-52.0	Engineering & PM	\$18,671
Natural Gas (m ³)	6,387	Contingency	\$12,448
GHG (tCO ₂ e)	9.2	Total Capital Cost	\$155,595
GHG Baseline Reduction	26%	Utility Savings	-\$3,254
EUI Reduction (ekWh/m ²)	0.94	Annual O&M	\$-
TEDI Reduction	0%	Simple Payback	-47.8
		Net-Present Value	-\$190,014

Existing Conditions:

The majority of the Administration Building is heated via natural gas radiant tube heaters. These heaters, while an efficient means of heating the space, are a significant source of GHG emissions.

Location	Radiant Tube Heating Capacity (BTUh)
Control Room	80,000
Locker Room	40,000
Truck Bay	80,000
Filter Press Room	80,000
Workshop	80,000
Chlorine Room	80,000

Proposed Measure:

The measure proposes replacing the existing radiant tube heaters with mini-split heat pumps with electric backup heating. The mini-split heat pumps will operate at outdoor air temperatures above 2° C and the electric heating will supply heat at lower temperatures, ensuring the interior temperature is consistently maintained.

Location	Heat Pump Capacity (BTUh)	Supplementary Electric Capacity (BTUh)
Control Room	60,000	80,000
Locker Room	30,000	40,000
Truck Bay	60,000	80,000
Filter Press Room	60,000	80,000
Workshop	60,000	80,000
Chlorine Room	60,000	80,000

Implementation and Non-Financial Considerations:

Installation costs include penetration to the building envelope to accommodate the new systems. The actual placement of the interior fan coil units will differ from the current heating system as the interior fan coil units will be limited in the distance away from the exterior units they can be located.

Measurement and Verification:

To measure the change in energy consumption IPMVP Option A is recommended to keep M&V costs in line with savings estimates.

5.2.4 ECM – Reduce Exhaust Area for Filter Press

Utility Savings		Financial Analysis	
Electricity (kWh)	7,023	Materials & Labour	\$2,135
Demand (kW)	9.7	Engineering & PM	\$320
Natural Gas (m ³)	0	Contingency	\$213
GHG (tCO ₂ e)	0.6	Total Capital Cost	\$2,668
GHG Baseline Reduction	2%	Utility Savings	\$1,218
EUI Reduction (ekWh/m ²)	0.21	Annual O&M	\$1,020
TEDI Reduction	0%	Simple Payback	3.0
		Net-Present Value	\$1,256

Existing Conditions:

The WWTP's Belt Filter Press is located in the rear workshop area of the Main Building. When the Belt Filter Press operates, the ACA Exhaust unit operates at high speed, and the MUA provides make-up fresh air. This fresh air requires heating during the winter months, increasing the amount of fossil fuels consumed on-site. When the Belt Filter Press is not operating, the ACA Exhaust runs continuously at low speed. In the current configuration, the total area exhausted by the ACA Exhaust is 40,150 ft³.

Existing Conditions	CFM	Motor HP	Air Changes per Hour
ACA Exhaust High Speed	48,000	20	71
ACA Exhaust Low Speed	24,000	5	35

Proposed Measure:

The measure proposes reducing the total area exhausted by the ACA Exhaust through the installation of a vinyl strip curtain wall. The curtain wall will reduce the exhaust area to approximately 15,000 ft³, allowing for lower exhaust ventilation and heating requirements.

Operating the ACA Exhaust at low speed provides sufficient ventilation to achieve the same number of air changes within the reduced workshop area as is currently achieved with the high-speed operation.

Proposed Measure	CFM	Motor HP	Air Changes
ACA Exhaust Low Speed	24,000	5	97

Implementation and Non-Financial Considerations:

Installing the vinyl curtain wall should not result in any significant changes in operations for the WWTP and the implementation of the measure could occur at any time. It is however recommended that the HVAC replacements take place during the summer months to minimize the heat loss from the interior space.

Access to all areas of the Belt Filtr Press will be maintained and the flexible nature of the curtain wall will ensure that maintenance or other modifications to the Belt Filter Press or other equipment in the area remains feasible.

On-going cleaning of the curtain wall will be required as soiling is expected during normal operation of the Belt Filter Press. Installing a PVC or Vinyl material curtain allows site staff to utilize existing power washers to clean the curtain the wall.

Measurement and Verification:

To measure the change in energy consumption IPMVP Option A or B is recommended, based on the availability of SCADA data and energy meter data.

5.2.5 ECM – Install Aeration Blower

Utility Savings		Financial Analysis	
Electricity (kWh)	88,936	Materials & Labour	\$212,749
Demand (kW)	10.2	Engineering & PM	\$31,912
Natural Gas (m ³)	0	Contingency	\$21,275
GHG (tCO ₂ e)	7.5	Total Capital Cost	\$265,936
GHG Baseline Reduction	21%	Utility Savings	\$15,425
EUI Reduction (ekWh/m ²)	2.61	Annual O&M	\$3,400
TEDI Reduction	0%	Simple Payback	17.5
		Net-Present Value	-\$49,307

Existing Conditions:

Aeration tanks at the WWTP utilize mechanical surface aerators to provide the required oxygen for the wastewater treatment process. These aerators operate at either Fast or Slow speed, depending on the requirements of the facility. Each mechanical aerator uses a gearbox to reduce the RPMs of the impellers. Based on motor RPM and gearbox ratio, the existing units can be classified as low-speed aerators.

Existing Conditions	Motor HP	Metered Input kW	Transfer Rate (lb O ₂ /HP*h)
Aerator No.3 – Low Speed	8.4	5.8	2.5
Aerator No.4 – Low Speed	8.4	5.8	2.5
Aerator No.5 – Low Speed	8.4	5.8	2.5
Aerator No.6 – Low Speed	8.4	5.8	2.5
Aerator No.7 – Low Speed	8.4	5.8	2.5
Aerator No.8 – Low Speed	8.4	5.8	2.5
Aerator No.3 – High Speed	15	8.9	3.5
Aerator No.4 – High Speed	15	8.9	3.5

Aerator No.5 – High Speed	15	8.9	3.5
Aerator No.6 – High Speed	15	8.9	3.5
Aerator No.7 – High Speed	15	8.9	3.5
Aerator No.8 – High Speed	15	8.9	3.5

Proposed Measure:

Replace the surface aerators with one (1) variable speed turbo aeration blower. The blower can be installed within the existing blower building, with underground piping delivering air to the aeration tanks via fine bubble tube diffusers installed at the bottom of each tank.

Proposed Measure	Power (kW)	Flow Rate (Nm³/hr)	Transfer Rate (lb O₂/HP*h)
Variable Speed Aeration Blower	27.6	7.5	29.1

Implementation and Non-Financial Considerations:

Implementation of this measure will require significant impact to site operations and as such will need to be carefully staged in consultation with facility operators. The turbo blower can be installed with minimal impacts to operations, as can the underground piping. The piping, however, should be installed during the summer months to reduce installation costs. Care will need to be taken to ensure installation does not damage existing underground piping. To reduce the risk of damaging existing infrastructure, the proposed new piping will be installed on the West side of the aeration tanks (see Appendix D: Schematics). When installing the diffuser tubes within the aeration tanks, the tanks will need to be drained and cleaned. This should be scheduled during periods of low flow and may require the use of the plant's overflow holding tanks to allow for this work to occur. The installation of the diffuser tanks is recommended to occur one tank at a time to reduce the impacts to the plant's capacity.

The Town of Goderich may elect to maintain the existing surface aerators as a back-up system should the new Turbo Blower require repairs or maintenance.

Measurement and Verification:

IPMVP Option B is recommended for verifying the energy savings for this measure due to the availability of SCADA and energy metering data for the current conditions. The proposed measure's energy consumption can be recorded using the on-board VFD controller for a direct comparison of energy usage.

5.2.6 ECM – Install Ground Mount Solar PV System 260 kW DC

Utility Savings		Financial Analysis	
Electricity (kWh)	300,000	Materials & Labour	\$497,250
Demand (kW)	0.0	Engineering & PM	\$98,750
Natural Gas (m ³)	0	Contingency	\$49,725
GHG (tCO ₂ e)	25.3	Total Capital Cost	\$645,725
GHG Baseline Reduction	72%	Utility Savings	\$48,000
EUI Reduction (ekWh/m ²)	8.80	Annual O&M	\$3,900
TEDI Reduction	0%	Simple Payback	13.5
		Net-Present Value	\$228,373

Existing Conditions:

The WWTP currently purchases all electricity from the Local Distribution Company.

Proposed Measure:

The property has significant opportunity to accommodate a large number of solar panels. On the Northern and Western sides of the facility are large areas of open land that could be used for electricity generation via ground mounted solar panels. This measure recommends installing a net-metered system of 260 kW DC solar PV panels to offset 300,000 kWh of facility consumption.

Proposed Measure	Installed Capacity (kW DC)	Estimated Generation (kWh)
Ground Mount Solar PV System	260	300,000

Under a net-metering scenario the energy generated by the panels is sent to the distribution system for a credit towards electricity costs. Excess generation credits can be carried forward to offset future electricity costs for a period of up to 12 months.

A Solar PV System of the size above is sufficient to offset 90% of the remaining electricity loads after all decarbonizing measures have been implemented.

Implementation and Non-Financial Considerations:

Implementing a ground-mounted solar PV system requires suitable land, zoning and electrical approvals, and coordination with utility interconnection standards.

Construction may temporarily impact site access, but long-term disruption is minimal. Non-financial considerations include aesthetics and future land use flexibility.

Measurement and Verification:

Net-metered renewable energy installations will meet IPMVP Option B M&V requirements as they will be independently metered by the distribution company. Generation data is commonly provided on a monthly basis.

5.2.7 ECM – Install Ground Mount Solar PV System 510 kW DC

Utility Savings		Financial Analysis	
Electricity (kWh)	600,000	Materials & Labour	\$975,375
Demand (kW)	0.0	Engineering & PM	\$193,125
Natural Gas (m ³)	0	Contingency	\$97,538
GHG (tCO ₂ e)	50.6	Total Capital Cost	\$1,266,038
GHG Baseline Reduction	144%	Utility Savings	\$96,000
EUI Reduction (ekWh/m ²)	17.60	Annual O&M	\$7,650
TEDI Reduction	0%	Simple Payback	13.3
		Net-Present Value	\$485,131

Existing Conditions:

The WWTP currently purchases all electricity from the Local Distribution Company.

Proposed Measure:

The property has significant opportunity to accommodate a large number of solar panels. On the Northern and Western sides of the facility are large areas of open land that could be used for electricity generation via ground mounted solar panels. This measure recommends installing a net-metered system of 510 kW DC solar PV panels to offset 600,000 kWh of facility consumption.

Proposed Measure	Installed Capacity (kW DC)	Estimated Generation (kWh)
Ground Mount Solar PV System	510	600,000

Under a net-metering scenario the energy generated by the panels is sent to the distribution system for a credit towards electricity costs. Excess generation credits can be carried forward to offset future electricity costs for a period of up to 12 months.

A Solar PV System of the size above is sufficient to offset 90% of the remaining electricity loads after all decarbonizing measures have been implemented.

Implementation and Non-Financial Considerations:

Implementing a ground-mounted solar PV system requires suitable land, zoning and electrical approvals, and coordination with utility interconnection standards. Construction may temporarily impact site access, but long-term disruption is minimal. Non-financial considerations include aesthetics and future land use flexibility.

Measurement and Verification:

Net-metered renewable energy installations will meet IPMVP Option B M&V requirements as they will be independently metered by the distribution company. Generation data is commonly provided on a monthly basis.

5.2.8 Low or No-Cost Additional Recommendations

The following recommendations are considered low- or no-cost measures and have not been quantified through energy modeling. While their energy savings may be minimal or difficult to measure, they are expected to contribute positively to overall energy performance. These actions typically involve operational adjustments, minor equipment improvements, or behavioral changes that require little to no capital investment. Due to their low implementation cost and potential to support broader energy management efforts, they are recommended as practical steps to enhance efficiency. Even if the impact is small, these measures often help reinforce a culture of energy awareness and can complement larger retrofit initiatives.

5.2.8.1 Truckway Isolation

Located in the workshop of the Administration Building is a bay door that allows vehicle access for the removal of bio-solids from the facility. The area where the vehicles park for loading is referred to as the Truckway.

During the site visit it was noted that there are two doors between the Truckway and the main workshop area. One of these doors, a self-closing standard door, remains closed at all times. While the other, a sliding door that spans from floor to ceiling, remains open.

It is suggested that site staff close this door permanently and only allow access to the Truckway through the self-closing standard door. This will reduce the amount of outside air that enters the main workshop area when the garage bay door is open and will reduce the heating requirements for this space.

5.2.8.2 Truckway Bay Door Heating Lockout

When vehicles enter the Administration Building through the Truckway bay door, a substantial amount of heat energy escapes to the outside environment. This heat loss

becomes even more significant if the bay door remains open while the heating system continues to operate, leading to unnecessary energy consumption and increased operating costs. To address this issue, it is recommended that a simple lockout control be installed to link the bay door with the heating system. This control would prevent the heating system from operating when the door is open, thereby avoiding wasteful heating during periods of exposure. This low-cost measure offers an effective way to reduce energy losses and improve the overall efficiency of the space with minimal investment.

5.3 Energy modelling approach

Building energy simulations were prepared for the Maitland Recreation Centre, located in Goderich, Ontario using eQuest, a DOE-2 driven software that has been tested according to ANSI/ASHRAE Standard 140-2017 Standard Method of Test for the Evaluation of Building Energy Analysis Computer Programs. The Proposed design energy model reflects most up to date drawings provided combined with information gathered from an on-site walkthrough of the building and systems.

Energy Modeling Software and Notes:

- eQuest v3.65 Build 7173 – DOE 2.2
- All building components and loads have been considered, including building envelope, heating, ventilation and air conditioning systems and plant, service and domestic water heating, lighting and miscellaneous plug loads.
- The results shown are based on the output of the hourly energy simulation software and are reflective of the modelling assumptions and design parameters listed throughout this report.
- While the work was performed with reasonable care and in accordance with the latest professional standards, the actual energy use of the building will differ based on various factors that influence the actual energy cost of the building including but not limited to: weather, variations in occupancy, workmanship, depreciation of the thermal resistance of building materials, occupant and operator behaviour, and building operation.

Documents Referenced:

- Architectural Drawings: 1981-2006, 2024 Site Visit Data
- Mechanical Drawings: 1981-2006, 2024 Site Visit Data
- Electrical Drawings: 1981-2006, 2024 Site Visit Data

For Simulation Inputs, Parameters used, and Simulation Results, please see Appendix G: Energy Model Documentation.

5.4 Embodied Carbon Impacts

Embodied carbon refers to the greenhouse gas emissions released during the production, transport, installation, maintenance, and disposal of building materials and systems. Unlike operational carbon, which is tied to a building's energy use, embodied carbon is "locked in" once construction or retrofit work is complete. As buildings become more energy efficient and grids decarbonize, embodied carbon makes up a growing share of total lifecycle emissions, making it a critical consideration in deep retrofits and long-term climate strategies. The following describes the impacts on Embodied Carbon in relation to the deep retrofit measures recommended within this report.

Window Glass Replacement Measures

These recommended measures propose the replacement of the existing double-glazed glass with a high-performance triple-glazed system. The new systems will significantly enhance thermal performance, reduce heating and cooling loads, and improve occupant comfort. Beyond operational energy savings, this upgrade will also involve a one-time increase in embodied carbon due to the manufacture and transport of new glazing units and framing materials, and the disposal of existing components.

Embodied carbon associated with the triple-glazed glass and curtain walls was estimated using benchmark values from the Building Transparency Organization's Embodied Carbon in Construction Calculator's database of Environmental Product Declarations (Building Transparency, 2024). Based on these sources:

- Double-glazed Exterior Glass systems typically have an embodied carbon intensity of approximately 98.5 kg CO₂e/m² of façade area.
- Triple-glazed Exterior Glass systems with improved thermal breaks range average 164 kg CO₂e/m²

To illustrate, a placement of approximately 150 m² of curtain wall (approximate size of the pool exterior glass at the MRC) translates to:

- Baseline embodied carbon: ~14,775 kg CO₂e
- Proposed system: ~24,600 kg CO₂e
- Net increase: ~9,825 kg CO₂e

While the proposed curtain wall retrofit introduces an initial increase in embodied carbon, this is fully offset within the operational life of the asset through improved thermal performance. Continued energy savings over the lifespan of the system provide a strong net carbon benefit and align with long-term decarbonization goals.

Heat Pump Installation Measures

Facilities currently use conventional natural gas-fired HVAC systems for a significant portion of space heating, typically relying on mid-efficiency furnaces or boilers. Recommended measures propose replacing these fossil fuel-based systems with electric air-source heat pumps (ASHPs), which offer high-efficiency performance—often exceeding 100% due to their ability to transfer rather than generate heat. This transition is

expected to significantly reduce operational greenhouse gas (GHG) emissions, particularly when powered by relatively clean electricity grid.

In retrofits aiming to decarbonize HVAC systems, the embodied carbon difference between keeping a gas-fired unit vs. installing a new electric heat pump unit is relatively small. Conventional rooftop MAUs, HRVs, and dehumidifiers all carry an upfront carbon footprint largely influenced by the quantity of steel, aluminum, and other materials used in manufacturing. Replacing a gas burner with a heat pump or electric heater does not drastically change the manufacturing emissions – it may add slightly to the complexity (and thus a few hundred extra kg CO₂e at most), but the magnitude remains in the same range (Santos, 2023). For instance, a large heat recovery unit's embodied carbon is ~24 tons CO₂e whether it's paired with a gas furnace or an electric coil (IVL Swedish Environmental Research Institute, 2024).

From a climate perspective, this means the Town of Goderich owners can pursue electrification for operational carbon reduction without worrying about a significant “embodied carbon penalty.” The embodied carbon of the new electric HVAC equipment will typically be paid back in operational savings (emissions avoided by not burning gas) in just a few years of use (Finnegan, Jones, & Sharples, 2018). It is still important to source equipment with Environmental Product Declarations when possible, to accurately account for these impacts. In North American cold climates, manufacturers are beginning to provide EPDs which will improve the data available.

In summary, commercial heat pump systems offer major operational CO₂ reductions with only minimal embodied carbon differences compared to conventional gas units, making them an attractive choice for low-carbon retrofits.

6. GHG Reduction Pathway Capital Plan

This section summarizes the results from the GHG reduction pathway analysis, illustrating a strategic plan for achieving the Town's emission reduction goals. Three pathways were developed, each detailing a sequence of energy conservation measures (ECMs) and capital replacements, with differing levels of GHG reductions and investment timelines.


Pathways Analyzed:

- **Minimum Performance Scenario:**
 - Achieves at least **50% GHG reduction by year 10.**
 - Achieves at least **80% GHG reduction by year 20.**
 - Balances incremental investment over a longer time frame.
- **Aggressive Dep Retrofit Scenario:**
 - Accelerates implementation timeline significantly.
 - Achieves **50% GHG reduction within 5 years.**
 - Meets or exceeds **80% GHG reduction by year 20.**
 - Front-loads investments for quicker GHG reductions.
- **Business-As-Usual Scenario (BAU):**
 - Reflects "like-for-similar" equipment replacements without targeted emission reductions.
 - Serves as a baseline for comparing emission impacts and capital investments.

Additional analyses of these pathways can be found in Appendix F: Sensitivity Analysis, where key variables such as the Carbon Tax, grid emissions factors, and future weather impacts are investigated.

6.1 MRC Pathway Analyses

Figure 21: MRC Pathways Results



The table below summarizes the key financial and GHG-related outcomes of each pathway over the 20-year analysis period:

Table 9: MRC Pathways Results

Metric	Minimum Performance	Aggressive Deep Retrofit	Business As Usual
Capital Cost	\$6,313,490	\$5,532,788	\$2,208,394
External Funding	\$1,294,266	\$1,383,197	-
BAU Avoided Costs	\$2,208,394	\$2,208,394	
Residual Value at Study End	\$1,757,764	\$707,148	\$397,994
Incremental Costs	\$2,810,831	\$1,941,196	-
Operating Costs	\$11,572,724	\$11,725,763	\$10,472,299
5-year GHG Reduction (tCO ₂ e)	-23 (-5.7%)	202 (50.9%)	
10-year GHG Reduction (tCO ₂ e)	203 (51.3%)	299 (75.3%)	
20-year GHG Reduction (tCO ₂ e)	330 (83.3%)	345 (86.9%)	
Incremental LC Cost (20-year)	\$2,551,485	\$2,885,506	-
Cost per tonne CO ₂ e abated (\$ILCC/tCO ₂ e)	\$386	\$419	-

- **Capital Cost:** Refers to the initial expenditure required to acquire, construct, or set up an asset or project, such as buildings, equipment, or infrastructure. It includes all costs associated with the development or purchase, excluding ongoing operational or maintenance expenses.
- **BAU Avoided Costs:** The avoided costs from the Business-As-Usual capital renewal plan from the selection of alternative replacements.
- **Residual Value:** Residual value is the estimated amount that an asset is worth at the end of its useful life, after accounting for depreciation or wear and tear.
- **Incremental Costs:** The increase or decrease in the cost of construction, relative to the baseline costs outlined by the facility BCA.
- **Incremental Lifecycle (LC) Cost:** Incremental life cycle cost refers to the additional costs incurred when comparing two or more alternatives over their entire lifespan. It includes the extra costs of owning, operating and maintaining one option versus another, helping to evaluate the financial impact of choosing a particular solution or investment over time.
- **Cost per tonne CO₂e abated (\$ILCC/tCO₂e):** Incremental cost per tonne of carbon abated refers to the additional cost incurred to reduce one tonne of carbon dioxide (or its equivalent) emissions through a specific mitigation measure or pathway.

Recommended ECM Comparison Matrix


The following matrix summarizes the recommended energy conservation measures and indicates their year of implementation for each of the GHG reduction pathways.

Table 10: MRC Recommended ECMs

ECM Description	Year of Implementation	
	Minimum Performance	Aggressive Deep Retrofit
Recommissioning of the Geothermal Systems	2025	2025
Recommissioning of the BAS and Related Systems	2025	2026
Electrification of HRU's and MAU	2028	2027
Electrification of Unit Heaters	-	2044
Install Rooftop Solar PV System	2032	2027
Install Water-Source Heat Pump Boilers	2034	2029
Electrification of DH3	2044	2028

6.2 WWTP Pathway Analyses

Figure 22: WWTP Pathways Results



The table below summarizes the key financial and GHG-related outcomes of each pathway over the 20-year analysis period:

Table 11: WWTP Pathways Results

Metric	Minimum Performance	Aggressive Deep Retrofit	Business As Usual*
Capital Cost	\$1,190,016	\$1,525,183	-
External Funding	\$297,504	\$381,296	-
Residual Value at Study End	\$162,161	\$116,042	-
Operating Costs	\$1,733,395	\$679,080	\$2,836,827
20-Year Operational Cost Savings	\$1,103,432	\$2,157,747	-
20-Year LCC	\$2,463,747	\$1,706,924	-
5-year GHG Reduction (tCO ₂ e)	0 (-0.6%)	20 (55.5%)	-
10-year GHG Reduction (tCO ₂ e)	24 (67.1%)	24 (67.2%)	-
20-year GHG Reduction (tCO ₂ e)	29 (81.5%)	32 (91.3%)	-

*Aladaco is unable to provide incremental cost analysis under the GHG Reduction Pathway Analysis due to the absence of a BCA for the Goderich WWTP.

- **Capital Cost:** Refers to the initial expenditure required to acquire, construct, or set up an asset or project, such as buildings, equipment, or infrastructure. It includes all costs associated with the development or purchase, excluding ongoing operational or maintenance expenses.
- **Residual Value:** Residual value is the estimated amount that an asset is worth at the end of its useful life, after accounting for depreciation.
- **20-Year Operational Cost Savings:** The operational cost savings between the business-as-usual scenario and the GHG Reduction Pathway over the 20-year study period.
- **20-Year Life-Cycle Cost (LCC):** The combined 20-year cost off the GHG Reduction Pathways, accounting for capital costs, operating costs, external funding, and residual value.

Recommended ECM Comparison Matrix

The following matrix summarizes the recommended energy conservation measures and indicates their year of implementation for each of the GHG reduction pathways.

Table 12: WWTP Recommended ECMs

ECM Description	Year of Implementation	
	Minimum Performance	Aggressive Deep Retrofit
Thermostat Upgrades	2026	2026
Reduce Exhaust Area for Filter Press	2026	2027
Install 260 kW Ground Mount Solar PV System	2026	-
Install 510 kW Ground Mount Solar PV System	-	2026
Install Aeration Blower	2030	-
Electrification of Tube Heaters	2034	2044
Electrification of the MAU	2035	-

6.3 Recommended Pathways for Implementation

6.3.1 Maitland Recreation Centre

The Minimum Performance Pathway is recommended for implementation at the MRC. This scenario more closely aligns energy upgrades and decarbonization measures with the natural replacement cycles of existing building systems, reducing disruption to facility operations and minimizing additional capital expenditures. By coordinating project timing with the lifecycle of key equipment, the Town can effectively balance infrastructure renewal with targeted emissions reductions.

Benchmarking analysis indicates that the MRC currently operates above median energy-use intensities for similar recreation facilities, primarily due to its year-round ice rink operations and related mechanical systems. Recognizing this, the Minimum Performance Pathway prioritizes cost-effective electrification of existing heating loads through measures such as the phased installation of air-source heat pumps, leveraging and optimizing the existing geothermal infrastructure, and electrifying water heaters with water-source heat pumps. Geothermal system recommissioning is a critical early step in this pathway, ensuring the geothermal field's capacity is fully assessed and optimized to maximize the efficiency and effectiveness of subsequent retrofit measures.

Financially, the Minimum Performance scenario offers a notably lower incremental lifecycle cost (\$2,551,485 over 20 years) compared to the Aggressive Deep Retrofit scenario (\$2,885,506), and importantly, results in a more moderate impact on operating costs—an essential consideration given the anticipated operational cost increases from transitioning heating equipment from natural gas to electricity.

Overall, the Minimum Performance Pathway effectively meets the Town's targeted 80% emissions reduction by 2045, achieves cost-effective asset renewal, and delivers significant GHG reductions without incurring unnecessary financial strain or operational disruption.

Table 13: MRC Modelled Pathway Consumption Results

Modelled Pathways Results	Electricity (kWh)	Natural Gas (m ³)	tCO ₂ e
Minimum Performance Scenario (Recommended)	2,950,552	7,380	66.4
Aggressive Deep Retrofit Scenario	2,925,143	0	51.8

6.3.2 Wastewater Treatment Plant

The Aggressive Deep Retrofit Pathway is recommended for implementation at the Goderich Wastewater Treatment Plant. Unlike the Maitland Recreation Centre, benchmarking indicates that the WWTP currently operates more efficiently than typical Ontario wastewater facilities, with an energy use intensity significantly below the provincial average. However, the plant's operational profile, dominated by electricity consumption, provides substantial opportunities for achieving both deep GHG reductions and notable operational cost savings through early and aggressive energy efficiency improvements and renewable energy integration.

Central to this pathway is the installation of a large-scale ground-mounted solar PV system, which substantially reduces purchased electricity and associated emissions, directly translating to reduced operational expenses. Additional measures include electrification of existing natural gas-fired heating systems through air-source heat pumps and targeted efficiency improvements to high-energy-consuming process equipment. These combined measures yield substantial operational savings of approximately \$2.16 million over the 20-year study period, significantly greater than the savings (\$1.1 million) projected under the Minimum Performance scenario.

Although this aggressive approach requires higher upfront capital investment, it substantially decreases annual operating expenses, resulting in a lower total lifecycle cost over 20 years (\$1,706,924) compared to the Minimum Performance scenario (\$2,463,747). Additionally, proactively addressing emissions reductions through comprehensive electrification and renewable generation positions the WWTP for future operational resilience and reduced exposure to volatility in energy markets.

Ultimately, the Aggressive Deep Retrofit Pathway aligns strongly with the Town's emissions reduction objectives, leverages the WWTP's operational characteristics for maximum efficiency gains, and delivers robust long-term financial and environmental benefits.

Table 14: WWTP Modelled Pathway Consumption Results

Modelled Pathways Results	Electricity (kWh)	Natural Gas (m ³)	tCO ₂ e
Minimum Performance Scenario	367,467	0	6.5
Aggressive Deep Retrofit Scenario (Recommended)	155,183	164	3.1

7. Demand Forecasts

7.1 Maitland Recreation Centre

The MRC electrical supply is provided via a pad mounted 3-phase transformer with a capacity of 835 MVA. The main disconnect is rated for 1600 A at 600 V, resulting in a panel capacity of 960 kW. Based on the modelled forecast of future facility peak demand there is sufficient capacity at the MRC to support the implementation of either of the proposed GHG Reduction Pathways.

Table 15: MRC Current and Future Demand Forecasts

GHG Reduction Pathway	Current Peak Demand	Future Peak Demand	Required Additional Capacity
Minimum Performance Scenario	356 kW	605 kW	None
Aggressive Deep Retrofit Scenario	356 kW	610 kW	None

7.2 Wastewater Treatment Plant

The WWTP main disconnect is rated for 400 A at 600 V, resulting in a panel capacity of 240 kW. Based on the modelled forecast of future facility peak demand there is sufficient capacity at the WWTP to support the implementation of either of the proposed GHG Reduction Pathways.

Table 16: WWTP Current and Future Demand Forecasts

GHG Reduction Pathway	Current Peak Demand	Future Peak Demand	Required Additional Capacity
Minimum Performance Scenario	145 kW	223 kW	None
Aggressive Deep Retrofit Scenario	145 kW	230 kW	None

8. Conclusion

This GHG Reduction Feasibility Study has provided the Town of Goderich with comprehensive, actionable strategies to significantly reduce emissions from the Maitland Recreation Centre and the Goderich Wastewater Treatment Plant. Guided by clear emissions reduction targets aligned with the Federation of Canadian Municipalities' Community Buildings Retrofit initiative, the study identified technically viable and financially feasible pathways tailored to the distinct operational characteristics and opportunities present at each facility.

The two main scenarios analyzed—Minimum Performance and Aggressive Deep Retrofit—each meet or exceed the targeted 80% emissions reduction by 2045. The study incorporated thorough benchmarking analyses, which showed that the MRC currently operates above median energy-use intensities for comparable recreation facilities, primarily due to its year-round arena operations. Conversely, the WWTP was found to be operating significantly more efficiently than provincial benchmarks, highlighting unique opportunities for operational savings.

For the MRC, the recommended Minimum Performance Pathway prioritizes a phased electrification approach. By strategically sequencing decarbonization measures such as geothermal system recommissioning, water-source heat pumps, and air-source heat pumps to more closely align with planned equipment renewal timelines, this pathway spreads capital investments over a longer period, effectively managing upfront costs and moderating operational impacts associated with the transition from natural gas to electric heating equipment.

At the WWTP, the recommended Aggressive Deep Retrofit Pathway maximizes operational cost savings and emissions reductions through immediate investments in renewable energy generation and efficiency improvements. The installation of a large-scale ground-mounted solar PV system, complemented by targeted efficiency measures, and electrification of heating loads, significantly reduces purchased electricity. This scenario generates approximately \$2.16 million in operational cost savings over 20 years, providing both environmental and financial benefits to the Town.

Both recommended pathways underscore the importance of aligning retrofit strategies with asset lifecycle planning, operational resilience, and fiscal responsibility. By proactively securing external funding, the Town can help to offset upfront capital expenses and enhance project feasibility.

Aladaco sincerely appreciates the active participation and valuable contributions of Town staff throughout this process. Their insight, operational expertise, and collaborative spirit were instrumental in shaping realistic, implementable solutions. Additionally, we extend our thanks to the Goderich Town Council for the opportunity to present these findings and for their ongoing commitment to sustainability and climate leadership. This study provides a clear foundation for informed decision-making and effective progress toward achieving the Town's long-term climate and sustainability objectives.

Appendices

Appendix A: Design Workshop Summary Report



ALADACO

Powering Progress with
Sustainable Solutions

DESIGN WORKSHOP SUMMARY REPORT

Prepared for The Town of Goderich
GHG Reduction Pathways Feasibility Study

Date: March 10, 2025

ALADACO CONSULTING INC.

6-425 Hespeler Road, Suite 378
Cambridge, ON N1R 8J6

aladaco.com

Table of Contents

1. Introduction.....	1
2. Project Timeline.....	1
3. Site Investigations	1
4. Energy Modelling.....	2
5. Design Workshop	3
5.1. Workshop Attendees	3
5.2. Decarbonization Measure Selections.....	4
6. Conclusion and next steps	8
7. Appendix: PPT Presentations	9

Table of Figures

Table 1 Project Timeline	1
Table 2 Workshop Attendees	3
Table 3 Selected ECMs	4
Table 4 Disqualified ECMs	6

1. Introduction

This Design Workshop Summary Report is intended to provide the Town of Goderich (Goderich) with a summary of the outcomes from the recently completed Design Workshop for their GHG Reduction Pathways Feasibility Study project funded through the Federation of Canadian Municipalities Green Municipal Fund. This Report will also provide a summary of the completed site investigations and energy modelling efforts completed to date.

Included within the Appendix of this document are copies of the PowerPoint presentation slides developed by Aladaco Consulting Inc. (Aladaco) to conduct the Design Workshops.

2. Project Timeline

Below is a summary of the project milestones as described within Aladaco's RFP response for the GHG Reduction Pathways Feasibility Study. To date the Site Investigations, Energy Model, and Design Workshop phases of the project have been completed. The expected completion dates for the remaining milestones are indicated in the table. For further details on specifics of each milestone, please refer to the Study Review Process slide within Appendix: PPT Presentations.

Table 1 Project Timeline

Project Milestone	Timeline for Completion
Site Investigations	Complete
Energy Modelling	Complete (see section 4 Energy Modelling)
Design Workshop	Complete
Measure Level Analysis	February to April, 2025
Scenario Development	April to May, 2025
Decision Making Workshop	May, 2025
Final GHG Reduction Pathway Feasibility Study Report and Presentation	August 2025

3. Site Investigations

On October 29th, 2024, Aladaco's site investigator, Sean Pittman, P.Eng, CEM, CMVP, CBCP, met with Town of Goderich site staff at the Maitland Recreation Centre (MRC, 190 Suncoast Dr E, Goderich) to conduct the on-site investigation portion of this project.

The investigation began with a meeting attended by Sean Pittman (Aladaco) and Goderich Staff including Jessica Clapp - Project Lead, Greg Morningstar - Recreation Facilities Supervisor, and Kyle Williams - Community Services and Operations Manager. The meeting outlined the project scope and objectives, the data and documentation received to date, facilitated discussions on on-going operational and maintenance items, as well as the facility operational parameters. Following the meeting Aladaco was provided access to all areas of the facility to document existing equipment and assess facility systems such as: the building envelope, mechanical and electrical systems, internal loads, building schedules, and potential for renewable energy systems.

Similarly, an on-site investigation was conducted at the Wastewater Treatment Plant (WWTP, 211 Sunset Dr, Goderich) on October 30, 2024. A meeting held at this location was attended by Sean Pittman (Aladaco), Jessica Clapp - Project Lead (Goderich), and Steve Johnston (Veolia Water Canada), prior to conducting the on-site documentation portion of the investigation.

In addition to the on-site portion of the Site Investigations, Aladaco has also completed a full review of all available facility drawings, operation and maintenance records, and building condition assessments provided by the Town of Goderich. We have also completed a review and analysis of facility utility data from 2021 to 2023.

4. Energy Modelling

Detailed energy models were developed for each facility to assess facility energy consumption. These models will also be used to inform measure level analysis when determining existing and retrofit case consumption. In accordance with GMF Study Guidance, the models were calibrated following ASHRAE 14 standards, and a calibration report will be provided with the Final Report.

The models captured all key building characteristics and systems impacting energy use and emissions, including:

- Building orientation and envelope components
- Hydronic, HVAC, and dehumidification systems
- Electrical systems, lighting, and plug loads
- Refrigeration plants and associated equipment
- Automation, control, and heat recovery systems
- Process equipment and renewable energy generation

For systems not accurately represented within the energy modeling software (e.g., wastewater aeration blowers), separate analyses were conducted in Excel and integrated into the results. If required, these supplementary analyses can be provided along with the energy model files.

Energy models will continue to be refined and developed throughout the study process, with finalized calibration reports and model files delivered with the Final Report.

5. Design Workshop

On February 5, 2025, Aladaco conducted Design Workshops for each of the facilities. The in-person workshops took place at the Town of Goderich offices located at 57 West St, Goderich. The intent of the Design Workshops was to gather all relevant stakeholders to review preliminary decarbonization measures and their feasibility, while also encouraging engagement and discussion on the challenges and opportunities at each facility.

Please refer to Appendix: PPT Presentations for more details.

5.1. Workshop Attendees

The following personnel attended and participated in the Design Workshops.

Table 2 Workshop Attendees

Stakeholders	Organization	Title
Jessica Clapp	Town of Goderich	Asset Management and Environmental Services Coordinator (Goderich Project Lead)
Janice Hallahan	Town of Goderich	Chief Administrative Officer
Deanna Hastie	Town of Goderich	Director of Corporate Services/Treasurer
Sean Thomas	Town of Goderich	Director of Community Services, Infrastructure, and Operations
Kyle Williams	Town of Goderich	Community Services and Operations Manager
Greg Morningstar	Town of Goderich	Recreation Facilities Supervisor
Steve Johnston	Veolia Water Canada	Assistant Project Manager
Sean Pittman	Aladaco Consulting Inc.	Conservation & Energy Management Lead (Aladaco Project Lead)
Taylor Wilson	Aladaco Consulting Inc.	Technical Lead – Energy & Carbon Management
Jeremiah Heffernan	HEMCon Energy Modeling Solutions	Founder, Principal Energy Analyst

5.2. Decarbonization Measure Selections

One of the primary goals of the Design Workshop was to form a consensus on a selection of Decarbonization or Energy Conservation Measures (ECMs) for inclusion in the Measure Level Analysis phase of this project. A selection of measures for each facility was presented to the groups and the feasibility of each was discussed. Selection of specific measures for further investigations is required to remain within the scope of the feasibility study's budget.

Below you will find summary tables of all measures which were included for consideration in the Design Workshops. Those selected for further analysis are included in the Selected ECM table, those which were not selected are in the Disqualified ECM table.

Table 3 Selected ECMs

Facility	Measure Description	Description of the Selected Measure
MRC	Recommission Geothermal System	Conduct a detailed assessment of system performance to identify inefficiencies in controls, pumping, and heat exchange. Evaluate system capacity for future additional heating integrations
MRC	Install Water-Source Heat Pumps	Install additional Water-Source Heat Pumps connected to the existing Geothermal System to provide additional heating for Domestic Hot Water and the Pool
MRC	Variable Frequency Drives - Pool	Install Variable Frequency Drives on Pool Pumps that are currently manually throttled
MRC	Variable Frequency Drives - Heating Loop	Install additional controls to dynamically adjust the speed of existing variable frequency drives on heating loop pumps based on system demand
MRC	BAS Recommissioning	Conduct Existing Building Recommissioning on Building Automation Systems. Based on system age this measure is expected to occur later in the implementation timeline

Facility	Measure Description	Description of the Selected Measure
MRC	Electrify Heating	Replace fossil fueled heating equipment with electric alternatives (heat pumps or electric resistive heaters)
MRC	Install Solar PV Panels	Install rooftop mounted Solar PV panels. Requires staging with existing capital plans to repair the roof
WWTP	Reduce Exhaust Area for Filter Press	Install plastic curtain wall to reduce the area required to be ventilated during operation of the filter press
WWTP	Replace Aerators with Low-Speed Models	Replace the existing mechanical aerators with models designed to operate at lower speeds and/or at higher oxygen delivery rates
WWTP	Upgrade Thermostats	Install new thermostats to reduce interior air temperature during unoccupied periods
WWTP	Isolate Truckway	Improve the isolation between the Truckway and the workshop area and reduce the impacts to heating load when the bay doors are opened
WWTP	Lockout Truckway Heating	Lock-out heating in the Truckway when the bay doors are open
WWTP	Electrify Heating	Replace fossil fueled heating equipment with electric alternatives (heat pumps or electric resistive heaters)
WWTP	Install Solar PV Panels	Investigate the optimal approach to installing ground-mount Solar PV panels

Table 4 Disqualified ECMs

Facility	Measure Description	Rationale for Disqualification
MRC	Improve Building Envelope	High implementation cost and limited return potential
MRC	Liquid Pool Cover	Limited return potential. The Town of Goderich intends to pursue this ECM independently from this study
MRC	Reduce Pool Make-up Water	During stakeholder engagement it was determined that make-up water is controlled automatically to maintain sufficient water levels within the pool, thus there is no opportunity to reduce the volume of make-up water.
MRC	Cold Water Ice-Resurfacing	The viability of this technology is still in question and operators are concerned that this system will not produce the quality of ice required to maintain their standards of service.
MRC	Electric Ice-Resurfacer	High capital costs and limited return potential
MRC	Install LED Lamps	Most of the facility's lighting has already been retrofitted to LED
MRC	Install High-Efficiency Pumps	The majority of the facility's pumps are already high-efficiency models. On replacement Goderich staff are selecting the highest efficiency models available
WWTP	Improve Building Envelope - Windows	Due to the limited return potential this measure is not included in future analysis, Aladaco will however include this retrofit in the energy models to reflect Goderich's intent to proceed with a window reduction

Facility	Measure Description	Rationale for Disqualification
WWTP	Improve Building Envelope - Other	High implementation cost and limited return potential
WWTP	Improve Process Related VFD Use	Many of the pumps and motors are equipped with VFDs that act dynamically to reduce energy consumption
WWTP	Replace Aerators with Aeration Blowers	A similar measure to this was previously investigated by the Town and was not selected for implementation. This measure also requires more significant disruption to WWTP operations than the aerator replacement measure
WWTP	Install High-Efficiency Pumps	The majority of the facility's pumps are already high-efficiency models. On replacement Goderich staff are selecting the highest efficiency models available
WWTP	Increase SCADA/BAS capabilities	SCADA system has been recently updated. Any additional capabilities required to implement any of the selected measures will be included within those analyses.
WWTP	Install LED Lamps	While lamp retrofit opportunities exist, the electrical load associated with lighting at this facility is small in comparison to other measures. Energy models will be updated to reflect a gradual phasing out of fluorescent lamps over the next 5 years, but this measure will not be included in additional analysis.

6. Conclusion and next steps

Aladaco would like to thank the Town of Goderich for their engagement and participation in the feasibility study process. In completing these first steps we have laid the foundation for a final report that will provide the most feasible and cost-effective decarbonization pathways available to the Town.

Our next steps in this process include completing the Measure Level Analysis and Pathways Scenario Planning prior to meeting again with stakeholders to decide on the optimal pathways to meeting the decarbonization targets. We look forward to continuing to collaborate with the Town throughout these steps.

7. Appendix: PPT Presentations

Aladaco Consulting Inc.
**Maitland Recreation Centre
Town of Goderich
Design Workshop**



Agenda

- Introductions
- Review of the Study Process
- Confirmation of Project Goals
- Current Emissions and Distribution
- Existing Capital Plans Review
- Decarbonization Measures
- Funding Opportunities
- Next steps and Discussion





THIS IS A LIVE DOCUMENT

Discussion and engagement are encouraged. We will build out and edit this document together today and distribute a final copy to all participants.




Introductions - Aladaco

- Aladaco Consulting Inc
 - Founded in 2007
 - Energy professionals providing services to help organizations navigate and reach energy efficiency and decarbonization goals
 - Energy management and M&V, GHG inventorying and decarbonization pathways, CDM planning
 - IESO Industrial Technical Review Services



Sean Pittman
Conservation & Energy
Management Lead
P.Eng., CEM, CMVP



Taylor Wilson
Technical Lead - Energy &
Carbon Management
CET, CEM, CMVP



Introductions – HEMCon Energy Modeling Solutions

HEMCon is an energy analysis and building simulation firm.

We specialize in building energy models for new and existing buildings to facilitate good design decisions.



Jeremiah Heffernan
Founder, Principal Energy Analyst
P.Eng, M.Eng., G.Dip Green Energy,
BEMP, LEED AP BD+C




Introductions – Town of Goderich

- Jessica Clapp (Town of Goderich Project Lead)
Asset Management and Environmental Services
Coordinator
- Deanna Hastie
Director of Corporate Services/Treasurer
- Janice Hallahan
Chief Administrative Officer
- Greg Morningstar
Recreation Facilities Supervisor
- Sean Thomas
Director of Community Services,
Infrastructure, and Operations
- Kyle Williams
Community Services and Operations
Manager



Study Review Process



Project Goals and Outcomes

PROJECT GOALS

- Develop a tailored GHG Reduction Pathway Feasibility Study for the Town of Goderich
- Prioritize efficiency measures to reduce emissions and costs
- Align decarbonization strategies with facility needs and lifecycle planning
- Maintain current standards of service without significant cost increases



Project Goals and Outcomes


OUTCOMES

- Delivery of 3 scenarios:
 - **Minimum Performance:** 50% reduction in 10 years, 80% in 20 years
 - **Aggressive Deep Retrofit:** 50% reduction in 5 years, 80% in 20 years
 - **Business-As-Usual:** Like-for-like replacements with existing specs
- Detailed GHG reduction pathways and financial analyses
- Clear, actionable recommendations for decarbonization



GHG Emissions Calculations




IESO Grid Emissions



Natural Gas Combustion Emissions




Current Emissions and Targets



Baseline Emissions (tCO2 _e)			Targets	
Electricity	Gas	Total	50%	80%
76.3	320.2	396.5	198.3	79.3




Natural Gas Emissions Distribution



Future Grid Emissions Factors


Ontario Average Emissions Factors
(gCO₂e/kWh)



Existing Capital Replacements

Replacement Year	Equipment
2025	B-1 DHW Boiler
	Pool Water Heater
	Whirlpool Water Heater
	Roof
	Heat Pumps
	HRU-1
	HRU-2
	UH1 - UH5
	DH-1
	MUA-1
	Pool Filter Pump
	Hot Tub Filter & Jet Pump
	Pool Filter Chemical Pumps
	Filter Room Motor Starters
	Ice Resurfacer
	P110 HPLP Return Pump
	P-107 Pool Water Heating Pump
	P-108 Pool Water Heating Pump
	Boiler Room Circulation Pumps

Replacement Year	Equipment
2028	P101 HPLP Loop Pump
	P102 HPLP Loop Pump
	Ice Cube Room Heater and Pump
	CT-1
2030	Doors
	Water Feature Pump
2032	SW Corner Ground Loop
2033	Kube HPs (1 to 8)
2035	Windows
2038	DH-2
2043	Heating Loops
2050	DH-3



Based on BCA, Roof Condition Assessment Report, and
Town of Goderich Capital Replacement data



Energy Conservation Measures (ECMs)



ECMs – Geothermal System Recommissioning

PROJECT DESCRIPTION

- Conduct a detailed assessment of system performance to identify inefficiencies in controls, pumping, and heat exchange operations
- Optimize control settings for temperature setpoints, seasonal operation modes, and occupancy schedules
- Test and balance ground loop flow rates to ensure efficient heat exchange and minimize energy waste

ECM OUTCOMES

- Improve energy performance of the system (3% to 5%)
- Evaluate capacity for additional Heating opportunities
- Right size future electrification measures
- Potential to tie-in Unit Heaters





ECMs – Install Water-Source Heat Pumps

PROJECT DESCRIPTION


- Mechanical Design Drawings indicate additional Water Source Heat Pumps were originally planned to support Pool and DHW Heating
- Geothermal System Recommissioning can determine the available heating capacity

ECM OUTCOMES

- Reduce Boiler Loads
- Reduce electrification impacts and right size future electrification measures



ECMs – Install Water-Source Heat Pumps



ECMs – Building Envelope Improvements

PROJECT DESCRIPTION



- Wall Insulation Improvements
- Air Sealing
- Decrease Thermal Bridging
- Windows & Doors
- Roof

ECM OUTCOMES


- Estimates of up to 10% to 15% Energy Savings
- Improved Occupant Comfort
- Reduces Equipment Cycling and prolongs expected life



ECMs – Building Envelope Improvements



ECMs – Variable Frequency Drives



PROJECT DESCRIPTION

- Variable Frequency Drives on Pool Pumps & Heat Loop
- Requires enabling/programming for Heat Loop and new VFDs for Pool Pumps

ECM OUTCOMES

- Significant energy savings
- Increased controls to match operation to requirements
- Prolongs expected life



ECMs – Other Opportunities

PROJECT DESCRIPTION

- Liquid Pool Cover
- Cold Water Ice-Resurfacing
- Electric Ice-Resurfacer
- LED Lamps

- BAS Recommissioning
- High Efficiency Pumps
- Pool Make-up Water



ECMs – Heating Electrification

PROJECT DESCRIPTION

- Replace all Natural Gas heating sources with electric alternatives (resistance or Heat Pumps)
- Includes Pool Boilers, DHW Boilers, Unit Heaters, Rooftop Units

ECM OUTCOMES

- Significant reduction in GHG
- Increased building electrical loading



ECMs – Renewable Energy Generation

PROJECT DESCRIPTION

- Install Solar PV Panels on Rooftops and/or property
- 1,700 m² of approximate rooftop area available
- 250 kW DC System Capacity estimated

ECM OUTCOMES

- Significant reduction in GHG from Grid Emissions
- Up to 300,000 kWh/yr displaced energy consumption
- Rough savings of up to: \$42,000/yr and 11.4 tCO_{2e}

ECMs – Power Factor Correction


PROJECT DESCRIPTION

- Install capacitor banks to improve facility power factor

ECM OUTCOMES

- Reduce Power Factor penalties on utility bills
- Financial savings measure only, will not impact emissions or energy use.

Average PF



Funding Opportunities

Funding Entity	Program	Available Funding	Notes
IESO	Custom Retrofit	\$0.13/kWh or \$1,200/kW Peak Demand Savings	May be applicable to Heating Electrification and Heat Pump Installations
	Prescriptive Retrofit	Varies by Equipment Type	Per unit incentives for Lighting, VFDs, high-efficiency pumps, heat pumps, etc.
	Solar PV DER	\$860/kW-AC	For a 240 kW-AC system = \$206,400
Enbridge	Custom Retrofit	\$0.25/m ³ , up to \$100,000	
FCM Green Municipal Fund	GHG Impact Retrofit	Maximum of \$5 million per project.	Up to 25% as a grant and the remainder as a loan. Combined loan and grant for up to 80% of eligible project costs. 30% GHG reduction required
Canadian Infrastructure Bank	Green Infrastructure Program	Varies based on project	Provides financing to reduce investment barriers and decarbonize buildings.



ECM Summary

ECM	Energy Savings Potential	GHG Savings Potential	Implementation Cost	Life-Cycle Cost	Selected for Study
Geothermal System Recommissioning	Low	Low	\$\$	Positive	X
Installing Water-Source Heat Pumps	Medium	High	\$\$\$	Negative	X
Building Envelope Improvements	Low	Low	\$\$\$\$	Negative	
Variable Frequency Drives - Pool	Low	Low	\$\$	Positive	X
Variable Frequency Drives - Heating Loop	Medium	Low	\$	Positive	X
Liquid Pool Cover	Low	Low	\$	Positive	
Reduce Pool Make-up Water	Low	Low	\$	Positive	
Cold Water Ice-Resurfacing	Low	Medium	\$	Positive	
Electric Ice-Resurfacer	None	Medium	\$\$\$	Negative	
LED Lamps	Low	Low	\$	Positive	
BAS Recommissioning	Low	Low	\$\$	Positive	X
High-Efficiency Pumps	Low	Low	\$	Positive	
Electrification of Heating	Medium	High	\$\$\$\$	Negative	X
Solar PV Panels	None	Medium	\$\$\$	Positive	X

Next Steps

- Finalization of PPT and measures selected for analysis
- Delivery of Summary Report
- Begin Measure Level Analysis phase
- Decision Making Workshop April/May





Thank You

Questions?



Powering Progress with
Sustainable Solutions



Aladaco Consulting Inc.

Wastewater Treatment Plant Town of Goderich Design Workshop



Agenda

- Introductions
- Review of the Study Process
- Confirmation of Project Goals
- Current Emissions and Trends
- Existing Capital Plans Review
- Decarbonization Measures
- Funding Opportunities
- Next steps and Discussion





THIS IS A LIVE DOCUMENT

Discussion and engagement are encouraged. We will build out and edit this document together today and distribute a final copy to all participants.




Introductions - Aladaco

- Aladaco Consulting Inc
 - Founded in 2007
 - Energy professionals providing services to help organizations navigate and reach energy efficiency and decarbonization goals
 - Energy management and M&V, GHG inventorying and decarbonization pathways, CDM planning
 - IESO Industrial Technical Review Services



Sean Pittman
Conservation & Energy
Management Lead
P.Eng., CEM, CMVP



Taylor Wilson
Technical Lead - Energy &
Carbon Management
CET, CEM, CMVP



Introductions – HEMCon Energy Modeling Solutions

HEMCon is an energy analysis and building simulation firm.

We specialize in building energy models for new and existing buildings to facilitate good design decisions.



Jeremiah Heffernan
Founder, Principal Energy Analyst
P.Eng, M.Eng., G.Dip Green Energy,
BEMP, LEED AP BD+C




Introductions – Town of Goderich

- Jessica Clapp (Town of Goderich Project Lead)
Asset Management and Environmental Services
Coordinator
- Deanna Hastie
Director of Corporate Services/Treasurer
- Janice Hallahan
Chief Administrative Officer
- Sean Thomas
Director of Community Services,
Infrastructure, and Operations
- Steven Walmsley
Veolia Water Canada
- Steve Johnston
Veolia Water Canada



Study Review Process



Project Goals and Outcomes

PROJECT GOALS

- Develop a tailored GHG Reduction Pathway Feasibility Study for the Town of Goderich
- Prioritize efficiency measures to reduce emissions and costs
- Align decarbonization strategies with facility needs and lifecycle planning
- Maintain current standards of service without significant cost increases



Project Goals and Outcomes


OUTCOMES

- Delivery of 3 scenarios:
 - **Minimum Performance:** 50% reduction in 10 years, 80% in 20 years
 - **Aggressive Deep Retrofit:** 50% reduction in 5 years, 80% in 20 years
 - **Business-As-Usual:** Like-for-like replacements with existing specs
- Detailed GHG reduction pathways and financial analyses
- Clear, actionable recommendations for decarbonization



GHG Emissions Calculations



IESO Grid Emissions



Natural Gas Combustion Emissions



Current Emissions and Targets




Baseline Emissions (tCO2 _e)			Targets	
Electricity	Gas	Total	50%	80%
22.9	12.3	35.2	17.6	7.0



Future Grid Emissions Factors

Ontario Average Emissions Factors
(gCO₂e/kWh)



Existing Capital Replacements

Replacement Year	Equipment
2025	Primary Clarifier 1, 2, 3, & 4
	Final Clarifier 1, 2, & 3
	WAS Pump 1
	Aerator 3 & 4
	RPU2 Chemical Pumps
	UV Banks 1 & 2
	KM04 Pumps
	Pumphouse Electric Unit Heaters
	CSO Return Pumps
	ACA Exhaust Unit
	MUA-1

Replacement Year	Equipment
2028	Final Clarifier 4
	RAS Pumps 1, 2, 3, 4, 5, & 6
	WAS Pump 2
	Aerator 7
	Booster Pump
	Filtrate Pump
	Raw Water Pump
	Radiant Tube Heaters
2031	Belt Filter Press
	Grit Screener
	Aerator 5, 6, & 8
	Aeration Blower
2034	Admin Building Roof
2038	Domestic Hot Water Heater
2046	Wasting Pump
2048	Belt Filter Air Compressor

2024 Capital Work

- SCADA Improvements
- MCC/HVAC Upgrades
- Sludge Pump Replacements
- Lighting Upgrade
- WAS Pump Replacement



Energy Conservation Measures (ECMs)



ECMs – Reduce Exhaust Area for Filter Press

PROJECT DESCRIPTION


- Investigate methods of reducing the overall quantity of air exhausted and replaced during Belt Filter Press operation
- Options to include traditional interior walls, or plastic curtain walls.

ECM OUTCOMES

- Reduces natural gas consumption required to heat make-up air
- Reduces run-time of the make-up air unit fan



ECMs – Reduce Exhaust Area for Filter Press



ECMs – Building Envelope Improvements

PROJECT DESCRIPTION


- Walls Insulation Improvements
- Windows & Doors
- Window Area Reduction

ECM OUTCOMES

- Low quantity of GHG reductions
- Improved Occupant Comfort
- Reduces Equipment Cycling and prolongs expected life



ECMs – Process Related VFD Improvements



PROJECT DESCRIPTION

- Optimize the use of VFDs to reduce pumping energy
- Integrate VFD controls with SCADA to better match energy use to process requirements

ECM OUTCOMES

- Significant energy savings
- Increased controls to match operation to requirements
- Prolongs expected life



ECMs – Replace Mechanical Aerators with Aeration Blowers

PROJECT DESCRIPTION

- Replace the mechanical aerators with a diffuse aeration system
- Requires Engineering Study to determine feasibility

ECM OUTCOMES

- Reduces electrical consumption related to the treatment of wastewater



ECMs – Replace Mechanical Aerators with Low-Speed Models

PROJECT DESCRIPTION

- Replace the mechanical aerators with a diffuse aeration system
- Requires Engineering Study to determine feasibility

ECM OUTCOMES

- Reduces electrical consumption related to the treatment of wastewater



ECMs – Other Opportunities

PROJECT DESCRIPTION

- High-Efficiency Pumps
 - Thermostat Upgrades
 - LED Lamps
 - Increase SCADA/BAS capabilities
- Isolate Truckway from other interior areas
 - Lock-out heating in garage when bay doors are open



ECMs – Electrify Heating

PROJECT DESCRIPTION

- Replace MAU Natural Gas heating with electric alternative (resistance or Heat Pumps)
- Replace Radiant Tube Heaters with Heat Pumps
- Replace Electric Resistive Unit Heaters with Heat Pumps

ECM OUTCOMES

- Significant reduction in GHG
- Increased building electrical loading



ECMs – Renewable Energy Generation

PROJECT DESCRIPTION

- Install Solar PV Panels on unused property
- 5,000 m² of approximate area available

ECM OUTCOMES

- Significant reduction in GHG from Grid Emissions
- Potential to produce more energy than is consumed on-site
- Rough savings potential of up to: \$110,000/yr and

ECMs – Power Factor Correction


PROJECT DESCRIPTION

- Install capacitor banks to reduce inductive loads and improve facility power factor

ECM OUTCOMES

- Reduce Power Factor penalties on utility bills
- Financial savings measure only, will not impact emissions or energy use.

Average PF



Funding Opportunities

Funding Entity	Program	Available Funding	Notes
IESO	Custom Retrofit	\$0.13/kWh or \$1,200/kW Peak Demand Savings	Applies to process related improvements. May be applicable to Heating Electrification and Heat Pump Installations
	Prescriptive Retrofit	Varies by Equipment Type	Per unit incentives for Lighting, VFDs, high-efficiency pumps, heat pumps, etc.
	Solar PV DER	\$860/kW-AC	For a 60 kW-AC system = \$51,600
Enbridge	Custom Retrofit	\$0.25/m ³ , up to \$100,000	
FCM Green Municipal Fund	GHG Impact Retrofit	Maximum of \$5 million per project.	Up to 25% as a grant and the remainder as a loan. Combined loan and grant for up to 80% of eligible project costs. 30% GHG reduction required
Canadian Infrastructure Bank	Green Infrastructure Program	Varies based on project	Provides financing to reduce investment barriers and decarbonize buildings.



ECM Summary

ECM	Energy Savings Potential	GHG Savings Potential	Implementation Cost	Life-Cycle Cost	Selected for Study
Reduce Exhaust Area for Filter Press	Low	Low	\$	Positive	X
Building Envelope Improvements - Windows	Low	Low	\$\$	Negative	
Building Envelope Improvements - Other	Low	Low	\$\$\$\$	Negative	
Process Related VFD Improvements	Medium	Low	\$\$	Positive	
Replace Aerators with Aeration Blowers	Medium	Low	\$\$\$	Positive	
Replace Aerators with Low-Speed Models	Medium	Low	\$\$\$	Positive	X
High-Efficiency Pumps	Low	Low	\$	Positive	
Thermostat Upgrades	Low	Low	\$	Positive	X
LED Lamps	Low	Low	\$	Positive	
Increase SCADA/BAS capabilities	Low	Low	\$\$\$	Negative	
Truckway Isolation	Low	Low	\$\$	Negative	X
Lockout Garage Heating	Low	Low	\$	Negative	X
Electrification of Heating	Medium	High	\$\$\$	Negative*	X
Solar PV Panels	None	High	\$\$\$	Positive	X

Next Steps

- Finalization of PPT and measures selected for analysis
- Delivery of Summary Report
- Begin Measure Level Analysis phase
- Decision Making Workshop April/May





Thank You

Questions?



Powering Progress with
Sustainable Solutions



Appendix B: Calculations

Grid Emission Factors:

Emission Factors (CO ₂ e) - ZCB ref		
Year	Electricity (g/kWh)	Natural Gas (g/m3)
2019	30.5	1,921
2020	28.0	1,921
2021	30.0	1,921
2022	38.0	1,921
2023	38.0	1,921
2024	63.1	1,921
2025	84.4	1,921
2026	69.7	1,921
2027	84.9	1,921
2028	72.9	1,921
2029	66.0	1,921
2030	55.1	1,921
2031	53.4	1,921
2032	47.9	1,921
2033	40.7	1,921
2034	31.6	1,921
2035	28.0	1,921
2036	26.6	1,921
2037	24.9	1,921
2038	23.4	1,921
2039	21.5	1,921
2040	20.7	1,921
2041	19.8	1,921
2042	19.3	1,921
2043	18.6	1,921
2044	17.7	1,921

Financial Metrics

Financial Metrics	
Inflation (Capital)	2%
Inflation (Elec Cost)	2%
Inflation (NG Cost)	2%
Inflation (Labor)	2%
Discount Rate	4%

Utility Rates		
	MRC	WWTP
Electricity (kWh)	\$0.15	\$0.16
Demand (kW)	\$9.95	\$9.73
Natural Gas (m3)	\$0.38	\$0.72

ECM Calculations

Equipment	Quantity	Baseline		Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
		kWh	m3	kWh	m3	kWh	kW	m3						
Recommissioning of the Geothermal Systems	1	1,366,294	0	1,332,137	0	34,157	0	0	\$21,500	\$0	\$0	\$21,500	\$972	Vendor

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	NPV
Recommissioning of the Geothermal Systems	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035				\$21,705.82
Project Cost	-\$21,500														
Elec Savings	\$5,465	\$5,574	\$5,686	\$5,800	\$5,916	\$6,034	\$6,155	\$6,278	\$6,403	\$6,531	\$6,662				
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Maintenance Cost	-\$972	-\$992	-\$1,012	-\$1,032	-\$1,052	-\$1,073	-\$1,095	-\$1,117	-\$1,139	-\$1,162	-\$1,185				
Emissions Savings	2.88	2.38	2.90	2.49	2.25	1.88	1.82	1.64	1.39	1.08	0.96				
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Residual Value															
Net Cash Flow	\$4,493	\$4,583	\$4,674	\$4,768	\$4,863	\$4,961	\$5,060	\$5,161	\$5,264	\$5,369	\$5,477				

Equipment	Quantity	Baseline			Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
		BTUh Heating	kWh	m3	kWh	m3	kWh	kW	m3						
Pool Boiler B1	1	688,500	0	24,029	78,567	0	-78,567	-66	24,029	\$777,430	\$116,614	\$77,743	\$971,787	\$1,600	Vendor
Domestic B1	1	1,062,500	0	45,726	151,971	0	-151,971	-88	45,726	\$919,155	\$137,873	\$91,915	\$1,148,944	\$2,900	Vendor
Whirlpool Water Heater	1	323,190	0	4,024	13,273	0	-13,273	-44	4,024	\$480,555	\$72,083	\$48,055	\$600,694	\$400	Vendor

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Install Water-Source Heat Pump Boilers	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$2,721,424															
Elec Savings	-\$39,010	-\$39,790	-\$40,586	-\$41,397	-\$42,225	-\$43,070	-\$43,931	-\$44,810	-\$45,706	-\$46,620	-\$47,553	-\$48,504	-\$49,474	-\$50,463	-\$51,473	-\$52,502
Demand Savings	-\$1,927	-\$1,965	-\$2,004	-\$2,044	-\$2,085	-\$2,127	-\$2,170	-\$2,213	-\$2,257	-\$2,302	-\$2,348	-\$2,395	-\$2,443	-\$2,492	-\$2,542	-\$2,593
NG Savings	\$52,834	\$53,890	\$54,968	\$56,067	\$57,189	\$58,333	\$59,499	\$60,689	\$61,903	\$63,141	\$64,404	\$65,692	\$67,006	\$68,346	\$69,713	\$71,107
Maintenance Cost	-\$4,900	-\$4,998	-\$5,098	-\$5,200	-\$5,304	-\$5,410	-\$5,518	-\$5,629	-\$5,741	-\$5,856	-\$5,973	-\$6,093	-\$6,214	-\$6,339	-\$6,465	-\$6,595
Emissions Savings	121.15	124.74	121.03	123.96	125.64	128.30	128.71	130.05	131.81	134.03	134.90	135.25	135.66	136.03	136.49	136.68
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$6,997	\$7,137	\$7,280	\$7,426	\$7,574	\$7,726	\$7,880	\$8,038	\$8,198	\$8,362	\$8,530	\$8,700	\$8,874	\$9,052	\$9,233	\$9,417
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Install Water-Source Heat Pump Boilers	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					-\$2,582,731.84	
Project Cost																
Elec Savings	-\$53,552	-\$54,623	-\$55,716	-\$56,830	-\$57,966	-\$59,126	-\$60,308	-\$61,514	-\$62,745	-\$64,000						
Demand Savings	-\$2,645	-\$2,698	-\$2,752	-\$2,807	-\$2,863	-\$2,920	-\$2,978	-\$3,038	-\$3,099	-\$3,161						
NG Savings	\$72,529	\$73,980	\$75,459	\$76,969	\$78,508	\$80,078	\$81,680	\$83,313	\$84,980	\$86,679						
Maintenance Cost	-\$6,727	-\$6,861	-\$6,998	-\$7,138	-\$7,281	-\$7,427	-\$7,575	-\$7,727	-\$7,881	-\$8,039						
Emissions Savings	136.90	137.03	137.20	137.42	137.68	138.02	138.29	138.44	138.27	138.00						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$198,724												
Net Cash Flow	\$9,606	\$9,798	\$9,994	\$10,194	\$10,398	\$10,606	\$10,818	\$11,034	\$11,255	\$11,480						

Equipment	Quantity	Pump Size (HP)	Pump Flow (GPM)	Pump Speed (RPM)	Discharge Pressure (psig)	Discharge Head (Ft)	Valve Position	Cv	Pressure Drop	Adjusted Head	Adjusted Speed (RPM)	Operating Hours	kWh Savings	kW Savings	Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
Install Variable Frequency drives on Pool Pumps	1	20	600	1,800	34	78.7	70% Closed	380	1.6	75.0	1,758	8,760	1,270	0.20	\$9,065	\$1,360	\$906	\$11,331	\$0	RSMeans

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Install Variable Frequency drives on Pool Pumps	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$11,331															
Elec Savings	\$203	\$207	\$211	\$216	\$220	\$224	\$229	\$233	\$238	\$243	\$248	\$253	\$258	\$263	\$268	\$273
Demand Savings	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$2	\$3	\$3	\$3
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Emissions Savings	0.11	0.09	0.11	0.09	0.08	0.07	0.07	0.06	0.05	0.04	0.04	0.03	0.03	0.03	0.03	0.03
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$205	\$209	\$213	\$218	\$222	\$226	\$231	\$236	\$240	\$245	\$250	\$255	\$260	\$265	\$271	\$276
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Install Variable Frequency drives on Pool Pumps															-\$8,591.43	
Project Cost																
Elec Savings																
Demand Savings																
NG Savings																
Maintenance Cost																
Emissions Savings																
Carbon Tax Savings																
Residual Value																
Net Cash Flow																

Equipment	Area	Type	Baseline		Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
			kWh	m3	kWh	m3	kWh	kW	m3						
Upgrade to High Efficiency Windows	Pool	Triple Pane HE	2,471,575	162,471	2,471,104	162,452	471	0	20	\$400,000	\$60,000	\$40,000	\$500,000	\$0	Vendor (Fisher Glass)

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Upgrade to High Efficiency Windows	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$500,000															
Elec Savings	\$75	\$77	\$78	\$80	\$82	\$83	\$85	\$87	\$88	\$90	\$92	\$94	\$96	\$97	\$99	\$101
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
NG Savings	\$14	\$14	\$15	\$15	\$15	\$16	\$16	\$16	\$17	\$17	\$17	\$18	\$18	\$18	\$19	\$19
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Emissions Savings	0.08	0.07	0.08	0.07	0.07	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$89	\$91	\$93	\$95	\$97	\$99	\$101	\$103	\$105	\$107	\$109	\$111	\$114	\$116	\$118	\$120
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Upgrade to High Efficiency Windows	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	-\$498,024.28	
Project Cost																
Elec Savings	\$103	\$106	\$108	\$110	\$112	\$114	\$117	\$119	\$121	\$124	\$126	\$129	\$131	\$134		
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
NG Savings	\$19	\$20	\$20	\$21	\$21	\$21	\$22	\$22	\$23	\$23	\$24	\$24	\$25	\$25		
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
Emissions Savings	0.05	0.05	0.05	0.05	0.05	0.05	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05		
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
Residual Value				\$78,238												
Net Cash Flow	\$123	\$125	\$128	\$130	\$133	\$136	\$138	\$141	\$144	\$147	\$150	\$153	\$156	\$159		

Equipment	Quantity	Baseline		Retrofit		Savings		Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
		kWh	m3	kWh	m3	kWh	m3						
Recommissioning of the BAS and Related Systems	1	1,471,503	159,276	1,434,715	155,295	36,788	3,982	\$0	\$18,060	\$0	\$18,060	\$1,944	Vendor

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	NPV
Recommissioning of the BAS and Related Systems	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035				\$47,263.91
Project Cost	-\$18,060														
Elec Savings	\$5,886	\$6,004	\$6,124	\$6,246	\$6,371	\$6,499	\$6,629	\$6,761	\$6,896	\$7,034	\$7,175				
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
NG Savings	\$2,851	\$2,908	\$2,967	\$3,026	\$3,086	\$3,148	\$3,211	\$3,275	\$3,341	\$3,408	\$3,476				
Maintenance Cost	-\$1,944	-\$1,983	-\$2,023	-\$2,063	-\$2,105	-\$2,147	-\$2,190	-\$2,234	-\$2,278	-\$2,324	-\$2,370				
Emissions Savings	10.75	10.21	10.77	10.33	10.08	9.68	9.61	9.41	9.15	8.81	8.68				
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0				
Residual Value															
Net Cash Flow	\$6,793	\$6,929	\$7,067	\$7,209	\$7,353	\$7,500	\$7,650	\$7,803	\$7,959	\$8,118	\$8,281				

Equipment	Quantity	Tons Cooling	BTUh Heating	HP Size	COP	Balance Point (Deg C)	BTUh	Backup Electric COP	Baseline		Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
									kWh	m3	kWh	m3	kWh	kW	m3						
MAU-1	1	4	200,000	48,000	3	2	200,000	1	3,363	5,217	23,918	0	-20,555	-0.1	5,225	\$455,780	\$79,762	\$68,367	\$603,909	\$4,300	RSMMeans
HRV-1	1	22	800,000	264,000	3	2	800,000	1	139,652	19,588	233,230	0	-93,578	-3	19,588						
HRV-2	1	22	800,000	264,000	3	2	800,000	1	58,386	9,915	117,297	0	-58,911	-4	9,915						

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Electrification of HRU's and MAU	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$603,909															
Elec Savings	-\$27,687	-\$28,241	-\$28,806	-\$29,382	-\$29,969	-\$30,569	-\$31,180	-\$31,804	-\$32,440	-\$33,089	-\$33,750	-\$34,425	-\$35,114	-\$35,816	-\$36,532	-\$37,263
Demand Savings	-\$60	-\$62	-\$63	-\$64	-\$65	-\$67	-\$68	-\$69	-\$71	-\$72	-\$74	-\$75	-\$77	-\$78	-\$80	-\$81
NG Savings	\$24,869	\$25,366	\$25,874	\$26,391	\$26,919	\$27,457	\$28,006	\$28,567	\$29,138	\$29,721	\$30,315	\$30,921	\$31,540	\$32,171	\$32,814	\$33,470
Maintenance Cost	-\$4,300	-\$4,386	-\$4,474	-\$4,563	-\$4,654	-\$4,748	-\$4,842	-\$4,939	-\$5,038	-\$5,139	-\$5,242	-\$5,347	-\$5,453	-\$5,563	-\$5,674	-\$5,787
Emissions Savings	52.11	54.65	52.02	54.10	55.29	57.18	57.47	58.42	59.67	61.24	61.87	62.11	62.40	62.66	62.99	63.13
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	-\$7,178	-\$7,322	-\$7,468	-\$7,618	-\$7,770	-\$7,926	-\$8,084	-\$8,246	-\$8,411	-\$8,579	-\$8,750	-\$8,925	-\$9,104	-\$9,286	-\$9,472	-\$9,661
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Electrification of HRU's and MAU	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					-\$746,191.07	
Project Cost																
Elec Savings	-\$38,008	-\$38,769	-\$39,544	-\$40,335	-\$41,141	-\$41,964	-\$42,804	-\$43,660	-\$44,533	-\$45,424						
Demand Savings	-\$83	-\$84	-\$86	-\$88	-\$90	-\$91	-\$93	-\$95	-\$97	-\$99						
NG Savings	\$34,140	\$34,823	\$35,519	\$36,229	\$36,954	\$37,693	\$38,447	\$39,216	\$40,000	\$40,800						
Maintenance Cost	-\$5,903	-\$6,021	-\$6,141	-\$6,264	-\$6,390	-\$6,517	-\$6,648	-\$6,781	-\$6,916	-\$7,055						
Emissions Savings	63.29	63.37	63.49	63.65	63.84	64.08	64.27	64.38	64.26	64.07						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$41,602												
Net Cash Flow	-\$9,854	-\$10,052	-\$10,253	-\$10,458	-\$10,667	-\$10,880	-\$11,098	-\$11,320	-\$11,546	-\$11,777						

Equipment	Quantity	Tons Cooling	BTUh Heating	HP Size	COP	Balance Point (Deg C)	BTUh	Backup Electric COP	Baseline		Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
Electrification of DH3	1	80	1,100,000	960,000	3	2	1,100,000	1	261,817	50,828	645,479	0	-383,662	-45	50,828	\$783,328	\$137,082	\$117,499	\$1,037,910	\$2,600	Vendor

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Electrification of DH3	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$1,037,910															
Elec Savings	-\$61,386	-\$62,614	-\$63,866	-\$65,143	-\$66,446	-\$67,775	-\$69,131	-\$70,513	-\$71,923	-\$73,362	-\$74,829	-\$76,326	-\$77,852	-\$79,409	-\$80,997	-\$82,617
Demand Savings	-\$439	-\$448	-\$457	-\$466	-\$475	-\$484	-\$494	-\$504	-\$514	-\$524	-\$535	-\$546	-\$557	-\$568	-\$579	-\$591
NG Savings	\$36,398	\$37,126	\$37,868	\$38,626	\$39,398	\$40,186	\$40,990	\$41,810	\$42,646	\$43,499	\$44,369	\$45,256	\$46,161	\$47,084	\$48,026	\$48,987
Maintenance Cost	-\$2,600	-\$2,652	-\$2,705	-\$2,759	-\$2,814	-\$2,871	-\$2,928	-\$2,987	-\$3,046	-\$3,107	-\$3,169	-\$3,233	-\$3,297	-\$3,363	-\$3,431	-\$3,499
Emissions Savings	65.26	70.90	65.07	69.67	72.32	76.50	77.15	79.26	82.02	85.52	86.90	87.43	88.09	88.66	89.39	89.70
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	-\$28,027	-\$28,588	-\$29,159	-\$29,743	-\$30,337	-\$30,944	-\$31,563	-\$32,194	-\$32,838	-\$33,495	-\$34,165	-\$34,848	-\$35,545	-\$36,256	-\$36,981	-\$37,721
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Electrification of DH3	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					-\$1,593,428.53	
Project Cost																
Elec Savings	-\$84,270	-\$85,955	-\$87,674	-\$89,428	-\$91,216	-\$93,041	-\$94,901	-\$96,799	-\$98,735	-\$100,710						
Demand Savings	-\$602	-\$614	-\$627	-\$639	-\$652	-\$665	-\$678	-\$692	-\$706	-\$720						
NG Savings	\$49,966	\$50,966	\$51,985	\$53,025	\$54,085	\$55,167	\$56,270	\$57,396	\$58,543	\$59,714						
Maintenance Cost	-\$3,569	-\$3,641	-\$3,713	-\$3,788	-\$3,863	-\$3,941	-\$4,020	-\$4,100	-\$4,182	-\$4,266						
Emissions Savings	90.04	90.24	90.50	90.85	91.27	91.81	92.23	92.46	92.19	91.77						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$71,500												
Net Cash Flow	-\$38,475	-\$39,245	-\$40,030	-\$40,830	-\$41,647	-\$42,480	-\$43,329	-\$44,196	-\$45,080	-\$45,981						

Equipment	Quantity	Tons Cooling	BTUh Heating	HP Size	COP	Balance Point (Deg C)	BTUh	Backup Electric COP	Baseline		Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
									kWh	m3	kWh	m3	kWh	kW	m3						
Electrification of Unit Heaters	5	-	250,000	-	-	-	250,000	1	0	3,195	22,969	0	-22,969	0.1	3,195	\$17,907	\$2,686	\$403	\$20,996	\$0	RSMMeans

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Electrification of Unit Heaters	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$20,996															
Elec Savings	-\$3,675	-\$3,749	-\$3,824	-\$3,900	-\$3,978	-\$4,058	-\$4,139	-\$4,221	-\$4,306	-\$4,392	-\$4,480	-\$4,569	-\$4,661	-\$4,754	-\$4,849	-\$4,946
Demand Savings	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1	\$1
NG Savings	\$2,288	\$2,334	\$2,380	\$2,428	\$2,477	\$2,526	\$2,577	\$2,628	\$2,681	\$2,734	\$2,789	\$2,845	\$2,902	\$2,960	\$3,019	\$3,079
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Emissions Savings	4.20	4.54	4.19	4.46	4.62	4.87	4.91	5.04	5.20	5.41	5.49	5.53	5.57	5.60	5.64	5.66
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	-\$1,386	-\$1,414	-\$1,442	-\$1,471	-\$1,500	-\$1,530	-\$1,561	-\$1,592	-\$1,624	-\$1,656	-\$1,690	-\$1,723	-\$1,758	-\$1,793	-\$1,829	-\$1,865
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Electrification of Unit Heaters	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					-\$48,469.62	
Project Cost																
Elec Savings	-\$5,045	-\$5,146	-\$5,249	-\$5,354	-\$5,461	-\$5,570	-\$5,682	-\$5,795	-\$5,911	-\$6,029						
Demand Savings	\$1	\$1	\$1	\$1	\$1	\$1	\$2	\$2	\$2	\$2						
NG Savings	\$3,141	\$3,204	\$3,268	\$3,333	\$3,400	\$3,468	\$3,537	\$3,608	\$3,680	\$3,754						
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Emissions Savings	5.68	5.69	5.71	5.73	5.76	5.79	5.81	5.83	5.81	5.79						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$1,635												
Net Cash Flow	-\$1,903	-\$1,941	-\$1,980	-\$2,019	-\$2,060	-\$2,101	-\$2,143	-\$2,186	-\$2,229	-\$2,274						

Equipment	Quantity	Capacity DC (kW)	Capacity AC (kW)	Operating Hours	Baseline			Retrofit			Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
					kWh	kW	m3	kWh	kW	m3	kWh	kW	m3						
Install Rooftop Solar PV System	1	341	250	1,600	0	0	0	-400,000	0	0	400,000	0	0	\$582,250	\$115,750	\$58,225	\$756,225	\$5,115	Vendor (Delta Energy Solutions)

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Install Rooftop Solar PV System	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$756,225															
Elec Savings	\$64,000	\$65,280	\$66,586	\$67,917	\$69,276	\$70,661	\$72,074	\$73,516	\$74,986	\$76,486	\$78,016	\$79,576	\$81,167	\$82,791	\$84,447	\$86,136
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Maintenance Cost	-\$5,115	-\$5,217	-\$5,322	-\$5,428	-\$5,537	-\$5,647	-\$5,760	-\$5,876	-\$5,993	-\$6,113	-\$6,235	-\$6,360	-\$6,487	-\$6,617	-\$6,749	-\$6,884
Emissions Savings	33.76	27.88	33.96	29.16	26.40	22.04	21.36	19.16	16.28	12.64	11.20	10.64	9.96	9.36	8.60	8.28
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$58,885	\$60,063	\$61,264	\$62,489	\$63,739	\$65,014	\$66,314	\$67,640	\$68,993	\$70,373	\$71,780	\$73,216	\$74,680	\$76,174	\$77,698	\$79,251
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Install Rooftop Solar PV System	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					\$410,923.11	
Project Cost																
Elec Savings	\$87,858	\$89,615	\$91,408	\$93,236	\$95,101	\$97,003	\$98,943	\$100,922	\$102,940	\$104,999						
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Maintenance Cost	-\$7,022	-\$7,162	-\$7,305	-\$7,452	-\$7,601	-\$7,753	-\$7,908	-\$8,066	-\$8,227	-\$8,392						
Emissions Savings	7.92	7.72	7.44	7.08	6.64	6.08	5.64	5.40	5.68	6.12						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$53,146												
Net Cash Flow	\$80,836	\$82,453	\$84,102	\$85,784	\$87,500	\$89,250	\$91,035	\$92,856	\$94,713	\$96,607						

Equipment	Quantity	Baseline			Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
		BTUh Heating	kWh	m3	kWh	m3	kWh	kW	m3						
Pool Boiler B1	1	688,500	0	24,029	196,540	0	-196,540	-210	24,029	\$313,649	\$78,412	\$62,730	\$454,790	\$3,750	RSMeans/Vendor (Electro Industries)
Domestic B1	1	1,062,500	0	45,726	380,054	0	-380,054	-300	45,726						
Whirlpool Water Heater	1	323,190	0	4,024	33,304	0	-33,304	-120	4,024						

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Electrification of Pool and DHW Boilers	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$454,790															
Elec Savings	-\$97,584	-\$99,535	-\$101,526	-\$103,557	-\$105,628	-\$107,740	-\$109,895	-\$112,093	-\$114,335	-\$116,622	-\$118,954	-\$121,333	-\$123,760	-\$126,235	-\$128,760	-\$131,335
Demand Savings	-\$6,130	-\$6,252	-\$6,378	-\$6,505	-\$6,635	-\$6,768	-\$6,903	-\$7,041	-\$7,182	-\$7,326	-\$7,472	-\$7,622	-\$7,774	-\$7,930	-\$8,088	-\$8,250
NG Savings	\$52,834	\$53,890	\$54,968	\$56,067	\$57,189	\$58,333	\$59,499	\$60,689	\$61,903	\$63,141	\$64,404	\$65,692	\$67,006	\$68,346	\$69,713	\$71,107
Maintenance Cost	-\$3,750	-\$3,825	-\$3,902	-\$3,980	-\$4,059	-\$4,140	-\$4,223	-\$4,308	-\$4,394	-\$4,482	-\$4,571	-\$4,663	-\$4,756	-\$4,851	-\$4,948	-\$5,047
Emissions Savings	90.26	99.22	89.95	97.27	101.48	108.13	109.16	112.52	116.91	122.46	124.65	125.51	126.54	127.46	128.62	129.11
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	-\$54,630	-\$55,723	-\$56,837	-\$57,974	-\$59,133	-\$60,316	-\$61,522	-\$62,753	-\$64,008	-\$65,288	-\$66,594	-\$67,925	-\$69,284	-\$70,670	-\$72,083	-\$73,525
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Electrification of Pool and DHW Boilers	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050						-\$1,537,600.28
Project Cost																
Elec Savings	-\$133,961	-\$136,641	-\$139,374	-\$142,161	-\$145,004	-\$147,904	-\$150,862	-\$153,880	-\$156,957	-\$160,096						
Demand Savings	-\$8,415	-\$8,583	-\$8,755	-\$8,930	-\$9,109	-\$9,291	-\$9,477	-\$9,666	-\$9,860	-\$10,057						
NG Savings	\$72,529	\$73,980	\$75,459	\$76,969	\$78,508	\$80,078	\$81,680	\$83,313	\$84,980	\$86,679						
Maintenance Cost	-\$5,148	-\$5,251	-\$5,356	-\$5,463	-\$5,572	-\$5,684	-\$5,797	-\$5,913	-\$6,032	-\$6,152						
Emissions Savings	129.65	129.96	130.39	130.94	131.61	132.46	133.13	133.50	133.07	132.40						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$28,629												
Net Cash Flow	-\$74,995	-\$76,495	-\$78,025	-\$79,586	-\$81,177	-\$82,801	-\$84,457	-\$86,146	-\$87,869	-\$89,626						

Equipment	Existing Volume (ft³)	Retrofit Volume (ft³)	Baseline			Retrofit			Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
			kWh	kW	m3	kWh	kW	m3	kWh	kW	m3						
Reduce Exhaust Area for Filter Press	40,147	14,650	35,661	15.1	186	28,638	5.4	186	7,023	9.7	0	\$2,135	\$320	\$213	\$2,668	\$1,020	Vendor (ULine)

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Reduce Exhaust Area for Filter Press	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$2,668	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	\$1,124	\$1,146	\$1,169	\$1,192	\$1,216	\$1,241	\$1,265	\$1,291	\$1,317	\$1,343	\$1,370	\$1,397	\$1,425	\$1,454	\$1,483	\$1,512
Demand Savings	\$94	\$96	\$98	\$100	\$102	\$104	\$106	\$108	\$111	\$113	\$115	\$117	\$120	\$122	\$124	\$127
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Maintenance Cost	-\$1,020	-\$1,040	-\$1,061	-\$1,082	-\$1,104	-\$1,126	-\$1,149	-\$1,172	-\$1,195	-\$1,219	-\$1,243	-\$1,268	-\$1,294	-\$1,319	-\$1,346	-\$1,373
Emissions Savings	0.59	0.49	0.60	0.51	0.46	0.39	0.38	0.34	0.29	0.22	0.20	0.19	0.17	0.16	0.15	0.15
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$198	\$202	\$206	\$210	\$214	\$219	\$223	\$227	\$232	\$237	\$241	\$246	\$251	\$256	\$261	\$266
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Reduce Exhaust Area for Filter Press	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					\$1,256.19	
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Elec Savings	\$1,543	\$1,573	\$1,605	\$1,637	\$1,670	\$1,703	\$1,737	\$1,772	\$1,807	\$1,843						
Demand Savings	\$129	\$132	\$135	\$137	\$140	\$143	\$146	\$149	\$152	\$155						
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Maintenance Cost	-\$1,400	-\$1,428	-\$1,457	-\$1,486	-\$1,516	-\$1,546	-\$1,577	-\$1,608	-\$1,641	-\$1,673						
Emissions Savings	0.14	0.14	0.13	0.12	0.12	0.11	0.10	0.09	0.10	0.11						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$195												
Net Cash Flow	\$272	\$277	\$283	\$288	\$294	\$300	\$306	\$312	\$318	\$325						

Equipment	Quantity	Capacity DC (kW)	Capacity AC (kW)	Operating Hours	Baseline		Retrofit		Savings		Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
					kWh	m3	kWh	m3	kWh	m3						
Install Ground Mount Solar PV System 510 kW DC	1	510	429	1,400	0	0	-600,000	0	600,000	0	\$975,375	\$193,125	\$97,538	\$1,266,038	\$7,650	Vendor (Delta Energy Solutions)

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Install Ground Mount Solar PV System 510 kW DC	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$1,266,038	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	\$96,000	\$97,920	\$99,878	\$101,876	\$103,913	\$105,992	\$108,112	\$110,274	\$112,479	\$114,729	\$117,023	\$119,364	\$121,751	\$124,186	\$126,670	\$129,203
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Maintenance Cost	-\$7,650	-\$7,803	-\$7,959	-\$8,118	-\$8,281	-\$8,446	-\$8,615	-\$8,787	-\$8,963	-\$9,142	-\$9,325	-\$9,512	-\$9,702	-\$9,896	-\$10,094	-\$10,296
Emissions Savings	50.64	41.82	50.94	43.74	39.60	33.06	32.04	28.74	24.42	18.96	16.80	15.96	14.94	14.04	12.90	12.42
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$88,350	\$90,117	\$91,919	\$93,758	\$95,633	\$97,546	\$99,496	\$101,486	\$103,516	\$105,586	\$107,698	\$109,852	\$112,049	\$114,290	\$116,576	\$118,907
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Install Ground Mount Solar PV System 510 kW DC	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050						\$485,130.64
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Elec Savings	\$131,787	\$134,423	\$137,112	\$139,854	\$142,651	\$145,504	\$148,414	\$151,382	\$154,410	\$157,498						
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Maintenance Cost	-\$10,502	-\$10,712	-\$10,926	-\$11,145	-\$11,367	-\$11,595	-\$11,827	-\$12,063	-\$12,305	-\$12,551						
Emissions Savings	11.88	11.58	11.16	10.62	9.96	9.12	8.46	8.10	8.52	9.18						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$89,030												
Net Cash Flow	\$121,286	\$123,711	\$126,186	\$128,709	\$131,283	\$133,909	\$136,587	\$139,319	\$142,105	\$144,948						

Equipment	Qty	Flowrate (Nm3/hr)	Transfer Rate (Nm3/kWh)	Power (kW)	Underground Piping (m)	Diffuser Tubes (m)	Operating Hours	Existing Mechanical Aerators (Metered)		Baseline		Retrofit		Savings		Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
								Low Speed Annual (kWh)	High Speed Annual (kWh)	kWh	kW	kWh	kW	kWh	kW						
Install Aeration Blower	1	1800	65.21	27.6	100	150	8,760	252,723	77,989	330,712	37.8	241,776	27.6	88,936	10.2	\$212,749	\$31,912	\$21,275	\$265,936	\$3,400	RSMeans/Vendor (ENV Treatment Systems)

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Install Aeration Blower	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$265,936	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	\$14,230	\$14,514	\$14,805	\$15,101	\$15,403	\$15,711	\$16,025	\$16,346	\$16,672	\$17,006	\$17,346	\$17,693	\$18,047	\$18,408	\$18,776	\$19,151
Demand Savings	\$100	\$102	\$104	\$106	\$108	\$110	\$112	\$114	\$117	\$119	\$121	\$124	\$126	\$129	\$131	\$134
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Maintenance Cost	-\$3,400	-\$3,468	-\$3,537	-\$3,608	-\$3,680	-\$3,754	-\$3,829	-\$3,906	-\$3,984	-\$4,063	-\$4,145	-\$4,227	-\$4,312	-\$4,398	-\$4,486	-\$4,576
Emissions Savings	7.51	6.20	7.55	6.48	5.87	4.90	4.75	4.26	3.62	2.81	2.49	2.37	2.21	2.08	1.91	1.84
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$10,929	\$11,148	\$11,371	\$11,598	\$11,830	\$12,067	\$12,308	\$12,554	\$12,806	\$13,062	\$13,323	\$13,589	\$13,861	\$14,138	\$14,421	\$14,710
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Install Aeration Blower	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					-\$49,306.59	
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Elec Savings	\$19,534	\$19,925	\$20,324	\$20,730	\$21,145	\$21,568	\$21,999	\$22,439	\$22,888	\$23,345						
Demand Savings	\$137	\$139	\$142	\$145	\$148	\$151	\$154	\$157	\$160	\$163						
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Maintenance Cost	-\$4,667	-\$4,761	-\$4,856	-\$4,953	-\$5,052	-\$5,153	-\$5,256	-\$5,361	-\$5,469	-\$5,578						
Emissions Savings	1.76	1.72	1.65	1.57	1.48	1.35	1.25	1.20	1.26	1.36						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$19,419												
Net Cash Flow	\$15,004	\$15,304	\$15,610	\$15,922	\$16,241	\$16,565	\$16,897	\$17,235	\$17,579	\$17,931						

Equipment	Quantity	Baseline		Retrofit		Savings		Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
		kWh	m3	kWh	m3	kWh	m3						
Thermostat Upgrades	13	36,754	6,387	16,383	3,790	20,371	2,597	\$3,900	\$0	\$0	\$4,290	\$510	Internal

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Thermostat Upgrades	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$4,290	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	\$3,259	\$3,325	\$3,391	\$3,459	\$3,528	\$3,599	\$3,671	\$3,744	\$3,819	\$3,895	\$3,973	\$4,053	\$4,134	\$4,216	\$4,301	\$4,387
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
NG Savings	\$1,860	\$1,897	\$1,935	\$1,974	\$2,013	\$2,053	\$2,095	\$2,136	\$2,179	\$2,223	\$2,267	\$2,313	\$2,359	\$2,406	\$2,454	\$2,503
Maintenance Cost	-\$510	-\$520	-\$531	-\$541	-\$552	-\$563	-\$574	-\$586	-\$598	-\$609	-\$622	-\$634	-\$647	-\$660	-\$673	-\$686
Emissions Savings	6.71	6.41	6.72	6.47	6.33	6.11	6.08	5.97	5.82	5.63	5.56	5.53	5.50	5.47	5.43	5.41
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$4,609	\$4,701	\$4,795	\$4,891	\$4,989	\$5,089	\$5,191	\$5,295	\$5,400	\$5,508	\$5,619	\$5,731	\$5,846	\$5,963	\$6,082	\$6,203
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Thermostat Upgrades	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	\$97,464.13	
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
Elec Savings	\$4,474	\$4,564	\$4,655	\$4,748	\$4,843	\$4,940	\$5,039	\$5,140	\$5,242	\$5,347	\$5,454	\$5,563	\$5,675	\$5,788		
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
NG Savings	\$2,553	\$2,604	\$2,656	\$2,709	\$2,764	\$2,819	\$2,875	\$2,933	\$2,991	\$3,051	\$3,112	\$3,175	\$3,238	\$3,303		
Maintenance Cost	-\$700	-\$714	-\$728	-\$743	-\$758	-\$773	-\$788	-\$804	-\$820	-\$837	-\$853	-\$871	-\$888	-\$906		
Emissions Savings	5.39	5.38	5.37	5.35	5.33	5.30	5.28	5.26	5.28	5.30	5.30	5.30	5.30	5.30		
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
Residual Value				\$763												
Net Cash Flow	\$6,327	\$6,454	\$6,583	\$6,715	\$6,849	\$6,986	\$7,126	\$7,268	\$7,414	\$7,562	\$7,713	\$7,867	\$8,025	\$8,185		

Equipment	Location	Existing Windowed Area (ft2)	Retrofit Windowed Area (ft2)	Type	Baseline		Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
					kWh	m3	kWh	m3	kWh	kW	m3						
Reduce Windowed Area in the Control Room	Control Room	10.2	6.5	Triple Pane HE	0	1,633	0	1,390	0	0	243	\$14,563	\$2,184	\$2,184	\$18,932	\$0	RSMeans

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Reduce Windowed Area in the Control Room	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$18,932	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
NG Savings	\$174	\$177	\$181	\$184	\$188	\$192	\$196	\$199	\$203	\$208	\$212	\$216	\$220	\$225	\$229	\$234
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Emissions Savings	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$174	\$177	\$181	\$184	\$188	\$192	\$196	\$199	\$203	\$208	\$212	\$216	\$220	\$225	\$229	\$234
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Reduce Windowed Area in the Control Room	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054	-\$15,097.77	
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
Elec Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
NG Savings	\$238	\$243	\$248	\$253	\$258	\$263	\$268	\$274	\$279	\$285	\$291	\$296	\$302	\$308		
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
Emissions Savings	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47		
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0		
Residual Value				\$2,848												
Net Cash Flow	\$238	\$243	\$248	\$253	\$258	\$263	\$268	\$274	\$279	\$285	\$291	\$296	\$302	\$308		

Equipment	Quantity	Airflow	BTUh Heating	Baseline		Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
				kWh	m3	kWh	m3	kWh	kW	m3						
Electrification of the MAU	1	4,000	12,000	1,096	186	2,631	0	-1,535	-3.5	186	\$29,344	\$4,402	\$2,934	\$36,681	\$1,500	RSMeans

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Electrification of the MAU	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$36,681	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	-\$246	-\$251	-\$256	-\$261	-\$266	-\$271	-\$277	-\$282	-\$288	-\$294	-\$299	-\$305	-\$311	-\$318	-\$324	-\$331
Demand Savings	-\$34	-\$35	-\$36	-\$36	-\$37	-\$38	-\$39	-\$39	-\$40	-\$41	-\$42	-\$43	-\$43	-\$44	-\$45	-\$46
NG Savings	\$133	\$136	\$139	\$141	\$144	\$147	\$150	\$153	\$156	\$159	\$162	\$166	\$169	\$172	\$176	\$179
Maintenance Cost	-\$1,500	-\$1,530	-\$1,561	-\$1,592	-\$1,624	-\$1,656	-\$1,689	-\$1,723	-\$1,757	-\$1,793	-\$1,828	-\$1,865	-\$1,902	-\$1,940	-\$1,979	-\$2,019
Emissions Savings	0.23	0.25	0.23	0.25	0.26	0.27	0.28	0.28	0.30	0.31	0.31	0.32	0.32	0.32	0.32	0.33
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	-\$1,647	-\$1,679	-\$1,713	-\$1,747	-\$1,782	-\$1,818	-\$1,854	-\$1,891	-\$1,929	-\$1,968	-\$2,007	-\$2,047	-\$2,088	-\$2,130	-\$2,173	-\$2,216
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Electrification of the MAU	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					-\$69,316.10	
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Elec Savings	-\$337	-\$344	-\$351	-\$358	-\$365	-\$372	-\$380	-\$387	-\$395	-\$403						
Demand Savings	-\$47	-\$48	-\$49	-\$50	-\$51	-\$52	-\$53	-\$54	-\$55	-\$56						
NG Savings	\$183	\$187	\$190	\$194	\$198	\$202	\$206	\$210	\$214	\$219						
Maintenance Cost	-\$2,059	-\$2,100	-\$2,142	-\$2,185	-\$2,229	-\$2,273	-\$2,319	-\$2,365	-\$2,413	-\$2,461						
Emissions Savings	0.33	0.33	0.33	0.33	0.33	0.33	0.34	0.34	0.34	0.33						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$2,678												
Net Cash Flow	-\$2,260	-\$2,306	-\$2,352	-\$2,399	-\$2,447	-\$2,496	-\$2,546	-\$2,596	-\$2,648	-\$2,701						

Equipment	Existing Quantity	Existing Capacity (BTUh)	Retrofit Quantity	Retrofit Capacity (BTUh)	Retrofit COP	Baseline		Retrofit		Savings			Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
						kWh	m3	kWh	m3	kWh	kW	m3						
Truck Bay Tube Heater	1	80,000	2	49,000	3	0	1,238	6,126	0	-6,126	-7	1,238	\$124,476	\$18,671	\$12,448	\$155,595	\$0	RSMeans/ Vendor (Senville)
Workshop Tube Heater	1	80,000	2	49,000	3	0	1,376	9,458	0	-9,458	-30	1,376						
Belt Filter Press Tube Heater	1	80,000	2	49,000	3	0	1,404	9,608	0	-9,608	-30	1,404						
Chlorine Tube Heater	1	80,000	1	49,000	3	0	623	2,775	0	-2,775	-6	623						
Control Tube Heater	2	40,000	2	49,000	3	0	1,633	7,661	0	-7,661	-18	1,633						
Locker Tube Heater	1	40,000	1	49,000	3	0	113	650	0	-650	-3	113						

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Electrification of Tube Heaters	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$155,595	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	-\$5,804	-\$5,921	-\$6,039	-\$6,160	-\$6,283	-\$6,409	-\$6,537	-\$6,668	-\$6,801	-\$6,937	-\$7,076	-\$7,217	-\$7,361	-\$7,509	-\$7,659	-\$7,812
Demand Savings	-\$506	-\$516	-\$526	-\$537	-\$548	-\$559	-\$570	-\$581	-\$593	-\$605	-\$617	-\$629	-\$642	-\$655	-\$668	-\$681
NG Savings	\$4,574	\$4,665	\$4,759	\$4,854	\$4,951	\$5,050	\$5,151	\$5,254	\$5,359	\$5,466	\$5,576	\$5,687	\$5,801	\$5,917	\$6,035	\$6,156
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Emissions Savings	9.21	9.74	9.19	9.63	9.88	10.27	10.33	10.53	10.79	11.12	11.25	11.31	11.37	11.42	11.49	11.52
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	-\$1,736	-\$1,771	-\$1,807	-\$1,843	-\$1,880	-\$1,917	-\$1,956	-\$1,995	-\$2,035	-\$2,075	-\$2,117	-\$2,159	-\$2,202	-\$2,246	-\$2,291	-\$2,337
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Electrification of Tube Heaters	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					-\$190,013.87	
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Elec Savings	-\$7,968	-\$8,128	-\$8,290	-\$8,456	-\$8,625	-\$8,798	-\$8,974	-\$9,153	-\$9,336	-\$9,523						
Demand Savings	-\$695	-\$708	-\$723	-\$737	-\$752	-\$767	-\$782	-\$798	-\$814	-\$830						
NG Savings	\$6,279	\$6,405	\$6,533	\$6,663	\$6,797	\$6,933	\$7,071	\$7,213	\$7,357	\$7,504						
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Emissions Savings	11.55	11.57	11.60	11.63	11.67	11.72	11.76	11.78	11.75	11.71						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$11,362												
Net Cash Flow	-\$2,384	-\$2,432	-\$2,480	-\$2,530	-\$2,580	-\$2,632	-\$2,685	-\$2,738	-\$2,793	-\$2,849						

Equipment	Quantity	Heating Capacity (kW, ea)	HP Size (BTUh, ea)	COP	Baseline	Retrofit	Savings		Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
					kWh	kWh	kWh	kW						
Replace Electric Unit Heaters with Heat Pumps	12	3	12,000	3	37,978	21,778	16,200	7.7	\$55,377	\$8,307	\$5,538	\$69,221	\$0	RSMeans/Vendor (Senville)

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Replace Electric Unit Heaters with Heat Pumps	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$69,221	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	\$2,592	\$2,644	\$2,697	\$2,751	\$2,806	\$2,862	\$2,919	\$2,977	\$3,037	\$3,098	\$3,160	\$3,223	\$3,287	\$3,353	\$3,420	\$3,488
Demand Savings	\$74	\$76	\$77	\$79	\$81	\$82	\$84	\$86	\$87	\$89	\$91	\$93	\$94	\$96	\$98	\$100
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Emissions Savings	1.37	1.13	1.38	1.18	1.07	0.89	0.87	0.78	0.66	0.51	0.45	0.43	0.40	0.38	0.35	0.34
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$2,666	\$2,720	\$2,774	\$2,830	\$2,886	\$2,944	\$3,003	\$3,063	\$3,124	\$3,187	\$3,250	\$3,315	\$3,382	\$3,449	\$3,518	\$3,589
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Replace Electric Unit Heaters with Heat Pumps	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050					-\$16,370.37	
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Elec Savings	\$3,558	\$3,629	\$3,702	\$3,776	\$3,852	\$3,929	\$4,007	\$4,087	\$4,169	\$4,252						
Demand Savings	\$102	\$104	\$106	\$108	\$111	\$113	\$115	\$117	\$120	\$122						
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Maintenance Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Emissions Savings	0.32	0.31	0.30	0.29	0.27	0.25	0.23	0.22	0.23	0.25						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$5,055												
Net Cash Flow	\$3,660	\$3,734	\$3,808	\$3,884	\$3,962	\$4,041	\$4,122	\$4,205	\$4,289	\$4,375						

Equipment	Quantity	Capacity DC (kW)	Capacity AC (kW)	Operating Hours	Baseline		Retrofit		Savings		Materials & Labour	Engineering	Contingency	Total Capital	O&M	Pricing
					kWh	m3	kWh	m3	kWh	m3						
Install Ground Mount Solar PV System 260 kW DC	1	260	214	1,400	0	0	-300,000	0	300,000	0	\$497,250	\$98,750	\$49,725	\$645,725	\$3,900	Vendor (Delta Energy Solutions)

NPV Calculations	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Install Ground Mount Solar PV System 260 kW DC	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040
Project Cost	-\$645,725	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Elec Savings	\$48,000	\$48,960	\$49,939	\$50,938	\$51,957	\$52,996	\$54,056	\$55,137	\$56,240	\$57,364	\$58,512	\$59,682	\$60,876	\$62,093	\$63,335	\$64,602
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Maintenance Cost	-\$3,900	-\$3,978	-\$4,058	-\$4,139	-\$4,221	-\$4,306	-\$4,392	-\$4,480	-\$4,569	-\$4,661	-\$4,754	-\$4,849	-\$4,946	-\$5,045	-\$5,146	-\$5,249
Emissions Savings	25.32	20.91	25.47	21.87	19.80	16.53	16.02	14.37	12.21	9.48	8.40	7.98	7.47	7.02	6.45	6.21
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Residual Value																
Net Cash Flow	\$44,100	\$44,982	\$45,882	\$46,799	\$47,735	\$48,690	\$49,664	\$50,657	\$51,670	\$52,704	\$53,758	\$54,833	\$55,929	\$57,048	\$58,189	\$59,353
NPV Calculations	17	18	19	20	21	22	23	24	25	26	27	28	29	30	NPV	
Install Ground Mount Solar PV System 260 kW DC	2041	2042	2043	2044	2045	2046	2047	2048	2049	2050						\$228,372.51
Project Cost	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Elec Savings	\$65,894	\$67,212	\$68,556	\$69,927	\$71,325	\$72,752	\$74,207	\$75,691	\$77,205	\$78,749						
Demand Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
NG Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Maintenance Cost	-\$5,354	-\$5,461	-\$5,570	-\$5,682	-\$5,795	-\$5,911	-\$6,029	-\$6,150	-\$6,273	-\$6,398						
Emissions Savings	5.94	5.79	5.58	5.31	4.98	4.56	4.23	4.05	4.26	4.59						
Carbon Tax Savings	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0						
Residual Value				\$45,388												
Net Cash Flow	\$60,540	\$61,751	\$62,986	\$64,245	\$65,530	\$66,841	\$68,178	\$69,541	\$70,932	\$72,351						

Appendix C: Disqualified ECMs

The following ECMs were identified for analysis through the Design Workshops but were disqualified from inclusion in the decarbonization pathways due to limited potential for GHG reductions and poor financial returns.

MRC ECM – Install Variable Frequency drives on Pool Pumps (MRC)

Utility Savings		Financial Analysis	
Electricity (kWh)	1,270	Materials & Labour	\$9,065
Demand (kW)	0.2	Engineering & PM	\$1,360
Natural Gas (m ³)	0	Contingency	\$906
GHG (tCO ₂ e)	0.1	Total Capital Cost	\$11,331
GHG Baseline Reduction	0%	Utility Savings	\$214
EUI Reduction (ekWh/m ²)	0.18	Annual O&M	\$-
TEDI Reduction	0%	Simple Payback	52.9
		Net-Present Value	-\$8,591

Existing Conditions:

The primary pool circulation pump has its output flow restricted by a butterfly valve. This is likely to aid in balancing the systems' overall flow and improve system performance. This type of flow control, however, represents an inefficiency in energy usage, as the amount of pumping energy used is higher than required by the system.

Figure 23: Pool Circulation Pump Control Valve

Proposed Measure:

To improve flow control and reduce energy usage, it is recommended to install a VFD to reduce the flow of water in the pool's circulation system. This type of flow control can significantly decrease energy consumed by pumps and motors while also increasing the level of operational control.

Implementation and Non-Financial Considerations:

Several other VFDs are already installed at this facility and site staff are familiar with their operation. The system can be tied into the existing BAS, allowing for a seamless integration with current systems. Implementation of the measure would result in a brief interruption of pool circulation with little to no impact on pool operations.

Measurement and Verification:

M&V for this measure is recommended to follow IPMVP Option A – Retrofit Isolation due to the quantity of saving, the availability of spot meter data, as well as BAS trend data.

MRC ECM – Electrification of Pool and DHW Boilers - MRC

Utility Savings		Financial Analysis	
Electricity (kWh)	-609,898	Materials & Labour	\$313,649
Demand (kW)	-630	Engineering & PM	\$78,412
Natural Gas (m ³)	73,780	Contingency	\$62,730
GHG (tCO ₂ e)	90.3	Total Capital Cost	\$454,790
GHG Baseline Reduction	23%	Utility Savings	-\$138,958
EUI Reduction (ekWh/m ²)	25.51	Annual O&M	\$3,750
TEDI Reduction	0%	Simple Payback	-3.3
		Net-Present Value	-\$1,537,600

Existing Conditions:

The MRC currently relies on natural gas-fired boilers to provide hot water for the pool, whirlpool, and domestic hot water systems. These boilers are a significant source of fossil fuel consumption at the facility and contribute directly to its operational greenhouse gas emissions. The equipment is aging and represents an opportunity for both emissions reduction and operational efficiency improvement through electrification.

Existing Equipment	Heating Capacity (BTUh)
Pool Boiler B1	688,500
Domestic Hot Water Boiler B1	1,062,500
Whirlpool Water Heater	323,190

Proposed Measure:

The measure proposes replacing the existing boilers with new equivalent capacity electric models to significantly reduce GHG emissions.

Proposed Equipment	Electric Boiler Capacity (kW)
Pool Boiler B1	210
Domestic Hot Water Boiler B1	300
Whirlpool Water Heater	120

Implementation and Non-Financial Considerations:

The measure is not expected to have any impact on occupant comfort or facility operations. Implementation of this measure is also not expected to impact operations.

Measurement and Verification:


To measure the change in energy consumption IPMVP Option A or B is recommended, based on the availability of BAS data and energy meter data.

MRC ECM – Upgrade to High Efficiency Windows

Utility Savings		Financial Analysis	
Electricity (kWh)	471	Materials & Labour	\$400,000
Demand (kW)	0.0	Engineering & PM	\$60,000
Natural Gas (m ³)	20	Contingency	\$40,000
GHG (tCO ₂ e)	0.1	Total Capital Cost	\$500,000
GHG Baseline Reduction	0%	Utility Savings	\$78
EUI Reduction (ekWh/m ²)	0.10	Annual O&M	\$-
TEDI Reduction	0.17%	Simple Payback	6,404
		Net-Present Value	-\$498,024

Existing Conditions:

The MRC currently has double-pane windows on its exterior. The majority of these windows are in the pool area, as pictured below. The existing windows will reach their end-of-life within the study period.



Proposed Measure:

The measure proposes replacing the pool area windows with triple-pane high efficiency windows. This measure will increase the insulating properties of this exterior wall and increase occupant comfort, while still maintaining natural lighting in the pool.

Implementation and Non-Financial Considerations:

Replacing the windows will require significant impacts to pool operations, including some shutdown of services. With proper planning, the severity of these impacts can be minimized by scheduling during low-occupancy periods. Overall, impacts from the project on occupants are expected to be positive due to increased comfort resulting from the improved thermal performance of the windows.

Measurement and Verification:

To measure the electrical energy and carbon savings IPMVP Option A or B is recommended, based on the scope of the project and the size of the estimated savings.

WWTP ECM – Replace Electric Unit Heaters with Heat Pumps

Utility Savings		Financial Analysis	
Electricity (kWh)	16,200	Materials & Labour	\$55,377
Demand (kW)	7.7	Engineering & PM	\$8,307
Natural Gas (m ³)	0	Contingency	\$5,538
GHG (tCO ₂ e)	1.4	Total Capital Cost	\$69,221
GHG Baseline Reduction	4%	Utility Savings	\$3,039
EUI Reduction (ekWh/m ²)	0.48	Annual O&M	\$-
TEDI Reduction	0%	Simple Payback	22.8
		Net-Present Value	-\$16,370

Existing Conditions:

The Pumphouse, Office, and Chlorine Room are heated via electric unit heaters. While these units do not produce significant carbon emissions, their operation can be improved through installing heat pumps.

Location	Electric Unit Heater Capacity (BTUh)
Pumphouses	110,000
Office & Chlorine Room	20,000

Proposed Measure:

The measure proposes replacing the existing electric unit heaters with mini-split heat pumps with electric backup heating. The mini-split heat pumps will operate at outdoor air temperatures above 2° C and the electric heating will supply heat at lower temperatures, ensuring the interior temperature is consistently maintained.

Location	Heat Pump Capacity (BTUh)	Supplementary Electric Capacity (BTUh)
Pumphouses	108,000	108,000
Office & Chlorine Room	24,000	24,000

Implementation and Non-Financial Considerations:

Installation costs include penetration to the building envelope to accommodate the new systems. The actual placement of the interior fan coil units will differ from the current heating system as the interior fan coil units will be limited in the distance away from the exterior units they can be located.

Measurement and Verification:

To measure the change in energy consumption IPMVP Option A is recommended to keep M&V costs in line with savings estimates.

WWTP ECM – Reduce Windowed Area in the Control Room

Utility Savings		Financial Analysis	
Electricity (kWh)	0	Materials & Labour	\$14,563
Demand (kW)	0.0	Engineering & PM	\$2,184
Natural Gas (m ³)	243	Contingency	\$2,184
GHG (tCO ₂ e)	0.5	Total Capital Cost	\$18,932
GHG Baseline Reduction	1%	Utility Savings	\$174
EUI Reduction (ekWh/m ²)	0.08	Annual O&M	\$-
TEDI Reduction	1.05%	Simple Payback	109.0
		Net-Present Value	-\$15,098

Existing Conditions:

The Control Room's exterior curtain wall is aged and uses older double pane insulated glass. Site staff have communicated that the windows are oversized and unnecessary for the space, often leading to overheating in the summer and increasing the heating requirements in the winter due to their age and construction.

Figure 24: WWTP Control Room Curtain Wall



Proposed Measure:

The measure proposes reducing the total windowed area by approximately 30% and installing modern triple pane insulated windows in place of the curtain wall. This measure will increase the insulating properties of this exterior wall and increase occupant comfort, while still maintaining natural lighting and visibility of the WWTP from the Control Room.

Implementation and Non-Financial Considerations:


Replacing the windows will require some impacts to plant operations during implementation. It is anticipated that 1 to 2 days of restricted access for the site staff will be required to complete the installation. With proper planning, the severity of these impacts can be minimized by scheduling much of the construction to weekends or other low-occupancy periods.



Measurement and Verification:

To measure the change in energy consumption IPMVP Option A or B is recommended, based on the scope of the project and the size of the estimated savings.

Appendix D: Schematics

ECM – Reduce Exhaust Area for Filter Press





Appendix E: Decision Making Workshop

Aladaco Consulting Inc.

Town of Goderich MRC Decision Making Workshop



Agenda

- Introductions
- Review of the required GHG Reduction Pathways
- Decarbonization Measures Analyzed
- Pathways Development
- Next steps and Discussion




Introductions - Aladaco

- Aladaco Consulting Inc
 - Founded in 2007
 - Energy professionals providing services to help organizations navigate and reach energy efficiency and decarbonization goals
 - Energy management and M&V, GHG inventorying and decarbonization pathways, CDM planning
 - IESO Industrial Technical Review Services



Sean Pittman
Conservation & Energy
Management Lead
P.Eng., CEM, CMVP



Taylor Wilson
Technical Lead - Energy &
Carbon Management
CET, CEM, CMVP



Introductions – HEMCon Energy Modeling Solutions

HEMCon is an energy analysis and building simulation firm.

We specialize in building energy models for new and existing buildings to facilitate good design decisions.



Jeremiah Heffernan
Founder, Principal Energy Analyst
P.Eng, M.Eng., G.Dip Green Energy,
BEMP, LEED AP BD+C




Introductions – Town of Goderich

- Jessica Clapp (Town of Goderich Project Lead)
Asset Management and Environmental Services
Coordinator
- Deanna Hastie
Director of Corporate Services/Treasurer
- Kyle Williams
Community Services and Operations Manager
- Greg Morningstar
Recreation Facilities Supervisor
- Sean Thomas
Director of Community Services,
Infrastructure, and Operations



Study Review Process



GHG Reduction Pathways

- **Minimum Performance:** 50% reduction in 10 years, 80% in 20 years
- **Aggressive Deep Retrofit:** 50% reduction in 5 years, 80% in 20 years
- **Business-As-Usual:** Like-for-like replacements with existing specs



ECM Summary

ECM	Energy Savings Potential	GHG Savings Potential	Implementation Cost	Life-Cycle Cost	Selected for Study
Geothermal System Recommissioning	Low	Low	\$\$	Positive	X
Installing Water-Source Heat Pumps	Medium	High	\$\$\$	Negative	X
Building Envelope Improvements	Low	Low	\$\$\$\$	Negative	
Variable Frequency Drives - Pool	Low	Low	\$\$	Positive	X
Variable Frequency Drives - Heating Loop	Medium	Low	\$	Positive	X
Liquid Pool Cover	Low	Low	\$	Positive	
Reduce Pool Make-up Water	Low	Low	\$	Positive	
Cold Water Ice-Resurfacing	Low	Medium	\$	Positive	
Electric Ice-Resurfacer	None	Medium	\$\$\$	Negative	
LED Lamps	Low	Low	\$	Positive	
BAS Recommissioning	Low	Low	\$\$	Positive	X
High-Efficiency Pumps	Low	Low	\$	Positive	
Electrification of Heating	Medium	High	\$\$\$\$	Negative	X
Solar PV Panels	None	Medium	\$\$\$	Positive	X


Decarbonization Measures Analyzed

ECM	Annual Utility Savings	GHG Savings (tCO _{2e})	Implementation Cost	NPV	SPP
Geothermal System Recommissioning	\$5,124	2.9	\$21,500	\$21,705	4.4
Variable Frequency Drive – Pool	\$214	0.1	\$11,331	-\$8,591	52.9
Window Replacement – Pool	\$78	0.1	\$500,000	-\$498,024	6,404
BAS Recommissioning	\$7,016	10.8	\$18,060	\$47,264	2.9
ASHP HRUs & MUA	-\$13,265	52.1	\$603,909	-\$746,191	-45.8
ASHP Dehumidifier (DH-3)	-\$41,125	65.3	\$1,037,910	-\$1,593,429	-25.3
WSHP Boilers	-\$32,464	121.2	\$2,721,424	-\$2,582,732	-84.0
Electrification of Boilers	-\$138,958	90.3	\$454,790	-\$1,537,600	-3.3
Electrification of Unit Heaters	-\$2,238	4.2	\$20,996	-\$48,470	-9.4
Solar PV Panels	\$60,000	33.8	\$756,225	\$410,923	12.7



GHG Reduction Pathways

MRC - GHG Reduction Pathways



GHG Reduction Pathways

Metric	Minimum Performance	Aggressive Deep Retrofit	BAU (Baseline)
Capital Cost	\$6,313,490	\$5,532,788	\$2,208,394
External Funding	\$1,294,266	\$1,383,197	-
BAU Avoided Costs	\$2,208,394	\$2,208,394	
Residual Value at Study End	\$1,757,764	\$707,148	\$397,994
Incremental Costs	\$2,810,831	\$1,941,196	-
Operating Costs	\$11,352,974	\$11,545,804	\$10,472,299
5-year GHG Reduction (tCO ₂ e)	-23 (-5.7%)	202 (50.9%)	-
10-year GHG Reduction (tCO ₂ e)	213 (53.8%)	299 (75.3%)	-
20-year GHG Reduction (tCO ₂ e)	338 (85.2%)	344 (86.7%)	-
Incremental LC Cost (20-year)	\$2,331,735	\$2,705,546	-
Cost per tonne CO ₂ e abated (\$ILCC/tCO ₂ e)	\$345	\$394	-

ECM Description	Min Performance Year	Aggressive Deep Retrofit Year
Geothermal Recommissioning	2025	2025
Water-Source Heat Pump Boilers	2034	2029
VFDs - Pool		
Window Replacement		
BAS Recommissioning	2025	2026
Air-source Heat Pump HRUs & MAU	2028	2027
Air-source Heat Pump DH3	2044	2028
Electrify UHs		2044
Solar PV Panels	2032	2027



Next Steps

- Finalization of PPT and timeline of measure implementations
- Delivery of Feasibility Study Report Draft (Mid July)
- Final Study Report and Council Presentation (August)





Thank You

Questions?



Powering Progress with
Sustainable Solutions



ECMs – Geothermal System Recommissioning

PROJECT DESCRIPTION

- Conduct a detailed assessment of system performance to identify inefficiencies in controls, pumping, and heat exchange operations
- Optimize control settings for temperature setpoints, seasonal operation modes, and occupancy schedules
- Test and balance ground loop flow rates to ensure efficient heat exchange and minimize energy waste

ECM OUTCOMES

- Improve energy performance of the system (3% to 5%)
- Evaluate capacity for additional Heating opportunities
- Right size future electrification measures
- Potential to tie-in Unit Heaters



ECMs – Install Water-Source Heat Pumps

PROJECT DESCRIPTION

- Mechanical Design Drawings indicate additional Water Source Heat Pumps were originally planned to support Pool and DHW Heating
- Geothermal System Recommissioning can determine the available heating capacity

ECM OUTCOMES

- Reduce Boiler Loads
- Reduce electrification impacts and right size future electrification measures



ECMs – Building Envelope Improvements

PROJECT DESCRIPTION



- Wall Insulation Improvements
- Air Sealing
- Decrease Thermal Bridging
- Windows & Doors
- Roof

ECM OUTCOMES

- Estimates of up to 10% to 15% Energy Savings
- Improved Occupant Comfort
- Reduces Equipment Cycling and prolongs expected life



ECMs – Building Envelope Improvements



ECMs – Heating Electrification

PROJECT DESCRIPTION

- Replace all Natural Gas heating sources with electric alternatives (resistance or Heat Pumps)
- Includes Pool Boilers, DHW Boilers, Unit Heaters, Rooftop Units

ECM OUTCOMES

- Significant reduction in GHG
- Increased building electrical loading



ECMs – Renewable Energy Generation

PROJECT DESCRIPTION

- Install Solar PV Panels on Rooftops and/or property
- 1,700 m² of approximate rooftop area available
- 250 kW DC System Capacity estimated

ECM OUTCOMES

- Significant reduction in GHG from Grid Emissions
- Up to 300,000 kWh/yr displaced energy consumption
- Rough savings of up to: \$42,000/yr and 11.4 tCO_{2e}

Funding Opportunities

Funding Entity	Program	Available Funding	Notes
IESO	Custom Retrofit	\$0.13/kWh or \$1,200/kW Peak Demand Savings	May be applicable to Heating Electrification and Heat Pump Installations
	Prescriptive Retrofit	Varies by Equipment Type	Per unit incentives for Lighting, VFDs, high-efficiency pumps, heat pumps, etc.
	Solar PV DER	\$860/kW-AC	For a 240 kW-AC system = \$206,400
Enbridge	Custom Retrofit	\$0.25/m ³ , up to \$100,000	
FCM Green Municipal Fund	GHG Impact Retrofit	Maximum of \$5 million per project.	Up to 25% as a grant and the remainder as a loan. Combined loan and grant for up to 80% of eligible project costs. 30% GHG reduction required
Canadian Infrastructure Bank	Green Infrastructure Program	Varies based on project	Provides financing to reduce investment barriers and decarbonize buildings.



Aladaco Consulting Inc.

Town of Goderich WWTP Decision Making Workshop



Agenda

- Introductions
- Review of the required GHG Reduction Pathways
- Decarbonization Measures Analyzed
- Pathways Development
- Next steps and Discussion




Introductions - Aladaco

- Aladaco Consulting Inc
 - Founded in 2007
 - Energy professionals providing services to help organizations navigate and reach energy efficiency and decarbonization goals
 - Energy management and M&V, GHG inventorying and decarbonization pathways, CDM planning
 - IESO Industrial Technical Review Services



Sean Pittman
Conservation & Energy
Management Lead
P.Eng., CEM, CMVP



Taylor Wilson
Technical Lead - Energy &
Carbon Management
CET, CEM, CMVP



Introductions – HEMCon Energy Modeling Solutions

HEMCon is an energy analysis and building simulation firm.

We specialize in building energy models for new and existing buildings to facilitate good design decisions.



Jeremiah Heffernan
Founder, Principal Energy Analyst
P.Eng, M.Eng., G.Dip Green Energy,
BEMP, LEED AP BD+C




Introductions – Town of Goderich

- Jessica Clapp (Town of Goderich Project Lead)
Asset Management and Environmental Services
Coordinator
- Deanna Hastie
Director of Corporate Services/Treasurer
- Sean Thomas
Director of Community Services,
Infrastructure, and Operations
- Scott Gowan
Veolia Water Canada
- Steve Johnston
Veolia Water Canada



Study Review Process



GHG Reduction Pathways

- **Minimum Performance:** 50% reduction in 10 years, 80% in 20 years
- **Aggressive Deep Retrofit:** 50% reduction in 5 years, 80% in 20 years
- **Business-As-Usual:** Like-for-like replacements with existing specs



ECM Summary

ECM	Energy Savings Potential	GHG Savings Potential	Implementation Cost	Life-Cycle Cost	Selected for Study
Reduce Exhaust Area for Filter Press	Low	Low	\$	Positive	X
Building Envelope Improvements - Windows	Low	Low	\$\$	Negative	
Building Envelope Improvements - Other	Low	Low	\$\$\$\$	Negative	
Process Related VFD Improvements	Medium	Low	\$\$	Positive	
Replace Aerators with Aeration Blowers	Medium	Low	\$\$\$	Positive	X
Replace Aerators with Low-Speed Models	Medium	Low	\$\$\$	Positive	X
High-Efficiency Pumps	Low	Low	\$	Positive	
Thermostat Upgrades	Low	Low	\$	Positive	X
LED Lamps	Low	Low	\$	Positive	
Increase SCADA/BAS capabilities	Low	Low	\$\$\$	Negative	
Truckway Isolation	Low	Low	\$\$	Negative	X
Lockout Garage Heating	Low	Low	\$	Negative	X
Electrification of Heating	Medium	High	\$\$\$	Negative*	X
Solar PV Panels	None	High	\$\$\$	Positive	X


Decarbonization Measures Analyzed

ECM	Annual Utility Savings	GHG Savings (tCO _{2e})	Implementation Cost	NPV	SPP
Reduce Exhaust Area for Filter Press	\$1,218	0.6	\$2,668	\$1,256	3.0
Replace Aerators with Aeration Blowers	\$15,425	7.5	\$265,936	-\$49,307	17.5
Thermostat Upgrades	\$5,119	6.7	\$4,290	\$97,464	0.9
Window Area Reduction in Control Room	\$174	0.5	\$18,932	-\$15,098	109
Electrification of MUA	-\$523	0.2	\$36,681	-\$69,316	-73.0
Electrification of Tube Heaters	-\$3,254	9.2	\$155,595	-\$190,014	-47.8
Electric Unit Heaters to HPs	\$3,039	1.4	\$69,221	-\$16,370	22.8
Solar PV Panels 260 kW DC	\$48,000	25.3	\$645,725	\$228,373	13.5
Solar PV Panels 510 kW DC	\$96,000	50.6	\$1,266,038	\$485,131	13.3



GHG Reduction Pathways

WWTP - GHG Reduction Pathways



GHG Reduction Pathways

Metric	Minimum Performance	Aggressive Deep Retrofit	BAU (Baseline)
Capital Cost	\$1,190,016	\$1,525,183	-
External Funding	\$297,504	\$381,296	-
Residual Value at Study End	\$162,161	\$116,042	-
Operating Costs	\$1,641,359	\$585,699	\$2,836,827
20-Year Operational Cost Savings	\$1,195,468	\$2,251,128	-
20-Year LCC	\$2,371,710	\$1,613,544	-
5-year GHG Reduction (tCO ₂ e)	1 (4%)	21 (60.2%)	-
10-year GHG Reduction (tCO ₂ e)	24 (69.4%)	24 (69.4%)	-
20-year GHG Reduction (tCO ₂ e)	29 (82.8%)	33 (93.5%)	-

ECM Description	Min Performance Year	Aggressive Deep Retrofit Year
WWTP MUA Area Reduction	2026	2027
Solar PV 510 kW DC	-	2026
Aeration Blower	2030	-
Thermostat Upgrades	2026	2026
Window Area Reduction	-	-
Electrification of MUA	2035	-
Electrification of Tube Heaters	2034	2044
Electric Unit Heaters to HPs	-	-
Solar PV 260 kW DC	2026	-



Next Steps

- Finalization of PPT and timeline of measure implementations
- Delivery of Feasibility Study Report Draft (Mid July)
- Final Study Report and Council Presentation (August)





Thank You

Questions?



Powering Progress with
Sustainable Solutions



ECMs – Reduce Exhaust Area for Filter Press

PROJECT DESCRIPTION


- Investigate methods of reducing the overall quantity of air exhausted and replaced during Belt Filter Press operation
- Options to include traditional interior walls, or plastic curtain walls.

ECM OUTCOMES

- Reduces natural gas consumption required to heat make-up air
- Reduces run-time of the make-up air unit fan



ECMs – Reduce Exhaust Area for Filter Press



ECMs – Building Envelope Improvements

PROJECT DESCRIPTION

- Walls Insulation Improvements
- Windows & Doors
- Window Area Reduction

ECM OUTCOMES

- Low quantity of GHG reductions
- Improved Occupant Comfort
- Reduces Equipment Cycling and prolongs expected life



ECMs – Replace Mechanical Aerators with Aeration Blowers

PROJECT DESCRIPTION

- Replace the mechanical aerators with a diffuse aeration system
- Requires Engineering Study to determine feasibility

ECM OUTCOMES

- Reduces electrical consumption related to the treatment of wastewater



ECMs – Replace Mechanical Aerators with Low-Speed Models

PROJECT DESCRIPTION

- Replace the mechanical aerators with a diffuse aeration system
- Requires Engineering Study to determine feasibility

ECM OUTCOMES

- Reduces electrical consumption related to the treatment of wastewater



ECMs – Other Opportunities

PROJECT DESCRIPTION

- High-Efficiency Pumps
 - Thermostat Upgrades
 - LED Lamps
 - Increase SCADA/BAS capabilities
- Isolate Truckway from other interior areas
 - Lock-out heating in garage when bay doors are open



ECMs – Electrify Heating

PROJECT DESCRIPTION

- Replace MAU Natural Gas heating with electric alternative (resistance or Heat Pumps)
- Replace Radiant Tube Heaters with Heat Pumps
- Replace Electric Resistive Unit Heaters with Heat Pumps

ECM OUTCOMES

- Significant reduction in GHG
- Increased building electrical loading



ECMs – Renewable Energy Generation

PROJECT DESCRIPTION

- Install Solar PV Panels on unused property
- 5,000 m² of approximate area available

ECM OUTCOMES

- Significant reduction in GHG from Grid Emissions
- Potential to produce more energy than is consumed on-site
- Rough savings potential of up to: \$110,000/yr and

Funding Opportunities

Funding Entity	Program	Available Funding	Notes
IESO	Custom Retrofit	\$0.13/kWh or \$1,200/kW Peak Demand Savings	Applies to process related improvements. May be applicable to Heating Electrification and Heat Pump Installations
	Prescriptive Retrofit	Varies by Equipment Type	Per unit incentives for Lighting, VFDs, high-efficiency pumps, heat pumps, etc.
	Solar PV DER	\$860/kW-AC	For a 60 kW-AC system = \$51,600
Enbridge	Custom Retrofit	\$0.25/m ³ , up to \$100,000	
FCM Green Municipal Fund	GHG Impact Retrofit	Maximum of \$5 million per project.	Up to 25% as a grant and the remainder as a loan. Combined loan and grant for up to 80% of eligible project costs. 30% GHG reduction required
Canadian Infrastructure Bank	Green Infrastructure Program	Varies based on project	Provides financing to reduce investment barriers and decarbonize buildings.



Appendix F: Sensitivity Analysis

Aladaco's GHG Reduction Pathways analysis relies on several key assumptions that can significantly influence projected outcomes. This section highlights the sensitivity of results to changes in select variables, offering additional insight into how pathway performance may vary. Specifically, it examines the effects of future weather patterns, carbon pricing, and projected grid emission factors.

Future Weather Analysis

The energy models used in this study are based on historical weather data specific to Goderich, Ontario. However, as climate conditions shift, changes in temperature and seasonal patterns will affect facility energy use. To assess this, energy models were updated using projected weather data for 25-year and 50-year time horizons. The analysis indicates a reduction in heating demand and an increase in cooling demand. As a result, the WWTP is expected to use less electricity and natural gas, reflecting its predominantly heating-driven loads. In contrast, the MRC will likely see a slight increase in electricity use due to higher cooling requirements, though natural gas use is expected to decrease. In all scenarios project facility GHG emissions are lower than what has been calculated in the selected GHG Reduction Pathways using 2025 weather data.

MRC Energy Model Results (2050 Weather)	Electricity (kWh)	Natural Gas (m3)	tCO2e	Facility Peak Demand
Minimum Performance Scenario	3,028,685	2,806	53.61	610 kW
Aggressive Deep Retrofit Scenario	3,008,052	0	53.24	620 kW

MRC Energy Model Results (2075 Weather)	Electricity (kWh)	Natural Gas (m3)	tCO2e	Facility Peak Demand
Minimum Performance Scenario	3,093,013	2,380	54.75	624 kW
Aggressive Deep Retrofit Scenario	3,075,840	0	54.44	624 kW

WWTP Energy Model Results (2050 Weather)	Electricity (kWh)	Natural Gas (m3)	tCO2e	Facility Peak Demand
Minimum Performance Scenario	350,117	0	6.20	222 kW
Aggressive Deep Retrofit Scenario	138,097	141	2.72	229 kW

WWTP Energy Model Results (2075 Weather)	Electricity (kWh)	Natural Gas (m3)	tCO2e	Facility Peak Demand
Minimum Performance Scenario	338,424	0	5.99	216 kW
Aggressive Deep Retrofit Scenario	126,550	124	2.48	222 kW

Carbon Pricing Analysis

At the time of this study, the federal carbon tax had been removed from consumer energy pricing. Accordingly, the primary GHG Reduction Pathways and Measures Analysis use a carbon price of \$0. To help the Town of Goderich understand the financial implications should the tax be reinstated, a sensitivity analysis was completed using the federal carbon pricing schedule. This scenario assumes a carbon price of \$95 per tonne in 2025, increasing by \$15 annually to \$170 per tonne in 2030, and remaining at that level through the remainder of the study period. The results demonstrate the added cost burden of continued fossil fuel use and highlight the increased financial value of electrification and emissions reduction strategies in a future with carbon pricing. Relevant changes in each pathway's metrics are highlighted below.



MRC Pathways Metrics with Carbon Pricing	Minimum Performance	Aggressive Deep Retrofit	BAU (Baseline)
Capital Cost	\$6,313,490	\$5,532,788	\$2,208,394
External Funding	\$1,294,266	\$1,383,197	-
BAU Avoided Costs	\$2,208,394	\$2,208,394	
Residual Value at Study End	\$1,757,764	\$707,148	\$397,994
Incremental Costs	\$2,810,831	\$1,941,196	-
Operating Costs	\$12,420,649 (+7%)	\$12,573,689 (+7%)	\$11,753,111 (+12%)
5-year GHG Reduction (tCO ₂ e)	-23 (-5.7%)	202 (50.9%)	
10-year GHG Reduction (tCO ₂ e)	203 (51.3%)	299 (75.3%)	
20-year GHG Reduction (tCO ₂ e)	330 (83.3%)	345 (86.9%)	
Incremental LC Cost (20-year)	\$2,118,599	\$2,452,620	-
Cost per tonne CO₂e abated (\$ILCC/tCO₂e)	\$321 (-17%)	\$356 (-15%)	-

WWTP Pathways Metrics with Carbon Pricing	Minimum Performance	Aggressive Deep Retrofit	BAU (Baseline)
Capital Cost	\$1,190,016	\$1,525,183	-
External Funding	\$297,504	\$381,296	-
Residual Value at Study End	\$162,161	\$116,042	-
Operating Costs	\$1,792,823 (+3%)	\$738,507 (+9%)	\$2,963,843 (4%)
20-Year Operational Cost Savings	\$1,171,021 (+6%)	\$2,225,337 (+3%)	-
20-Year LCC	\$2,523,174 (+2%)	\$1,766,352 (+3%)	-
5-year GHG Reduction (tCO ₂ e)	0 (-0.6%)	20 (55.5%)	-
10-year GHG Reduction (tCO ₂ e)	24 (67.1%)	24 (67.2%)	-
20-year GHG Reduction (tCO ₂ e)	29 (81.5%)	32 (91.3%)	-

Grid Emission Factor Analysis

Projected grid emission factors have a major impact on the results of the GHG Reduction Pathways. As the Town of Goderich reduces its reliance on fossil fuels, the emissions associated with electricity use will become increasingly significant. The primary analysis in this study uses future grid emissions forecasts from the Green Building Council's Zero Carbon Building Workbook, in line with FCM guidance. To test sensitivity, an alternative forecast from the Posterity Group was also applied. Since this source only projects values to 2033, the 2033 factor was held constant for all subsequent years in the analysis.

The results of this comparison show that if future grid emissions are significantly higher than those projected in the Zero Carbon Buildings reference, several of the selected GHG pathways may fall short of their target reductions. This underscores the critical importance of maintaining a clean electricity grid in Ontario, especially as facilities transition carbon-intensive systems to electric alternatives. Without a decarbonized grid, these efforts risk becoming ineffective.



Appendix G: Energy Model Documentation

Simulation Inputs – Maitland Recreation Center:

General Parameters

Location	190 Suncoast Dr E, Goderich, Ontario
Weather File	CWEC 2020 Goderich Weather Data, Modified CWEC 2020 Goderich Weather Data (2050 HDD & CDD Estimate), Modified CWEC 2020 Goderich Weather Data (2075 HDD & CDD Estimate) Custom Goderich 2023 Weather Data
HDD and Climate Zone	4000 (NECB 2020), Climate Zone 6 3734 (CWEC 2020), Climate Zone 5 2971 (CWEC 2050 Estimate), Climate Zone 4 2504 (CWEC 2075 Estimate), Climate Zone 4
Building Type	Recreational
Site Orientation	True North is Project North
Modeled GFA	7,750 m ²
Building Storeys	3 with 1 partially below ground
Occupancy Schedules	Based on: <ul style="list-style-type: none"> 5:30 AM – 11:30 PM Monday – Friday, 7:30 AM – 10:00 PM Saturday - Sunday (Modified from NECB Schedule C for retail spaces) for the Arena 6:00 AM – 10:00 PM Monday – Friday, 8:00 AM – 6:00 PM Saturday, 8:00 AM – 4:00 PM Sunday (Modified from NECB Schedule C for retail spaces) for the Gymnasium and Fitness Various Times for the Canteen
Fan Schedules	Based on: <ul style="list-style-type: none"> Occupancy Schedules previously defined (Modified from NECB Schedule C for retail spaces)
Thermostat Setpoints	Based on: <ul style="list-style-type: none"> 24C for cooling (no night setback) for the general recreational, gymnasium and fitness spaces 21C for heating (no night setback) for the general recreational, gymnasium and fitness spaces 13.3C for heating and cooling (no night setback) for the Arena and Seating Areas

- 27.7C for heating and cooling (no night setback) for the Pool Area

HVAC Plant

	Baseline Design
Cooling Plant	<ul style="list-style-type: none"> • Ground Source Heat Pump Ground Loop • Icecube Ice-making equipment
Heating Plant	<ul style="list-style-type: none"> • 1x Condensing Hot Water Boilers – General Heating Makeup – Not Functional • 1x Condensing Hot Water Boiler – Domestic Hot Water Heating (assumed 80% seasonal efficiency) • 1x Condensing Hot Water Boiler – Pool and Whirlpool Heating (assumed 80% seasonal efficiency) • Common Circulation Pump – Constant Volume 7.5 HP (Assumed 6.0 BHP)
Domestic Hot Water Heating - Load	<ul style="list-style-type: none"> • Domestic hot water load estimated based on the monthly facility natural gas use, measured water use, the average monthly ground temperature and an assumed seasonal efficiency
Pool and Whirlpool Heating - Load	<ul style="list-style-type: none"> • Pool and Whirlpool hot water estimate is based on the facility natural gas use, measured water use, the average monthly ground temperature, pool and whirlpool setpoints and an assumed seasonal efficiency • 1.5 and 5.0 kW Pool Pumps for heating and circulation
Ice Making Equipment	<ul style="list-style-type: none"> • 8x IceKube Heat Pumps – Assumed 4.0 COP • 16x 2.25kW Pumps providing circulation
Ground Source Heat Pump	<ul style="list-style-type: none"> • Based on on-site observations and interviews with the staff, it was determined that the ground loop appears to be operating strictly as a heat rejection device, no additional heat was injected into the loop, and the return temperature to the ground was observed to be 88-90°F at -30°C.

	<ul style="list-style-type: none"> The ground loop itself was not modelled and instead replaced with a heat rejection device on a water loop heat pump loop. 1x 30kW pump providing circulation year round to the ground loop
--	---

HVAC Systems

	Baseline Design
MUA	Cantine Make Up Air Unit <ul style="list-style-type: none"> Heating: Furnace (80% Efficient) Cooling: DX (EER 10 assumed) Airflow: 2,000 cfm Fan Power: 2" Static Pressure (assumed) Controls: fans run according to Cantine schedule Heat Recovery: Not Installed
HRV1 & 2	Dedicated Outdoor Air Units with Heat Recovery <ul style="list-style-type: none"> Heating: Furnace (80% Efficient) Cooling: DX (EER10 assumed) Airflow: 13,200 and 5,500 (estimated from the drawings) Fan Power: 1.5" Static Pressure on Supply and Return Controls: runs during operating hours to deliver outdoor air Heat Recovery: 60% heat recovery (estimated)
Pool and Whirlpool	Dehumidification Unit <ul style="list-style-type: none"> Heating: Furnace (80% Efficient) Cooling: DX (EER 10) Airflow: 3000 cfm Fan Power: 2.0" Static Pressure Controls: runs as required to maintain humidity
Gymnasium, Locker Rooms, Workout, etc.	Water Loop Heat Pump <ul style="list-style-type: none"> Heating: Heat Pump (3.0 COP) Cooling: Heat Pump (3.0 COP) Airflow: cfm varies (sized by software) Fan Power: 0.5" Static Pressure (assumed) Controls: runs as required to maintain thermostat setpoint

Arena Seating, Change Rooms	In Floor Radiant Heating <ul style="list-style-type: none"> • Heating: Hot Water • Cooling: N/A • Airflow: N/A • Controls: runs as required to maintain thermostat setpoint
------------------------------------	--

Envelope


	Baseline Design
Underground Floors and Walls	Walls <ul style="list-style-type: none"> • 50mm Polystyrene Floors <ul style="list-style-type: none"> • 50mm Polystyrene
Exterior Walls	Typical Brick <ul style="list-style-type: none"> • 90mm Brick, 50mm Rigid Insulation, 190mm Concrete Block • R 9.0 ft² °F/Btu (nominal) • R 6.5 ft² °F/Btu (effective including window perimeters, slab edge) Typical Metal Siding <ul style="list-style-type: none"> • Metal siding, 125mm Semi Rigid Insulation between Studs, 52mm Rigid Insulation, Structural Studs, Interior metal panel • R 28.0 ft² °F/Btu (nominal) • R 12.5 ft² °F/Btu (effective including window perimeters, penetrations)
Exterior Roof	Flat Roof (Estimated) <ul style="list-style-type: none"> • Built up roofing, 4" Rigid Insulation, 6" Concrete Deck • R 20.0 ft² °F/Btu (nominal) • R 17.5 ft² °F/Btu (effective including parapets, penetrations)
Glazing	<ul style="list-style-type: none"> • Double glazed, clear, 13mm Air gap, aluminum frame with standard spacer <ul style="list-style-type: none"> ○ USI 2.8 W/ m² °C (effective) ○ SHGC 0.70 ○ Total WWR 6.9%

Infiltration	<ul style="list-style-type: none"> 0.25 L/s/m² of wall and roof area
---------------------	--


Electrical and Other Loads

	Baseline Design
Lighting	<p>Interior Lighting</p> <ul style="list-style-type: none"> Building average lighting power density is 9.9 W/m² <ul style="list-style-type: none"> Arena: 13.8 W/m² Stairways, locker room, change room, corridors, electrical/mechanical, storage: 5.4 W/m² Gymnasium and Fitness: 10.8 W/m² Pool: 20.4 W/m² <p>Lighting scheduled to be on 90% of peak during normal working hours following the facility schedule. Lighting scheduled to be on at 5% of peak for emergency for all other hours.</p>
Other Electrical Loads	<p>Receptacle Loads</p> <ul style="list-style-type: none"> Building average receptacle power density is 7.3 W/m² <ul style="list-style-type: none"> Office, lounge: 10.8 W/m² Fitness: 53.8 W/m² Locker room, change room: 5.4 W/m² Server: 107.6 W/m² Electrical/mechanical: 16.1 W/m² Office, lounge: 10.8 W/m² <p>Elevator Load</p> <ul style="list-style-type: none"> Modelled as a 14.76 kW load based on the Savings by Design Elevator Schedule <p>Pool Latent Load Assumption</p> <ul style="list-style-type: none"> Modelled as a 35.5kW load based on the methodology presented in "eQuest Pool Modelling Guide for SCA Energy Models 01/02/2023"
Other Natural Gas Loads	<ul style="list-style-type: none"> N/A


South West View (Showing Varied Opaque Constructions)




North East View (Showing Varied Opaque Constructions)



South East View (Showing Varied Window Constructions)



North West View (Showing Varied Window Constructions)



ECM Summary:

#	ECM	Change Location	Change Details
1	ASHP MUA	Canteen MUA Unit	Replace 80% efficient natural gas furnace with air source heat pump (COP 3.0)
2	ASHP HRV1	HRV 1	Replace 80% efficient natural gas furnace with air source heat pump (COP 3.0)
3	ASHP HRV2	HRV 2	Replace 80% efficient natural gas furnace with air source heat pump (COP 3.0)
4	ASHP Pool Dehumidifier	Pool Dehumidifier	Replace 80% efficient natural gas furnace with air source heat pump (COP 3.0)
5	Electric Unit Heaters	Unit Heaters	Replace 80% efficient natural gas furnace unit heaters with electric unit heaters)
6	VFD Pool Pumps	Pool Pumps	Add VFD to pool pumps
7	Triple Glazed Pool Windows	Glazing	Triple glazed, low-e (0.1) (surface 2 an 5), 13mm Ar gap, vinyl or fiberglass frame with insulating spacer <ul style="list-style-type: none"> ○ USI 1.15 W/ m² °C (effective) ○ SHGC 0.48
8	Electric Domestic Hot Water Boiler	DHW Boiler	Replace 80% seasonal efficient natural gas boiler with an electric boiler
9	Heat Pump Domestic Hot Water Boiler	DHW Boiler	Replace 80% seasonal efficient natural gas boiler with a water loop heat pump boiler (seasonal COP 2.5)
10	Electric Pool Boiler	Pool Boiler	Replace 80% seasonal efficient natural gas boiler with an electric boiler
11	Heat Pump Pool Boiler	Pool Boiler	Replace 80% seasonal efficient natural gas boiler with a water loop heat pump boiler (seasonal COP 2.5)
12	Electric Whirlpool Boiler	Whirlpool Boiler	Replace 80% seasonal efficient natural gas boiler with an electric boiler
13	Heat Pump Whirlpool Boiler	Whirlpool Boiler	Replace 80% seasonal efficient natural gas boiler with a water loop heat pump boiler (seasonal COP 2.5)
14	2025 – Minimum Performance	Misc	ECMs 01, 02, 03, 04, 09, 11, 13 Combined CWEC 2020 Weather File
15	2050 – Minimum Performance	Misc	ECMs 01, 02, 03, 04, 09, 11, 13 Combined Modified CWEC 2050 Weather File

16	2075 – Minimum Performance	Misc	ECMs 01, 02, 03, 04, 09, 11, 13 Combined Modified CWEC 2075 Weather File
17	2025 – Aggressive	Misc	ECMs 01, 02, 03, 04, 05, 09, 11, 13 Combined CWEC 2020 Weather File
18	2050 – Aggressive	Misc	ECMs 01, 02, 03, 04, 05, 09, 11, 13 Combined Modified CWEC 2050 Weather File
19	2075 – Aggressive	Misc	ECMs 01, 02, 03, 04, 05, 09, 11, 13 Combined Modified CWEC 2075 Weather File

Results Summary:

#	ECM	Electrical Use (kWh)	Natural Gas Use (ekWh)	Total Energy (ekWh)	Total CO2 (kg)	Energy Savings	CO2 Savings
	Baseline	1,941,348	1,688,490	3,629,838	400,755	0.0%	0.0%
1	ASHP MUA	1,961,630	1,634,267	3,595,897	392,017	0.9%	2.2%
2	ASHP HRV1	2,034,524	1,484,991	3,519,515	368,813	3.0%	8.0%
3	ASHP HRV2	2,000,026	1,585,524	3,585,551	385,170	1.2%	3.9%
4	ASHP Pool Dehumidifier	2,324,957	1,160,324	3,485,281	324,941	4.0%	18.9%
5	Electric Unit Heaters	1,963,887	1,655,370	3,619,257	395,925	0.3%	1.2%
6	VFD Pool Pumps	1,939,677	1,688,490	3,628,168	400,672	0.0%	0.0%
7	Triple Glazed Pool Windows	1,940,469	1,644,994	3,585,463	392,888	1.2%	2.0%
8	Electric Domestic Hot Water Boiler	2,321,499	1,213,375	3,534,874	334,310	2.6%	16.6%
9	Heat Pump Domestic Hot Water Boiler	2,093,437	1,213,375	3,306,813	322,907	8.9%	19.4%
10	Electric Pool Boiler	2,138,047	1,438,828	3,576,875	365,686	1.5%	8.8%
11	Heat Pump Pool Boiler	2,020,016	1,438,828	3,458,844	359,785	4.7%	10.2%
12	Electric Whirlpool Boiler	1,974,732	1,646,753	3,621,485	394,918	0.2%	1.5%

13	Heat Pump Whirlpool Boiler	1,954,713	1,646,753	3,601,466	393,917	0.8%	1.7%
14	2025 – Minimum Performance	2,807,488	35,319	2,842,806	146,727	21.7%	63.4%
15	2050 – Minimum Performance	2,870,680	29,163	2,899,843	148,779	20.1%	62.9%
16	2075 – Minimum Performance	2,923,878	24,738	2,948,615	150,643	18.8%	62.4%
17	2025 – Aggressive	2,782,076	-	2,782,076	139,104	23.4%	65.3%
18	2050 – Aggressive	2,850,046	-	2,850,046	142,502	21.5%	64.4%
19	2075 – Aggressive	2,906,702	-	2,906,702	145,335	19.9%	63.7%

Simulation Inputs – Wastewater Treatment Plant:

General Parameters

Location	211 Sunset Dr, Goderich, Ontario
Weather File	CWEC 2020 Goderich Weather Data, Modified CWEC 2020 Goderich Weather Data (2050 HDD & CDD Estimate), Modified CWEC 2020 Goderich Weather Data (2075 HDD & CDD Estimate) Custom Goderich 2023 Weather Data
HDD and Climate Zone	4000 (NECB 2020), Climate Zone 6 3734 (CWEC 2020), Climate Zone 5 2971 (CWEC 2050 Estimate), Climate Zone 4 2504 (CWEC 2075 Estimate), Climate Zone 4
Building Type	Industrial
Site Orientation	True North is Project North
Modeled GFA	657 m ²
Building Storeys	1, with pump houses partially below ground
Occupancy Schedules	Based on:

	<ul style="list-style-type: none"> 7:00 AM – 3:30PM Monday – Friday (Modified from NECB Schedule A for office spaces)
Fan Schedules	Based on: <ul style="list-style-type: none"> 7:00 AM – 3:30PM Monday – Friday (Modified from NECB Schedule A for office spaces)
Thermostat Setpoints	Based on: <ul style="list-style-type: none"> 15C for heating (no night setback) for pumphouses and non-regularly occupied admin spaces 20C for heating (no night setback) for office and control room admin spaces 24C for cooling (no night setback) for chemical room admin space.

HVAC Plant

	Baseline Design
Cooling Plant	<ul style="list-style-type: none"> N/A
Heating Plant	<ul style="list-style-type: none"> N/A
Domestic Hot Water Heating - Load	<ul style="list-style-type: none"> 30 Watts per Occupant (Based on NECB default modified by utility analysis) 2 Occupants DHW based on NECB Schedule A for office
Domestic Hot Water Heating - Equipment	<ul style="list-style-type: none"> 1x Hot Water Boilers – Electric

HVAC Systems

	Baseline Design
Ventilation	Filter Make Up Air Unit <ul style="list-style-type: none"> Heating: Furnace (80% Efficient) Cooling: N/A Airflow: 4,000 cfm Fan Power: 7.5 HP, Variable Volume (assumed 6.0 bhp) Controls: fans and operation interlocked with filter press room equipment (approximately 2 hours a day) Heat Recovery: Not Installed

Pump Houses	Electric Unit Heater <ul style="list-style-type: none"> • Heating: Electric • Cooling: N/A • Airflow: 350-800 cfm (sized by software) • Fan Power: 0.1" Static Pressure • Controls: runs as required to maintain thermostat setpoint
Admin Building	Radiant Tube Heaters <ul style="list-style-type: none"> • Heating: Furnace (90% Efficient) • Cooling: Window AC in chemical room (EER 10) • Airflow: N/A • Fan Power: N/A • Controls: runs as required to maintain thermostat setpoint


Envelope

	Baseline Design
Underground Floors and Walls	Walls <ul style="list-style-type: none"> • 1" insulated board, 6" concrete Floors <ul style="list-style-type: none"> • No Insulation
Exterior Walls	Typical Brick <ul style="list-style-type: none"> • 4" Brick, 1.5" Insulated Board, 6" Concrete block • R 11.6 ft² °F/Btu (nominal)
Exterior Roof	Flat Roof (Estimated) <ul style="list-style-type: none"> • Built up roofing, 2" Rigid Insulation, 6" Concrete Deck • R 9.5 ft² °F/Btu (nominal)
Glazing	<ul style="list-style-type: none"> • Double glazed, clear, 13mm Air gap, aluminum frame with standard spacer <ul style="list-style-type: none"> ◦ U_{SI} 2.8 W/ m² °C (effective) ◦ SHGC 0.66
Infiltration	<ul style="list-style-type: none"> • 0.38 L/s/m² of wall and roof area (estimated)


Electrical and Other Loads

	Baseline Design
Lighting	Interior Lighting <ul style="list-style-type: none"> Admin building average lighting power density is 8.1 W/m² Pump house building average lighting power density is 5.4 W/m² <p>Lighting scheduled to be on 90% of peak during normal working hours (6am to 4pm) Monday to Friday. Lighting scheduled to be on at 5% of peak for emergency for all other hours.</p>
Other Electrical Loads	Receptacle Loads <ul style="list-style-type: none"> Building average receptacle power density is 2.7 W/m² WWTP Process Equipment Load <ul style="list-style-type: none"> Calculated as 675,000 kWh. Modelled as 154 kW load 12 hours a day
Other Natural Gas Loads	<ul style="list-style-type: none"> N/A


South West View (Showing Varied Opaque Constructions)




North East View (Showing Varied Opaque Constructions)



South East View (Showing Varied Opaque Constructions)



North West View (Showing Varied Opaque Constructions)



ECM Summary:

#	ECM	Change Location	Change Details
1	Electric MUA Unit	Belt MUA	Replace 80% efficient natural gas furnace with air source heat pump (COP 3.0)
2	Pump House ASHP	Pump Houses	Replace electric unit heaters with air source heat pump (COP 3.0)
3	ASHP Truck Bay	Admin Building	Replace 90% efficient radiant tube heaters with heating only air source heat pump (COP 3.0)
4	ASHP Belt Room	Admin Building	Replace 90% efficient radiant tube heaters with heating only air source heat pump (COP 3.0)
5	ASHP Chemical Room	Admin Building	Replace 90% efficient radiant tube heaters with heating only air source heat pump (COP 3.0)
6	ASHP Locker Room	Admin Building	Replace electric heater with air source heat pump (COP 3.0)
7	ASHP Office	Admin Building	Replace electric heater with air source heat pump (COP 3.0)
8	ASHP Control Room	Admin Building	Replace 90% efficient radiant tube heaters with air source heat pump (COP 3.0)
9	ASHP Chlorine Room	Admin Building	Replace 90% efficient radiant tube heaters and window air conditioner with air source heat pump (COP 3.0)
10	ASHP Workshop	Admin Building	Replace 90% efficient radiant tube heaters with heating only air source heat pump (COP 3.0)
11	ASHP All Admin Rooms	Admin Building	Replace all heating elements in the Admin Building to air source heat pump (COP 3.0). Cooling in the Office, Control Room and Chemical Room.
12	Reduce Filter Press Area	Filter Press Room	Reduce area of filter press room, reducing process energy by 7,000 kWh per year
13	Replace Process Aerators	Process Equipment	Replace mechanical agitators with blowers. Replace 80% seasonal efficient natural gas boiler with a water loop heat pump boiler (seasonal COP 2.5)
14	Adjust Occupancy Schedule	Pump Houses and Admin Building	Thermostats changed to occupancy based. Pumphouses and most Admin building spaces: 17C for 2 hours per day, 11C for all other times. Control room, office: 21C from 7:00-3:30 M-F, 15C for all other times.

15	Reduce Control Room Windows	Control Room	Reduce control room windows by 65% by replacing curtainwall with 2 punched windows 5.5'x3.25'
16	2025 – Minimum Performance	Misc	ECMs 01, 11, 12, 13, 14 Combined CWEC 2020 Weather File
17	2050 – Minimum Performance	Misc	ECMs 01, 11, 12, 13, 14 Combined Modified CWEC 2050 Weather File
18	2075 – Minimum Performance	Misc	ECMs 01, 11, 12, 13, 14 Combined Modified CWEC 2075 Weather File
19	2025 – Aggressive	Misc	ECMs 11, 12, 14 Combined CWEC 2020 Weather File
20	2050 – Aggressive	Misc	ECMs 11, 12, 14 Combined Modified CWEC 2050 Weather File
21	2075 – Aggressive	Misc	ECMs 11, 12, 14 Combined Modified CWEC 2075 Weather File

Results Summary:

#	ECM	Electrical Use (kWh)	Natural Gas Use (ekWh)	Total Energy (ekWh)	Total CO2 (kg)	Energy Savings	CO2 Savings
	Baseline	725,188	68,029	793,217	48,495	0.0%	0.0%
1	Electric MUA Unit	726,595	66,094	792,689	48,217	0.1%	0.6%
2	Pump House ASHP	714,109	68,029	782,137	47,941	1.4%	1.1%
3	ASHP Truck Bay	731,314	55,337	786,651	46,519	0.8%	4.1%
4	ASHP Belt Room	734,772	53,784	788,556	46,412	0.6%	4.3%
5	ASHP Chemical Room	722,579	68,263	790,842	48,407	0.3%	0.2%
6	ASHP Locker Room	725,862	67,149	793,011	48,370	0.0%	0.3%
7	ASHP Office	722,697	68,380	791,077	48,434	0.3%	0.1%
8	ASHP Control Room	732,867	51,498	784,365	45,906	1.1%	5.3%
9	ASHP Chlorine Room	727,972	61,844	789,817	47,522	0.4%	2.0%
10	ASHP Workshop	734,655	54,048	788,703	46,454	0.6%	4.2%

11	ASHP All Admin Rooms	759,832	1,934	761,767	38,340	4.0%	20.9%
12	Reduce Filter Press Area	718,154	68,322	786,475	48,196	0.8%	0.6%
13	Replace Process Aerators	636,086	68,322	704,407	44,092	11.2%	9.1%
14	Adjust Occupancy Schedule	704,818	41,327	746,145	42,674	5.9%	12.0%
15	Reduce and Replace Control Room Windows	725,217	65,801	791,018	48,096	0.3%	0.8%
16	2025 – Minimum Performance	667,535	-	667,535	33,377	15.8%	31.2%
17	2050 – Minimum Performance	650,184	-	650,184	32,509	18.0%	33.0%
18	2075 – Minimum Performance	638,489	-	638,489	31,924	19.5%	34.2%
19	2025 – Aggressive	755,260	1,700	756,960	38,069	4.6%	21.5%
20	2050 – Aggressive	738,172	1,466	739,638	37,172	6.8%	23.3%
21	2075 – Aggressive	726,624	1,290	727,914	36,563	8.2%	24.6%

Appendix H: References

- Building Transparency. (2024). *EPD Database*. Retrieved from <https://www.buildingtransparency.org/tools/#epd-database>
- Energy Star Portfolio Manager. (2023). *Technical Reference: Canadian Energy Use Intensity by Property Type*.
- Finnegan, S., Jones, C., & Sharples, S. (2018). The embodied CO₂e of sustainable energy technologies used in buildings: A review article. *Science Direct*, 50-61.
- IVL Swedish Environmental Research Institute. (2024). *EPD Swegon GOLD RX 100/ 120 – SILVER C RX 100/ 120*. Swegon Group AB.
- Posterity Group. (2018). *Market Characterization & Conservation Potential for Ontario's Drinking Water & Wastewater Treatment Plants*. Independent Electricity System Operator.
- Santos, A. F. (2023). An Eco-Energetic Performance Comparison of Dehumidification Systems in High-Moisture Indoor Environments. *Applied Sciences*.
- The Atmospheric Fund. (June 2024). *Ontario Electricity Emissions Factors and Guidelines*.

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Deanna Hastie, Director of Corporate Services/Treasurer
Meeting Date: August 11, 2025
Subject: 2025 Capital Projects Report to June 30
Attachment(s): 1) 2025 Capital Projects Report to June 30

Recommendation:

That Goderich Town Council receives this report for information.

Report Summary:

Updates for Council regarding the status of approved capital projects are provided throughout the year as part of the monitoring of approved projects and expenditures.

A summary of 2025 budgeted capital projects and expenditures paid to June 30 is attached to this staff report for Council's information, with comments regarding project status.

Capital projects are monitored by Department Managers and the Treasury Department throughout the year to ensure that budgeted expenditures and funding accurately reflect actual project costs and are as committed to in the approved budget.

Background and Analysis:

Nothing further to report.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☒ No. 1 Safe and Reliable Infrastructure
- ☐ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☒ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

And directly impacts (Choose all that apply):

- ☒ Road Network
- ☒ Water Network
- ☒ Sanitary Network
- ☒ Storm Network
- ☒ Fleet
- ☒ Facilities

- ☒ State of Good Repair/Replacement
- ☐ Municipal Levels of Service
- ☐ Risk Management
- ☐ Growth Impacts
- ☐ Financial Strategy

- ☒ Land Improvements
- ☒ Machinery and Equipment

Financial Impacts and/or Source of Funding:

The financial impact associated with the listed capital projects is as budgeted.

Consulted With:

N/A

Approved By:

Janice Hallahan, Chief Administrative Officer

Andrea Fisher, Director of Legislative Services/Clerk

Town of Goderich
2025 - Q2 Capital Projects Report

Land and Land Improvements	Cost	June 30	Comments
North Harbour Road - stairs	600,000	20,240	
Pollution Control Plant - Outfall	500,000	245,323	
Childcare parking lot improvements	15,000		Improvements complete - invoice not yet received
	1,115,000	265,563	

Building			
Columbarium - Cemetery	45,000	29,346	Complete
Victoria Park Pavilion roof	35,000		planned for fall
Master Control Centre/HVAC, filter upgrade, settling pond and Storm drain	4,409,375	125,276	
Bricking/Cladding - Maitland Recreation Centre	525,000	1,141	
Generator replacement - MacKay Centre	50,000		nearing completion
HVAC unit replacement - Town Hall	30,000		Installed - Supplier IT to update programing in August
Rental house roof replacement	8,000		
HVAC unit replacement - Library	20,000		
Loading dock carryforward - Water Treatment plant	40,000	32,187	Complete
Renovation - Maitland Valley Medical Centre	215,000		
Balance of Studio flooring - MRC		7,130	Complete
Generator at childcare - carryover		19,337	Complete
	5,377,375	187,950	

Linear			
Rebuilding Downtown Infrastructure Project - Year 1 of construction	5,533,945	534,709	On going
Suncoast Drive - Roadwork carryover from 2024	2,556,191	257,022	On going
Wolfe and Albert - Roadwork carryover from 2024	166,900		
Albert/Anglesea - top coat	58,101		
Crack sealing	25,000		
Water - as built	1,000		
Line painting - Stanley St parking	5,000		Complete - costs not allocated
	8,346,137	791,731	

Machinery and Equipment			
Water equipment and machinery - various	628,000	155,910	ongoing
Wastewater machinery and equipment - various	240,800	27,896	ongoing
Breathing air compressor - Fire	80,000		RFP complete - results to come to Council
Mowers - (2) Parks	50,000		August delivery expected
Airport - mower (carryover)	30,000		Supplier delay
Airport Fuel Point of Sale System replacement	40,000		
Overseeder - Cemetery	25,000		Pending
Phone system replacement - Townhall + other locations	17,000		Implementation in August
New Boardroom table - Menesetung	5,000	3,021	Complete
Floor scrubber - Recreation	15,000	16,790	Complete
Road maintenance equipment	75,000		Creating RFP
	1,205,800	203,617	

Vehicles			
Rescue truck - Fire	900,000		Tender accepted - Fire Chief to make adjustments to extras to result in cost of \$950k
One Ton Dump Truck - Cemetery	75,000		
Animal Control - SUV	70,000	67,642	Complete
Pick up - Recreation	50,000		August delivery expected
Conversion of Pumper Truck - Fire	50,000		Deferred
Pick up - Works	50,000		August delivery expected
Pick up - Parks	50,000	44,576	Complete
Pick up - Carryover - Parks	50,000		August delivery expected
	1,295,000	112,218	

17,339,312	1,561,080
-------------------	------------------

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Deanna Hastie, Director of Corporate Services/Treasurer
Meeting Date: August 11, 2025
Subject: Council and Staff Expenses to June 30, 2025
Attachment(s): 1) Council and Staff Expenses Report to June 30, 2025

Recommendation:

That Goderich Town Council receives this report for information.

Report Summary:

Information regarding Council and staff expense is provided to Council on a quarterly basis.

Background and Analysis:

Quarterly reports are provided to Council reflecting costs incurred for meetings, conferences, and other training by Council and staff. These reports are posted on the Town's website.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☐ No. 1 Safe and Reliable Infrastructure
- ☐ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☒ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

- ☐ Road Network
- ☐ Water Network
- ☐ Sanitary Network
- ☐ Storm Network
- ☐ Fleet
- ☐ Facilities
- ☐ Land Improvements
- ☐ Machinery and Equipment

And directly impacts (Choose all that apply):

- ☐ State of Good Repair/Replacement
- ☐ Municipal Levels of Service
- ☐ Risk Management
- ☐ Growth Impacts
- ☐ Financial Strategy

Financial Impacts and/or Source of Funding:

The expenses incurred represent the financial impact to the Corporation and are within the 2025 budgeted allocation.

Consulted With:

N/A

Approved By:

Janice Hallahan, Chief Administrative Officer

Andrea Fisher, Director of Legislative Services/Clerk

EXPENSES 2025

		Registration Fee	Accommodations	Travel (mileage/parking/tr ain/plane/taxi)	Expense Allowance - Meals, Misc etc	Per Diem	Expenses to Date for 2025
Council:							
Mayor Trevor Bazinet							
Blue Branch Tour				\$ 169.88		\$ 105.00	\$ 274.88
Clean Energy Frontier				\$ 92.07			\$ 92.07
CNA Conference		\$ 1,475.52	\$ 1,147.27	\$ 824.93		\$ 594.00	\$ 4,041.72
Marine Industry on the Great Lakes General Meeting			\$ 345.17	\$ 395.19	\$ 31.94	\$ 105.00	\$ 877.30
Great Lakes Cities Initiative Round Table			\$ 656.90	\$ 115.64		\$ 198.00	\$ 970.54
SOIC Q2 Meeting				\$ 92.07			\$ 92.07
Huron Economic Outlook					\$ 28.45		\$ 28.45
United Way					\$ 53.15		\$ 53.15
Thrive Summit		\$ 43.93					\$ 43.93
HC Municipal Officers AGM		\$ 50.00				\$ 198.00	\$ 248.00
							\$ -
Total		\$ 1,569.45	\$ 2,149.34	\$ 1,689.78	\$ 113.54	\$ 1,200.00	\$ 6,722.11
Deputy Mayor Leah Noel							
ROMA Conference		\$ 742.85	\$ 623.46	\$ 3.30	\$ 17.00	\$ 594.00	\$ 1,980.61
Council Roles & Responsibility Training						\$ 105.00	\$ 105.00
FCM Conference		\$ 1,221.12	\$ 926.38	\$ 864.75		\$ 396.00	\$ 3,408.25
							\$ -
Total		\$ 1,963.97	\$ 1,549.84	\$ 868.05	\$ 17.00	\$ 1,095.00	\$ 5,493.86
Councillor Liz Petrie							
Mayors Luncheon					\$ 43.25		\$ 43.25
FCM Conference		\$ 1,221.12	\$ 990.48	\$ 868.83			\$ 3,080.43
							\$ -
Total		\$ 1,221.12	\$ 990.48	\$ 868.83	\$ 43.25	\$ -	\$ 3,123.68

EXPENSES 2025

		Registration Fee	Accommodations	Travel (mileage/parking/tr ain/plane/taxi)	Expense Allowance - Meals, Misc etc	Per Diem	Expenses to Date for 2025
Councillor Allison Segeren							
OGRA		\$ 966.72	\$ 1,096.98	\$ 255.42		\$ 501.00	\$ 2,820.12
Code of Conduct Training						\$ 105.00	\$ 105.00
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ 966.72	\$ 1,096.98	\$ 255.42	\$ 43.25	\$ 606.00	\$ 2,968.37
Councillor John Thompson							
OGRA		\$ 966.72	\$ 1,194.08	\$ 237.10		\$ 501.00	\$ 2,898.90
Mayors Luncheon					\$ 43.25		\$ 43.25
Strong Mayor Powers Webinar						\$ 105.00	\$ 105.00
							\$ -
Total		\$ 966.72	\$ 1,194.08	\$ 237.10	\$ 43.25	\$ 606.00	\$ 3,047.15
Councillor Randy Carroll							
ROMA Conference		\$ 742.85	\$ 623.46	\$ 300.69	\$ 55.83	\$ 594.00	\$ 2,316.83
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ 742.85	\$ 623.46	\$ 300.69	\$ 99.08	\$ 594.00	\$ 2,360.08
Councillor Vanessa Kelly							
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ -	\$ -	\$ -	\$ 43.25	\$ -	\$ 43.25
Total Council Expenses From January 1 - June 30, 2025							
		\$ 7,430.83	\$ 7,604.18	\$ 4,219.87	\$ 402.62	\$ 4,101.00	\$ 23,758.50

		Registration Fee	Accommodations	Travel (mileage/parking/tr ain/plane/taxi)	Expense Allowance - Meals, Misc etc	Per Diem	Expenses to Date for 2025
Municipal Staff:							
CAO, J. Hallahan							
ROMA Conference		\$ 742.85	\$ 751.67	\$ 255.46	\$ 51.86		\$ 1,801.84
Now Housing/Building Bright Futures Rural Ontario				\$ 233.29			\$ 233.29
Huron Economic Outlook		\$ 28.45					\$ 28.45
AMO		\$ 915.84					\$ 915.84
United Way		\$ 53.15					\$ 53.15
Thrive Summit		\$ 43.93					\$ 43.93
HC Municipal Officers AGM		\$ 50.00					\$ 50.00
Mayors Luncheon					\$ 43.25		\$ 43.25
CAO/Mayor-Chamber Meeting					\$ 52.45		\$ 52.45
							\$ -
Total		\$ 1,834.22	\$ 751.67	\$ 488.75	\$ 147.56	\$ -	\$ 3,222.20
Director of Corporate Services/Treasurer - D. Hastie							
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ -	\$ -	\$ -	\$ 43.25	\$ -	\$ 43.25
Director of Community Services, Infrastructure & Operations -S. Thomas							
OGRA		\$ 966.72	\$ 1,096.98	\$ 128.16			\$ 2,191.86
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ 966.72	\$ 1,096.98	\$ 128.16	\$ 43.25	\$ -	\$ 2,235.11
Director of Legislative Services/Clerk - A Fisher							
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ -	\$ -	\$ -	\$ 43.25	\$ -	\$ 43.25
Deputy Clerk (Records Management)- A. Banting							
AMCTO Training		\$ 375.49					\$ 375.49
							\$ -
Total		\$ 375.49	\$ -	\$ -	\$ -	\$ -	\$ 375.49
CEMC, Accessibility and Health & Safety Manager - M. Johnston							
Nuclear Innovation Institute				\$ 129.60			\$ 129.60
Emergency Exercise Mileage - May				\$ 35.01			\$ 35.01
Thrive Summit				\$ 108.93			\$ 108.93
CWSB Meeting				\$ 27.23			\$ 27.23
							\$ -
Total		\$ -	\$ -	\$ 300.77	\$ -	\$ -	\$ 300.77
Finance and Human Resources Manager - T. Mero							
							\$ -
Total		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Finance and Taxation Manager -T. Darnbrough							
							\$ -
Total		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Tourism & Community Development Manager - J. Ujiye							
Thrive Summit		\$ 43.93					\$ 43.93
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ 43.93	\$ -	\$ -	\$ 43.25	\$ -	\$ 87.18

EXPENSES 2025

		Registration Fee	Accommodations	Travel (mileage/parking/tr ain/plane/taxi)	Expense Allowance - Meals, Misc etc	Per Diem	Expenses to Date for 2025
Community Services and Operations Manager -K. Williams							
Good Roads - Municipal Health & Safety Training		\$ 1,277.09	\$ 394.74	\$ 31.01	\$ 189.20		\$ 1,892.04
Small Airports Meeting		\$ 50.00					\$ 50.00
							\$ -
Total		\$ 1,327.09	\$ 394.74	\$ 31.01	\$ 189.20	\$ -	\$ 1,942.04
Manager of Child Care Services - B. Hastings							
Managing Employees Webinar		\$ 158.98					\$ 158.98
Conflict Management Training		\$ 46.99					\$ 46.99
							\$ -
Total		\$ 205.97	\$ -	\$ -	\$ -	\$ -	\$ 205.97
Building Services Manager/CBO - J. Dykstra							
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ -	\$ -	\$ -	\$ 43.25	\$ -	\$ 43.25
Asset Management/Environmental Services Manager -J. Feere							
							\$ -
Total		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Municipal Law Enforcement Manager - D Duncan							
MLEO Canine Bite Assessment Training		\$ 315.46	\$ 96.54	\$ 278.80			\$ 690.80
							\$ -
Total		\$ 315.46	\$ 96.54	\$ 278.80	\$ -	\$ -	\$ 690.80
Facilities Services Manager - J. Dobie							
							\$ -
Total		\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Fire Services Manager/Fire Chief - J. Wormington							
Mayors Luncheon					\$ 43.25		\$ 43.25
							\$ -
Total		\$ -	\$ -	\$ -	\$ 43.25	\$ -	\$ 43.25
Fire Staff							
Ontario Fire College		\$ 325.00					\$ 325.00
DZ License - J. Elliott		\$ 113.75					\$ 113.75
DZ License/Medical - M. Warnholtz		\$ 333.75					\$ 333.75
Pumper Operations Training - All Staff		\$ 213.00			\$ 66.00		\$ 279.00
Certification Mileage - B. Gibson				\$ 491.47			\$ 491.47
Certification Mileage - A. Depatie				\$ 49.28			\$ 49.28
Certification Mileage - B. Craig				\$ 101.15			\$ 101.15
Certification Mileage - J. Fritzley				\$ 491.47			\$ 491.47
							\$ -
Total		\$ 985.50	\$ -	\$ 1,133.37	\$ 66.00	\$ -	\$ 2,184.87

		Registration Fee	Accommodations	Travel (mileage/parking/tr ain/plane/taxi)	Expense Allowance - Meals, Misc etc	Per Diem	Expenses to Date for 2025
Works/Parks/Airport/Recreation Dept Staff							
Good Roads - Signs & Lines Course - A. Swick		\$ 1,277.09	\$ 394.74		\$ 116.55		\$ 1,788.38
Good Roads - TJ Mahony Road School Maintenance - C. Crawford		\$ 1,277.09	\$ 394.74	\$ 31.01	\$ 101.74		\$ 1,804.58
Good Roads - TJ Mahony Road School Maintenance - K. Langille		\$ 1,277.09	\$ 394.74		\$ 82.80		\$ 1,754.63
Ontario Parks Training - N. Feagan		\$ 325.00					\$ 325.00
DZ License - B. Haddock		\$ 113.75					\$ 113.75
DZ License - C. Crawford		\$ 113.75					\$ 113.75
DZ Physical- D. German		\$ 200.00					\$ 200.00
Traffic Protection Emergency Services Training - Misc Staff		\$ 2,900.16					\$ 2,900.16
Small Airport Meeting - J. Vanbeets		\$ 50.00					\$ 50.00
First Aid Training - Misc Staff		\$ 1,587.46					\$ 1,587.46
							\$ -
							\$ -
Total		\$ 9,121.39	\$ 1,184.22	\$ 31.01	\$ 301.09	\$ -	\$ 10,637.71
Child Care Staff							
Jan/Feb Mileage - K. Kyle				\$ 260.65			\$ 260.65
Mar/Apr Mileage - K. Kyle				\$ 330.03			\$ 330.03
Apr/May/Jun Milage - J. Glenn				\$ 680.15			\$ 680.15
May/June Mileage - K. Jyle				\$ 374.77			\$ 374.77
							\$ -
Total		\$ -	\$ -	\$ 1,645.60	\$ -	\$ -	\$ 1,645.60
Misc Staff/Council/Volunteers							
MLEO Canine Bite Assessment Training - N. Smith		\$ 315.45	\$ 96.54				\$ 411.99
OBIA Conference - L. Beatty		\$ 898.54	\$ 568.31				\$ 1,466.85
OBIA Conference - V. Culbert		\$ 898.54	\$ 692.85	\$ 233.42			\$ 1,824.81
Plumbing Inspectors Zone Meeting - L. Fulton				\$ 153.67			\$ 153.67
Code of Conduct Information Session - Council/Misc Staff		\$ 482.94					\$ 482.94
Mayors Luncheon - J. Shrier, S.L. McGregor, G. Stewart, D. Gall, L. Beattie					\$ 221.33		\$ 221.33
CANVA Training - S.L. McGregor				\$ 36.70			\$ 36.70
First Aid Training - Misc Staff		\$ 661.45					\$ 661.45
Traffic Protection Emergency Services Training - Misc Staff		\$ 610.56					\$ 610.56
Thrive Summit - E. McNeil		\$ 43.93					\$ 43.93
Thrive Summit - S.L. McGregor				\$ 36.71			\$ 36.71
ERTH AGM - L. McCabe				\$ 154.96			\$ 154.96
OPIA Meeting - L. Fulton				\$ 162.10			\$ 162.10
							\$ -
Total		\$ 3,911.41	\$ 1,357.70	\$ 777.56	\$ 221.33	\$ -	\$ 6,268.00
Municipal Staff Total January 1 - June 30, 2025		\$ 19,087.18	\$ 4,881.85	\$ 4,815.03	\$ 1,184.68	\$ -	\$ 29,968.74
Total Council & Staff January 1 - June 30, 2025		\$ 26,518.01	\$ 12,486.03	\$ 9,034.90	\$ 1,587.30	\$ 4,101.00	\$ 53,727.24

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Deanna Hastie, Director of Corporate Services/Treasurer
Meeting Date: August 11, 2025
Subject: Request to Increase Direct Electronic Transfer Limit

Recommendation:

That Goderich Town Council approves an increase in the Town's Direct Electronic Transfer daily limit from \$300,000 to \$500,000;

And That Council considers approving an updated Electronic Funds Transfer By-Law later in the agenda to formalize this adjustment if approved.

Report Summary:

The Town of Goderich uses direct deposit to provide employee payroll payments. The Town's payroll payments and related remittances have increased, and as such, the related limit for Direct Electronic Transfers requires adjustment. Staff are requesting an increase to \$500,000 from \$300,000 to ensure that the limit can meet the level of direct payments.

Background and Analysis:

The Town's bank requires a By-Law each year confirming the limit for its Direct Electronic Transfers. Direct electronic payments are used in limited circumstances to settle the Town's liabilities. The most significant direct electronic payment is for bi-weekly payroll. Due to increases in payroll payments and related remittances, an adjustment is requested to the daily limit from \$300,000 to \$500,000. This request does not change the internal controls implemented by the Town to ensure that the payroll payments or any other direct payments are accurate, supported, and authorized. This request relates only to the threshold maintained by the Town's bank for these types of direct disbursements.

Direct payments are also made to pay Town credit card balances monthly, Moneris, our payment processing company, and a handful of other small monthly payments.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☐ No. 1 Safe and Reliable Infrastructure
- ☐ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☐ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

- ☐ Road Network
- ☐ Water Network
- ☐ Sanitary Network
- ☐ Storm Network
- ☐ Fleet
- ☐ Facilities
- ☐ Land Improvements
- ☐ Machinery and Equipment

And directly impacts (Choose all that apply):

- ☐ State of Good Repair/Replacement
- ☐ Municipal Levels of Service
- ☐ Risk Management
- ☐ Growth Impacts
- ☐ Financial Strategy

Financial Impacts and/or Source of Funding:

No financial impact is associated with this report.

Consulted With:

N/A

Approved By:

Janice Hallahan, Chief Administrative Officer
Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Jason Dykstra, Building Services Manager/Chief Building Official
Meeting Date: August 11, 2025
Subject: Temporary Sign Location – Celtic Festival
Attachment(s): 1) Sign Permit Application

Recommendation:

That Goderich Town Council approves the application as submitted for a temporary sign at 47-49 Gloucester Terrace from August 1-11, 2025, for the Celtic Festival.

Report Summary:

This report identifies the placement of a temporary sign at 47-49 Gloucester Terrace from August 1 – 11, 2025.

Background and Analysis:

The Celtic Festival has been a long-running tradition in Goderich. Every year, the Celtic Festival Board applies for temporary signs to be placed around town to assist in directing traffic and promoting the event. Due to other temporary signs being in place this year due to the downtown construction, a new sign location was decided to be placed at 47-49 Gloucester Terrace, which is Town-owned land (The Salt Cairn location).

The Building Services Manager/Chief Building Official has no issue with sight lines or the sign being temporarily placed at this location for this event.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☐ No. 1 Safe and Reliable Infrastructure
- ☒ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☐ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

- ☐ Road Network
- ☐ Water Network
- ☐ Sanitary Network

And directly impacts (Choose all that apply):

- ☐ State of Good Repair/Replacement
- ☐ Municipal Levels of Service
- ☐ Risk Management

- ☐ Storm Network
- ☐ Fleet
- ☐ Facilities
- ☐ Land Improvements
- ☐ Machinery and Equipment

- ☐ Growth Impacts
- ☐ Financial Strategy

Financial Impacts and/or Source of Funding:

There is no financial impact associated with this report.

Consulted With:

N/A

Approved By:

Janice Hallahan, Chief Administrative Officer

Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Jeff Wormington, Fire Services Manager/ Fire Chief
Meeting Date: August 11, 2025
Subject: Replacement of Breathing Air Compressor

Recommendation:

That Goderich Town Council concurs with the Fire Chief/Fire Services Manager's recommendation to authorize the purchase of a new breathing air compressor in the amount of \$77,500, excluding HST.

Report Summary:

The Goderich Fire Department requires a new breathing air compressor due to the age and condition of the current Breathing Air compressor.

Background and Analysis:

The existing breathing air compressor within the Fire Department is encountering significant mechanical challenges attributable to its age and capacity. In 2019, the department upgraded its Self-Contained Breathing Apparatus (SCBA) from 2216 psi to 4500 psi cylinders. Concurrently, the cascade system was enhanced to include 6000 psi bottles; however, the compressor technology was not updated to match this advancement. The inadequate capacity of the legacy compressor's motor and unit size has resulted in substantially prolonged fill times for the new cylinders. These extended fill times negatively impact operations during structural firefighting scenarios, where rapid and reliable support is crucial. The increased operational strain on the dated compressor has led to overheating issues, rendering the equipment inoperative during lengthy emergency responses. Consequently, the department is compelled to seek assistance from neighboring fire departments to replenish cylinder banks in such critical times. This necessity introduces delays, imposes additional burdens on fire crews, and raises substantial safety concerns due to the potential scarcity of refilled air supply cylinders during emergencies.

Requests for Quotations (RFQs) were disseminated via the Bids and Tenders page of the Town's website, resulting in the receipt of two quotations:

- A.J Stone:
 - OPEN HD 400EM Coltri Compressor
 - SS-3PD Fill Station
 - 4 Position DOT Cylinder Rack
 - Quotation: \$71,849.00 plus HST
- M & L Supply:
 - Jordair AIR-KAT6-1214-1EUS
 - 3 Position Fill Station
 - 4 Position DOT Cylinder Rack
 - Quotation: \$77,500.00 plus HST

After evaluating the proposals, I recommend proceeding with the acquisition of the Jordair AIR-KAT6-1214-1EUS system from M & L Supply. This system meets our operational needs more effectively, offers a superior warranty, and comes with positive reviews from other departments using the same system and supplier. Consulting with these departments has confirmed that their experiences align well with our requirements and expectations.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☐ No. 1 Safe and Reliable Infrastructure
- ☐ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☒ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

And directly impacts (Choose all that apply):

- ☐ Road Network
- ☐ Water Network
- ☐ Sanitary Network
- ☐ Storm Network
- ☐ Fleet
- ☐ Facilities
- ☐ Land Improvements
- ☒ Machinery and Equipment

- ☒ State of Good Repair/Replacement
- ☒ Municipal Levels of Service
- ☒ Risk Management
- ☐ Growth Impacts
- ☐ Financial Strategy

Financial Impacts and/or Source of Funding:

Is this cost budgeted for? Yes: ☒ No: ☐

Budget: \$80,000

Actual: \$77,500.00 plus \$10,075.00 HST = \$87,575.00

Recoverable HST = \$8,711.00

Total net cost: \$78,864.00

Balance: \$1,136.00

Consulted With:

Deanna Hastie, Director of Corporate Services/Treasurer

Approved By:

Janice Hallahan, Chief Administrative Officer

Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Jeff Wormington, Fire Services Manager/Fire Chief
Meeting Date: August 11, 2025
Subject: Fire Department Q2 Report

Recommendation:

That Goderich Town Council receives the below detailed report for information regarding the activities and developments of the Goderich Fire Department for the second quarter of 2025.

Report Summary:

General

- Countywide recruit training concluded on June 8, with 13 members of the Goderich Fire Department completing certifications for NFPA Firefighter 1, Firefighter 2, and Hazmat Operations Level. Official results from testing are pending.
- Two members achieved certification in Fire Apparatus Driver Operator, focusing on Pumping Operations.
- The Fire Chief and 2 Captains successfully completed the NFPA 1033 Fire Investigator course held in Lambton Shores.
- Annual SCBA flow testing was conducted with no issues reported.
- Annual Pump testing was completed with minor repairs required on Pumper #14 and Ladder #15.

Fire Chief Activities

- Participated in 3 Huron County Chiefs meetings.
- Engaged in a Smoke Alarm Awareness event at Canadian Tire.
- Attended the Zone 5 PAC meeting in Walkerton.
- Completed 6 residential inspections.
- Conducted 2 Fire Hall tours accompanied by safety talks at St. Mary's School.
- Organized a 'Touch the Truck' event at St. Mary's School.
- Conducted regular administrative duties.
- Initiated development of a Cancer Prevention Program (currently in progress).

Training

- We conducted 6 bi-weekly in-house training sessions, achieving an 80% attendance rate.

Calls for Service

- The Goderich Fire Department responded to 62 calls for service in Q2 2025, an increase from 42 in Q2 of 2024. Breakdown:
 - **Central Huron:** 13
 - **Ashfield–Colborne–Wawanosh:** 15
 - **Goderich:** 34

I trust this information will provide clarity on the department's operations and contributions to public safety during the past quarter.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☐ No. 1 Safe and Reliable Infrastructure
- ☐ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☒ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

And directly impacts (Choose all that apply):

- ☐ Road Network
- ☐ Water Network
- ☐ Sanitary Network
- ☐ Storm Network
- ☐ Fleet
- ☐ Facilities
- ☐ Land Improvements
- ☐ Machinery and Equipment

- ☐ State of Good Repair/Replacement
- ☒ Municipal Levels of Service
- ☐ Risk Management
- ☐ Growth Impacts
- ☐ Financial Strategy

Financial Impacts and/or Source of Funding:

No financial impact is associated with this report.

Approved By:

Janice Hallahan, Chief Administrative Officer
Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Jessica Clapp, Asset Management and Environmental Services Manager
Meeting Date: August 11, 2025
Subject: Green Municipal Fund Community Building Retrofit Feasibility Study – Final Report
Attachment(s): 1) Green Municipal Fund Feasibility Study – Pre-Application
2) Green Municipal Fund Community Building Retrofit Feasibility Study

Recommendation:

That Goderich Town Council receives this staff report for information;

And That Goderich Town Council receives the Greenhouse Gas (GHG) Reduction Feasibility Study, prepared by Aladaco Consulting Inc., to satisfy the requirements of the Federation of Canadian Municipalities (FCM) Green Municipal Fund Community Building Retrofit Feasibility Study Application;

And That the recommendations provided within the GHG Reduction Feasibility Study be directed to staff to consider during future budget discussions.

Report Summary:

Last summer, the Town of Goderich secured funding through FCM's Green Municipal Fund Community Building Retrofit Grant to conduct a feasibility study for the Maitland Recreation Centre and Goderich Wastewater Treatment Plant. The study aimed to explore GHG reduction measures in alignment with FCM's GHG Reduction Pathways Feasibility Study funding requirements, which mandate the following targets:

- **A Minimum Performance Scenario:** Achieve at least 50% GHG reduction by year 10 and at least 80% GHG reduction by year 2045
- **An Aggressive Deep Retrofit Scenario:** Achieve 50% GHG reduction within 5 years and at least 80% GHG reduction by 2045.

Receiving the GHG Reduction Feasibility Study Final Report by Goderich Town Council is the final milestone to fulfill the grant requirements. The study recommends executing the Minimum Performance Scenario at the Maitland Recreation Centre and applying the Aggressive Deep Retrofit Scenario at the Goderich Wastewater Treatment Plant.

Given the various energy conservation capital projects outlined within the GHG Reduction Feasibility Study Final Report that include specified implementation timelines, it is advisable for Goderich Town Council to refer the report to staff for consideration in future budget planning.

Background and Analysis:

In November 2023, the Town of Goderich submitted the pre-application for FCM's Green Municipal Fund Community Building Retrofit Feasibility Study Pathway. This initiative focused on conducting a feasibility study at the Maitland Recreation Centre and Goderich Wastewater Treatment Plant to identify and implement measures to reduce greenhouse gas emissions by at least 50% over 10 years and aim for an 80% reduction over 20 years. Approval of the pre-application phase was granted in February 2024, and the full application was subsequently submitted. In June 2024, full grant approval was received, and Aladaco Consulting Inc. was contracted in August 2024 to execute the feasibility study as per FCM's funding agreement, which spans September 1, 2024, to August 30, 2025.

The following required milestones have been completed over the past year, as per FCM's funding requirements:

- Site Investigations
- Calibrated Energy Modelling
- Workshop #1: Design Workshop with Town of Goderich staff
- Measure Level Analysis
- GHG Reduction Scenario Planning
- Workshop #2: Decision Making Workshop with Town of Goderich staff
- Final Report and Presentation

The GHG Reduction Feasibility Study Final Report, presented by Aladaco Consulting Inc., recommends executing the Minimum Performance Scenario at the Maitland Recreation Centre and applying the Aggressive Deep Retrofit Scenario at the Goderich Wastewater Treatment Plant. It is advisable for Goderich Town Council to refer Aladaco's report, including the recommendations provided, to staff for consideration in future budget planning.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☐ No. 1 Safe and Reliable Infrastructure
- ☐ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☐ No. 4 Good Government
- ☒ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

- ☐ Road Network
- ☐ Water Network

And directly impacts (Choose all that apply):

- ☐ State of Good Repair/Replacement
- ☐ Municipal Levels of Service

- ☐ Sanitary Network
- ☐ Storm Network
- ☐ Fleet
- ☐ Facilities
- ☐ Land Improvements
- ☐ Machinery and Equipment

- ☐ Risk Management
- ☐ Growth Impacts
- ☐ Financial Strategy

Financial Impacts and/or Source of Funding:

There is no financial impact associated with this report at the time, as potential energy conservation measures will be incorporated in future budget discussions.

Consulted With:

Deanna Hastie, Director of Corporate Services/Treasurer

Sean Thomas, Director of Community Services, Infrastructure and Operations

Approved By:

Janice Hallahan, Chief Administrative Officer

Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

Report From: Jessica Clapp, Asset Management and Environmental Services Manager

Meeting Date: February 5, 2024

Subject: Green Municipal Fund Community Building Retrofit – Pre-Application

Recommendation:

That Goderich Town Council receive the Green Municipal Fund Community Building Retrofit pre-application report for information.

Report Summary:

To inform Goderich Town Council that the pre-application for the Green Municipal Fund (GMF) Community Building Retrofit (CBR), offered through the Federation of Canadian Municipalities (FCM), has been approved. Staff will move forward with the full application submission.

Background/Analysis:

At the November 6, 2023, meeting, Goderich Town Council authorized staff to submit a pre-application for FCM's Green Municipal Fund (GMF) Community Building Retrofit (CBR) to complete a feasibility study at the Maitland Recreation Centre, as well as the Wastewater Treatment Plant. Completion of a feasibility study will enable the municipality to identify a sequence of greenhouse gas reduction measures to reduce emissions by at least 50% within 10 years and by at least 80% within 20 years.

The Town of Goderich's pre-application was approved by FCM on January 18, 2024. It should be noted that approval of the pre-application indicates that the project meets the eligibility criteria for the grant program, and the municipality can now proceed to the full GMF application stage. Approval of eligibility does not guarantee funding.

Linkages:

- Corporate Strategic Plan Priority #5: Environmental Stewardship

Financial Impacts/Source of Funding:

There is no financial impact associated with this report.

Approved By: Janice Hallahan, Chief Administrative Officer
Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

Report From: Jessica Clapp, Asset Management / Environmental Services Manager

Meeting Date: November 6, 2023

Subject: Green Municipal Fund Community Buildings Retrofit – Feasibility Study

Recommendation:

THAT Goderich Town Council receive this report for information;

AND THAT Goderich Town Council authorize staff to prepare and submit an application to the Green Municipal Fund (GMF) Community Buildings Retrofit Initiative, Feasibility Study stream, offered by the Federation of Canadian Municipalities (FCM), to integrate energy and greenhouse gas (GHG) reductions into long-term plans for managing community buildings.

Report Summary:

Staff are requesting Council's authorization to file a grant application through the Green Municipal Fund Community Buildings Retrofit Initiative, Feasibility Study stream, to integrate energy and greenhouse gas reductions into long-term plans for managing community buildings.

Background/Analysis:

Through FCM's Green Municipal Fund, the Community Buildings Retrofit (CBR) Initiative helps to optimize the energy performance and reduce greenhouse gas emissions of community buildings owned by municipalities, resulting in significant environmental, economic, and social benefits for their communities.

The CBR Feasibility Study provides funding up to 80% of eligible costs, including up to \$65,000 for a single building application and up to \$200,000 for an application that includes a portfolio of buildings. Completion of a feasibility study will enable the municipality to identify a sequence of greenhouse gas reduction measures to reduce emissions by at least 50% within 10 years and by at least 80% (i.e., near net-zero greenhouse gas emissions) within 20 years. Additionally, the study will consider unique objectives and constraints (e.g., building use, capital budgets, equipment renewal cycles, etc.). To capture the greatest greenhouse gas reduction potential, the Town of Goderich's application would include a feasibility study for the Maitland Recreation Centre and Pollution Control Plant.

Applications are accepted year-round until all annual funds are allocated. New applicants are then deferred to April 1 of the following fiscal year. It should be noted, in order to submit future

capital projects through the GMF Community Buildings Retrofit Initiative, an eligibility requirement is for the capital project to be supported by a previously completed feasibility study.

It is recommended that Goderich Town Council authorize staff to prepare and submit an application to the Green Municipal Fund (GMF) Community Buildings Retrofit Initiative, Feasibility Study stream, for the Maitland Recreation Centre and Pollution Control Plant. If approved, the remaining cost not covered by the grant would be funded by the Energy Efficiency Reserve.

Linkages:

Corporate Strategic Plan Priority #5: Environmental Stewardship

Financial Impacts/Source of Funding:

No financial impact associated with this report at this time.

Reviewed By: Deanna Hastie, Director of Corporate Services/Treasurer

Approved By: Janice Hallahan, Chief Administrative Officer
Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Jessica Clapp, Asset Management and Environmental Services Manager
Meeting Date: August 11, 2025
Subject: Public Sector Digest Citywide Decision Support Module

Recommendation:

That Goderich Town Council authorizes staff to purchase the Decision Support module from Public Sector Digest (PSD) Citywide to incorporate proposed service levels into the municipality's financial strategy in preparation for submitting the Town of Goderich's 2025 Asset Management Plan, as mandated by Ontario Regulation 588/17: *Asset Management Planning for Municipal Infrastructure*;

And That the initial implementation cost of \$8,800.00 for the Decision Support module be funded from the Contingency Reserve Fund;

And That the annual subscription fee of \$2,950.00 for the Decision Support module be included in the annual budget.

Report Summary:

The Town of Goderich internally develops its Asset Management Plans to meet the regulatory requirements within Ontario Regulation 588/17 and effectively manages its asset inventory using PSD's Citywide Assets module. With evolving regulatory requirements, including incorporation of proposed service levels, the Town of Goderich would significantly benefit from the newly developed Citywide Decision Support module that captures the asset information found within Citywide Assets module (i.e., asset attribute data, lifecycle events, condition and risk) and creates scenarios to aid in aligning service levels with financial strategies.

Background and Analysis:

The Town of Goderich has been using PSD's Citywide Assets module for over a decade to manage the municipality's asset inventory and related information necessary for fulfilling asset management planning requirements under Ontario Regulation 588/17: *Asset Management Planning for Municipal Infrastructure*. This includes data on asset valuation, age, amortization, replacement cost, condition, lifecycle events, risk, disposal information, asset retirement obligations, and various other asset attributes.

As asset management regulatory requirements continue to evolve, including the latest mandate to incorporate proposed levels of service into the municipal Asset Management Plan, and as the municipality aims to utilize condition and risk data to strengthen its long-term financial strategy with each iteration of the Asset Management Plan, it becomes imperative to have the

appropriate tools that will integrate all the asset information the municipality has been collecting and managing for many years.

A recent tool that PSD has developed as an add-on to other modules within the Citywide suite is Citywide Decision Support (see Figure 1 below). The Citywide Decision Support module, directly linked to asset inventory data in Citywide Assets, utilizes various asset attributes and profiles, lifecycle events, condition, and risk information to generate scenarios that define service levels, optimize replacement and rehabilitation decisions, and compare infrastructure projects, assisting staff with resource allocation. For the Town of Goderich, which internally develops its asset management plan without external consultants, this module is invaluable for meeting Ontario Regulation 588/17 requirements, mandating integration of service levels and lifecycle management within financial strategies. Having access to the Decision Support module empowers Goderich to autonomously continue developing its Asset Management Plans, aligning service levels with financial capabilities, thereby fulfilling regulatory mandates effectively with data-driven insights.




Figure 1. PSD Citywide suite of tools that assist with the Town of Goderich meeting requirements under Ontario Regulation 588/17. Currently, the Town of Goderich has access to Citywide Assets, Citywide GIS, and Citywide CPA (shown above in orange). The Decision Support module is shown above in red. All information, reporting and strategies generated within the GIS, CPA and Decision Support add-on modules are derived from data managed within the Citywide Assets module.

The initial implementation cost of \$8,800.00 to purchase the Decision Support module, which includes licensing, software implementation services and training, is proposed to be funded through the Contingency Reserve Fund. Following this, there is an annual subscription fee of \$2,950.00, which would be accounted for in the annual budget.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☒ No. 1 Safe and Reliable Infrastructure
- ☐ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☒ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

And directly impacts (Choose all that apply):

- ☒ Road Network
- ☒ Water Network
- ☒ Sanitary Network
- ☒ Storm Network
- ☒ Fleet
- ☒ Facilities
- ☒ Land Improvements
- ☒ Machinery and Equipment

- ☐ State of Good Repair/Replacement
- ☒ Municipal Levels of Service
- ☒ Risk Management
- ☒ Growth Impacts
- ☒ Financial Strategy

Financial Impacts and/or Source of Funding:

Is this cost budgeted for? Yes: ☐ No: ☒

Proposed funding source for unbudgeted costs: Contingency Reserve

Consulted With:

Deanna Hastie, Director of Corporate Services/Treasurer

Approved By:

Janice Hallahan, Chief Administrative Officer

Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Michaela Johnston, CEMC, Accessibility and Health & Safety Manager
Meeting Date: August 11, 2025
Subject: Enhancing Access to Spaces for Everyone (EASE) Grant
Attachment(s): None

Recommendation:

That Goderich Town Council concurs with the staff recommendation to make application to the Enhancing Access to Spaces for Everyone (EASE) Grant.

Report Summary:

The Ministry for Seniors and Accessibility is launching a new grant program in 2025 called the Enhancing Access to Spaces for Everyone (EASE) Grant. The goal of this program is to enhance the quality of life for people with disabilities and older adults by supporting them to live active, healthy, safe, and socially connected lives.

The 2025-26 EASE Grant will provide up to a maximum of \$60,000 per successful applicant for projects that take place between November 2025 and September 30, 2026, that align with the following priority:

- Implement improvements to outdoor spaces and the built environment, including housing, to increase accessibility for people with disabilities and older adults

Staff recommend that an application be made for the addition of sensory and inclusive playground equipment at one or more of the Town of Goderich parks. At the time of this report, staff are undertaking discussions with various playground equipment providers to provide quotes for such inclusive equipment. Suggested items include an inclusive 'roundabout', sensory panels, sensory wave spinning seats, and an inclusive "We Rock EZ".

Examples of some suggested items are below.



Background and Analysis:

The Town has several playgrounds, many of which include inclusive features such as accessible swings and sensory equipment. Through replacement of aging equipment, grant funds, and donations, the Town looks to enhancing these public spaces to provide a more inclusive environment for all residents.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☐ No. 1 Safe and Reliable Infrastructure
- ☒ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☐ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

- ☐ Road Network
- ☐ Water Network

And directly impacts (Choose all that apply):

- ☒ State of Good Repair/Replacement
- ☒ Municipal Levels of Service

- ☐ Sanitary Network
- ☐ Storm Network
- ☐ Fleet
- ☐ Facilities
- ☐ Land Improvements
- ☐ Machinery and Equipment

- ☐ Risk Management
- ☐ Growth Impacts
- ☐ Financial Strategy

Financial Impacts and/or Source of Funding:

No financial impact is associated with this report, as this proposed project will not proceed unless the EASE grant application is approved and funding provided. The Grant program is fully funded by the Ministry for Seniors and Accessibility.

Consulted With:

Nathan Feagan, Parks/Cemetery Supervisor

Kyle Williams, Community Services and Operations Manager

Approved By:

Janice Hallahan, Chief Administrative Officer

Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Michaela Johnston, CEMC, Accessibility and Health & Safety Manager
Jeff Wormington, Fire Services Manager/Fire Chief
Meeting Date: August 11, 2025
Subject: Firehouse Subs Grant – 2025 Summer/Fall Cycle

Recommendation:

That Goderich Town Council receives this report for information;

And That Council concurs with the staff recommendation to make an application to the Firehouse Subs Grant 2025 Summer/Fall Cycle for funding in the sum of \$48,265.00 in order to purchase new battery-operated Spreader, Cutter, and Telescoping Ram, which is equipment used for vehicle extractions;

And That the Chief Administrative Officer be given power to act with respect to signing and submitting the Firehouse Subs Grant Application.

Report Summary:

The Firehouse Subs Public Safety Foundation's mission is to impact the lifesaving capabilities and the lives of local heroes and their communities. They aim to accomplish this by providing lifesaving equipment and prevention education tools to first responders and public safety organizations.

Battery-operated rescue tools are necessary as the Fire Department responds to multiple motor vehicle collisions each year, which frequently necessitate the use of rescue tools. A new battery-operated Spreader, Cutter, and Telescoping Ram with batteries and a charger will allow the Fire Department to increase its cutting and extrication speed. It will also allow for two vehicles to be worked on simultaneously while our current spreader and cutter are still viable but are past their expected life and are unreliable due to maintenance issues.

The Goderich Fire Department is requesting funding for the following items:

ES-100-28-18V – Storm Surge with 28" Spreader	\$17,910.00
ESLC-30-18V – Storm Surge 8.25" Cutter	\$17,056.00
ETLS-40-18V – Storm Surge 40" Telescoping Ram	\$13,299.00
TOTAL:	\$48,265.00

Background and Analysis:

Applications for the Firehouse Subs Grant (Summer/Fall Cycle) are currently being accepted. Chief Wormington has been approached by Firehouse Subs (Goderich) to make an application to the grant, and the owner of the Goderich franchise is assisting him with the application.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☒ No. 1 Safe and Reliable Infrastructure
- ☒ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy
- ☒ No. 4 Good Government
- ☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

- ☐ Road Network
- ☐ Water Network
- ☐ Sanitary Network
- ☐ Storm Network
- ☐ Fleet
- ☐ Facilities
- ☐ Land Improvements
- ☒ Machinery and Equipment

And directly impacts (Choose all that apply):

- ☒ State of Good Repair/Replacement
- ☒ Municipal Levels of Service
- ☐ Risk Management
- ☐ Growth Impacts
- ☐ Financial Strategy

Financial Impacts and/or Source of Funding:

Is this cost budgeted for? Yes: ☐ No: ☒

Budget: \$0.00

Actual: \$48,265.00

Difference: \$48,265.00

Proposed funding source for unbudgeted costs: Firehouse Subs Grant

Consulted With:

Firehouse Subs Canada

Approved By:

Janice Hallahan, Chief Administrative Officer
Andrea Fisher, Director of Legislative Services/Clerk

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Jenna Ujiye, Tourism and Community Development Manager
Meeting Date: August 11, 2025
Subject: 2025 Goderich Salt and Harvest Festival Update
Attachment(s): 1) 2025 Food Truck Map.pdf
2) 2025 SALT – Overall Site Plan.pdf
3) OPOP promo leaflet.pdf
4) SALT2025 – MAIN HANDOUT (1).pdf
5) SALT2025 – Salt Walk Site Map
6) Salty Silent Auction.png

Recommendation:

That Goderich Town Council receives this report for information;

And That during the Salt and Harvest Festival, Goderich Town Council approves Town staff's request for an exemption under Section 4.2 of By-Law 14 of 2016 (Municipal Alcohol Policy), for alcoholic beverages to be served in cans instead of plastic or paper cups.

Report Summary:

The 2024 Goderich Salt & Harvest Festival witnessed success, drawing an estimated attendance of 8,000 people, as reflected in the Festival's detailed After-Event Report in November 2024. This accomplishment is underscored by a significant increase compared to previous years, driven by strategic event expansion and an effective promotional campaign. The Festival featured 35 events, with 11 of these being paid opportunities and 24 free to the public, enhancing accessibility and appeal. Major enhancements, such as an extended event duration of two full days of activities downtown versus just one day in 2023, contributed to this growth. Such planning and execution suggests momentum for 2025's festival and have positioned the Town of Goderich confidently to aim in attracting approximately 10,000 visitors in 2025; reinforcing its stance as a vibrant cultural hub. This anticipated growth stands to further support local business activities and tourism opportunities, capitalizing on the Festival's reputation.

Below is an updated list of festival information - The 3rd Annual Goderich Salt & Harvest Festival will be occurring on Labour Day weekend, August 28 – 31, 2025. The following is planned for the weekend:

- **Salty Silent Auction – July 31 – August 26, 2025** - There is a silent auction held online on the saltedgoderich.ca website, with Salted merchandise, a meet and greet with Finger Eleven, and a Compass Minerals underground tour for three (3) people.

- **Goderich BIA Thursday Night Concert, Courthouse Square Plaza and Performance Stage Thursday, August 28** - Local Band Sal's Alley performing 7 PM in Courthouse Square Park. Square Brew will be running a beer garden during the concert.
- **Goderich BIA Thursday Night Market, Courthouse Square Plaza and Performance Stage Thursday, August 28**
- **Goderich BIA and Royal LePage Heartland Realty Friday Night Concert, Courthouse Square Plaza and Performance Stage Friday, August 29** - Partnership with the Goderich BIA. Bands include Texas King, Harley Olivia, The Dyadics, and Full Throttle. Running from 7 PM-Midnight, licensed and an all-ages event.
- **Salted Ceremony, Courthouse Square Park, 10 AM, Saturday, August 30** - Dignitaries and major sponsors are invited to speak on behalf of their organization and celebrate the 2025 festival.
- **Bus Tours, Various Locations, 10 AM to 4 PM, Saturday, August 30 and Sunday, August 31** - Organizers will be blocking the parking spaces on the interior of Courthouse Square between North and Hamilton Street to facilitate a safe loading area.
- **Inflatables, Courthouse Square Park, 10 AM to 3 PM, Saturday, August 30 and Sunday, August 31** - Sponsored by Parrish and Heimbecker, inflatables for various ages will be on site in Courthouse Square Park all weekend long.
- **Our Potential, Our Purpose Exhibit, Courthouse Square Park, 10 AM to 4 PM, Saturday, August 30 and Sunday, August 31. Waiting on final confirmation from Global Affairs Canada.** A free, Canadian Touring Experience where people of all ages can explore what it means to be a global citizen and imagine their role in a world full of potential. Developed by Aga Khan Foundation Canada in partnership with Global Affairs Canada.
- **Compass Minerals Above Ground Experience and Mine Rescue Demonstrations, Courthouse Square Park, 10 AM to 4 PM, Saturday, August 30 and Sunday, August 31**
- **Food Truck Village, Livery Parking, Friday August 29, Saturday, August 30 and Sunday, August 31** - Part of the partnership with Compass Minerals who brings approximately 500 staff and their families to Downtown Goderich. Friday hours: 6 PM – 11 PM. Saturday and Sunday hours: 11 AM – 7 PM. Vendors will be encouraged to re-open between 8 PM and 12 AM to support evening events. Confirmed trucks include, Fo Cheezy, Mardelle's Cookies, Cakes & Coffee, S.W.A.T., Cluck Daddy, My Big Fat Greek Food Truck, and Wicked Witches of West Street.
- **Salted Vendor Village, Courthouse Square Park, 10 AM to 4 PM, Saturday, August 30 and Sunday, August 31**

- **BIA Sidewalk Sales, Courthouse Square, 9 AM to 9 PM, Saturday, August 30 and Sunday, August 31** - Business owners in the downtown core are invited to host sidewalk sales during the festival.
- **Salted Menus, Various Businesses, All Weekend** - Food vendors of Goderich have been invited to create Salted Menus, which Goderich Tourism will promote via social media.
- **Salty Basin Beer Garden, Courthouse Square Plaza** - Working with Festival partners, the Salty Basin Beer Garden will be open to the public on the following dates: Friday, August 29 from 7:30 PM to 12 AM – Sponsored by Royal LePage Heartland Realty; Saturday, August 30 from 11 AM to 5 PM – Sponsored by Coldwell Banker and Sunday, August 31 from 11 AM to 5 PM – Sponsored by Coldwell Banker
- **Afternoon concert in the Salty Basin Beer Garden, Courthouse Stage, 2 PM to 5 PM, Saturday, August 30 of 2025** - Sponsored by Coldwell Banker, Graham Bedard will be performing.
- **Sunday Concert, Courthouse Stage, 10:30 AM to 2 PM, Sunday, August 31 of 2025** - Sponsored by the Goderich BIA with bands Country Junction and Bryan Bicknell Duo.
- **Historical Lit Salt Walk, Rotary Cove Lookout, All Weekend** - This portion of the festival has moved back to Rotary Cove Lookout and will act as a beautiful welcome to our waterfront, a recommended feature of the weekend. Offering an expanded 30 panel historical path.
- **Underground VR Experience, Tourism Information Centre, Saturday, August 30 and Sunday, August 31, 10 AM to 4 PM** - Underground VR experience will once again be available and free for folks to enjoy.
- **Make your Own Margarita, at the Salty Basin Beer Garden, Saturday, August 30 and Sunday, August 31 of 2025, 11 AM to 5 PM** - This was a hit last year. Open to all ages, with a variety of flavours and mixers, alcoholic and non-alcoholic options available.
- **Royal LePage Heartland Realty, Harvest Activities, 10 AM to 4 PM, Saturday, August 30 and Sunday, August 31** - Once again, Royal LePage Heartland Realty, Festival Partner, will be hosting a variety of activities which are free for families to enjoy.
 - **Horse Wagon Rides** between 11 AM and 2 PM
Organizers will be blocking the parking spaces beside North Street to facilitate a safe loading area.
 - **Family Photo Booth** between 10 AM and 4 PM
 - **Little Hobby Farm Petting Zoo** between 10 AM and 4 PM

- **Compass Mineral Concert ft. Finger Eleven with local opener Blacklist Social, Saturday, August 30 of 2025, 7 PM to 1 AM** – To date, approximately 900 tickets have been sold, with tickets available for purchase. Doors open at 7 PM with entertainment starting at 8 PM. Please note that the Salty Basin Beer Garden will be closed to reset for the ticketed event at 5:30 PM.
- **Temporary Signage, Various Locations Thursday, August 29 to Tuesday, September 3 of 2025**- Signage for bus tours will be placed temporarily for the weekend. No sign will measure more than 2' by 1.5'.

Linkage to the Corporate Strategic Plan (Choose all that apply):

- ☐ No. 1 Safe and Reliable Infrastructure
☒ No. 2 Welcoming and Caring Community
☒ No. 3 Strong Local Economy
☐ No. 4 Good Government
☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

- ☐ Road Network
☐ Water Network
☐ Sanitary Network
☐ Storm Network
☐ Fleet
☐ Facilities
☐ Land Improvements
☐ Machinery and Equipment

And directly impacts (Choose all that apply):

- ☐ State of Good Repair/Replacement
☐ Municipal Levels of Service
☐ Risk Management
☐ Growth Impacts
☐ Financial Strategy

Financial Impacts and/or Source of Funding:

Is this cost budgeted for? Yes: ☒ No: ☐

Budget: Excess of revenues over expenses for event of \$19,020.00

Actual: No additional financial impact associated with this report

Consulted With:

Emma MacNeil, Tourism Event and Marketing Coordinator
 Deanna Hastie, Director of Corporate Services/Treasurer

Approved By:


Janice Hallahan, Chief Administrative Officer

Andrea Fisher, Director of Legislative Services/Clerk

Goderich Salt & Harvest Festival: Food Truck Village 2025


SOUTH ST

The Livery



Goderich Salt & Harvest Festival - Site Plan

[Tentative] 2025



OUR POTENTIAL OUR PURPOSE *

A CANADIAN TOURING EXPERIENCE

A vibrant, interactive experience where people of all ages can explore what it means to be a global citizen and imagine their role in a world full of potential.



Touring Canada from **coast to coast**



AGA KHAN FOUNDATION
CANADA



LET THE WORLD COME TO YOU

This **inspiring** and **memorable** experience introduces visitors to people from around the world who are overcoming obstacles – like inequality, a lack of opportunities for education, and climate change – to build a **better future** for themselves, their families, and their communities.

The exhibition is an opportunity for visitors to reflect on barriers they may also face – recognizing that no one can **overcome challenges** alone. Through **play**, **exploration**, and **conversation**, visitors discover what they can do as global citizens to bring about **positive change**, and leave empowered to become part of a **solution for a better world**.

Agenda Page 346 of 363

AT A GLANCE

- A **mobile, Canada-wide** experience
- **Youthful, inclusive** design
- Diverse voices highlighting the **power of global citizenship**
- Focused on the **potential within us all**
- A unique atmosphere with **rich textures, vibrant colors, and captivating media**

August 28 to
August 31, 2025

Festival Details

Concerts
& Shows

Unique Salted
Experiences

Rides &
Tours

GODERICH SALT & HARVEST FESTIVAL



EVENTS



CONCERTS & SHOWS

BIA THURSDAY NIGHT CONCERT WITH SAL'S ALLEY

Sal's Alley is a 5-piece Rock and Roll cover band from Goderich Ontario. Sponsored by the Goderich BIA! **Thurs. Aug. 28, 7PM Courthouse Square.**

BIA FRIDAY NIGHT CONCERT

Featuring Texas King, Harley Olivia, The Dyadics & Full Throttle. Sponsored by the Goderich BIA and Royal LePage Heartland Realty. **Fri. Aug. 29, 8PM - 12AM at the Salty Basin Beer Garden in Courthouse Square Park. \$10/each, tickets can be purchased at door or at saltedgoderich.ca. ALL AGES!**

SALT & HARVEST CEREMONY

Join us in celebrating our 3rd annual Salt & Harvest Festival! **Sat. Aug. 30, 10AM in Courthouse Square Park.**

COLDWELL BANKER AFTERNOON WITH GRAHAM BEDARD

Brought to you by Coldwell Banker, local legend Graham Bedard will be rockin' the Salty Basin Beer Garden with his guitar. **Sat. Aug. 30, 2PM - 5PM at the Salty Basin Beer Garden in Courthouse Square Park. FREE FOR ALL AGES!**

COMPASS MINERALS CONCERT WITH FINGER ELEVEN

The iconic, Juno award winning Canadian rock band is taking over The Square at this year's Festival. Tickets are going fast - get yours before they're gone! **Sat. Aug. 30, 7PM - 1AM at the Salty Basin Beer Garden in Courthouse Square Park. \$60+fees, online at saltedgoderich.ca. ALL AGES!**

BIA SUNDAY CONCERT - COUNTRY JUNCTION & BRYAN BICKNELL DUO

Sponsored by the Goderich BIA! **Sun. Aug. 31, 10AM-2PM at the Salty Basin Beer Garden in Courthouse Square Park. FREE!**

RIDES & TOURS

HOP-ON HOP-OFF BUS TOURS

Learn about the history of salt mining in Goderich and how salt mining has evolved over the decades! **Sat & Sun, 10AM - 4PM at Courthouse Square. \$10 for adults, \$4 for kids under 12. Tickets can be purchased at saltedgoderich.ca or during the event at the Festival store located on South Street Plaza.**

SALT HISTORY WALK AT ROTARY COVE LOOKOUT

Now even bigger! This beautiful solar-lit stroll overlooking the Rotary Cove features historical facts, photos of Goderich's salty past, and over 300 solar lights. **Available day & night.**

WAGON RIDES

Experience the charm of Goderich like never before through a horse-drawn wagon ride. Rides for up to 6! **Sat. & Sun., 10AM - 4PM at Courthouse Square. Sponsored by Royal LePage.**

INFLATABLES, PETTING ZOO & PHOTO BOOTH

Fun for the whole family! Make new friends - some with fur and some without. **Sat & Sun, 10AM - 4PM in Courthouse Square Park.**

EATS & TREATS

BIA THURSDAY NIGHT MARKET

Shop as the sun goes down! A variety of vendors with an abundance of wares. **Thurs. Aug. 28 from 4PM - 8PM in Courthouse Square Park.**

SALTED MARKET & FARMERS MARKET

Featured "salted" artisans and vendors will have the perfect memento for you to take home. **Sat & Sun, 9AM - 4PM in the Courthouse Square Park.**

FOOD TRUCK VILLAGE

An area for folks to park themselves and enjoy their meal. **Sat & Sun, 11AM - 7PM in the Livery parking lot.**

SALTY BASIN BEER GARDEN

In Courthouse Square Park, this ain't your average beer garden! Featuring crowd favourites, salted specialties & local brews. **Fri. Aug. 29: 7:30PM - 12:00AM
Sat. Aug. 30: 11:00AM - 5:00PM
Sun. Aug. 31: 11:00AM - 5:00PM**

DIY MARGARITA BAR

Within the Salty Basin Beer Garden, build the custom margarita of your dreams with unique flavours, twists and salted rims. Non-alc. options available! **Sat 11AM - 5PM, Sun 11AM - 2PM.**

SALTED EXPERIENCES

SALT MINE VIRTUAL REALITY EXPERIENCE

Put on your glasses and go below! Tour the mine while above ground with the help of VR. **Sat & Sun, 10AM - 4PM at the Goderich Tourism office.**

ABOVE GROUND SALT EXPERIENCE

Experience the salt mine from above ground in this fun, kid friendly experience like no other! **Sat & Sun, 10AM - 4PM in Courthouse Square Park.**

SALT INDUSTRY FILM

Learn about the operation of the worlds largest salt mine. Free entry included with Hop-on Hop-off Bus Tour! **Sat, 10AM - 4:30PM & Sun, 1PM - 4:30PM at the Huron County Museum.**

MINE RESCUE DEMONSTRATION

See and learn how Compass Minerals works to keep their employees safe down below! **Sat & Sun, 10AM - 4PM in Courthouse Square Park.**

Scan QR code to
purchase tickets &
learn more!



Our Festival Partners:



SALT2025 - Salt Walk Site Plan

Rotary Cove Lookout: Aug. 28 - Sept. 1



Illuminated pathway

History Signage

Salt industry history signage will follow water treatment plant fencing and be adhered with zip ties.

Salty Silent Auction

Auction Collection



Finger Eleven Meet and Greet

Starting Bid
\$200 (0 bids)

Ends In:
26 August 2025 10:00 AM

Time Left:
3 weeks

[View Auction](#)



Underground Tour for Three

Starting Bid
\$500 (0 bids)

Ends In:
26 August 2025 08:00 AM

Time Left:
3 weeks

[View Auction](#)



Salted Merchandise Package

Starting Bid
\$50 (0 bids)

Ends In:
26 August 2025 08:00 AM

Time Left:
3 weeks

[View Auction](#)

Staff Report

To: Mayor Bazinet and Members of Council
Report From: Emma MacNeil, Tourism Events and Marketing Coordinator
Meeting Date: August 11, 2025
Subject: Staff Report
Attachment(s): 1) Goderich Kinsmen Terry Fox Run - Sept.14 - Ltr2Council.pdf
2) GDCI Track Rebuild Road Hockey – Sept. 6 – Ltr2Council.pdf

Recommendation:

That Goderich Town Council receives this report for information;

And Further That Goderich Town Council approves the use of temporary signage for the upcoming Kinsmen Terry Fox Run/Walk;

And Further That Goderich Town Council grants permission to make use of amplified sound for the upcoming GDCI Track Rebuild Road Hockey Tournament.

Report Summary:

The Goderich Kinsmen Terry Fox Run/Walk, September 14, 2025, between 1 and 3 PM

Bringing their successful event back for another year, the Goderich Kinsmen are hosting the Terry Fox Run on Sunday, September 14. The route will be the same as previous years and will take runners on a tour around Goderich. Participants will use the sidewalks and designated crossings to facilitate safety for the event.

This event will be making use of temporary lawn signs to indicate the route.

GDCI Track Rebuild Road Hockey Tournament, September 6, 2025, 10 AM – 5 PM, GDCI

The GDCI Track Rebuild Committee has been working hard at organizing a Road Hockey Tournament. This event will take place on September 6, 2025, in the GDCI parking lot. The organizers will move the event indoors if it rains.

This event requests permission to make use of amplified noise.

Maitland Trail Association 2025 El Camino Hike Update

Due to the Menesetung Bridge closure, this year's event will not be in the Town of Goderich. They are looking forward to returning next year.

Linkage to the Corporate Strategic Plan:

- ☐ No. 1 Safe and Reliable Infrastructure
- ☒ No. 2 Welcoming and Caring Community
- ☐ No. 3 Strong Local Economy

- ☐ No. 4 Good Government
☐ No. 5 Environmental Stewardship

Linkage to Asset Management Plan:

This staff report is related to the following within the Town's Asset Management Program (Choose one):

- ☐ Road Network
☐ Water Network
☐ Sanitary Network
☐ Storm Network
☐ Fleet
☐ Facilities
☐ Land Improvements
☐ Machinery and Equipment

And directly impacts (Choose all that apply):

- ☐ State of Good Repair/Replacement
☐ Municipal Levels of Service
☐ Risk Management
☐ Growth Impacts
☐ Financial Strategy

Financial Impacts and/or Source of Funding:

No financial impact is associated with this report.

Consulted With:

Jenna Ujiye, Tourism and Community Development Manager

Approved By:

Janice Hallahan, Chief Administrative Officer
Andrea Fisher, Director of Legislative Services/Clerk

Goderich Town Council
Town of Goderich
57 West Street
Goderich ON N7A 2K5

July 28, 2025

Kinsmen Club of Goderich
PO Box 23
Goderich, ON N7A 3Y5
519-524-5113
gnay@hurontel.on.ca

RE: Request to Council


To the Members of Goderich Town Council,

I am writing you today on behalf of the Terry Fox Run taking place on September 15, 2024. I would like to make the following request regarding our upcoming event.

- Permission to hold the Run on September 14, 2025.
- Permission to place advertising signs on Town Property 7 days prior to the Run.

Thank you very much for your time and consideration.

Sincerely,

A handwritten signature in dark ink, appearing to read 'Grant Gnay'. The signature is fluid and cursive, with a long vertical line extending downwards from the end of the name.

Grant Gnay
Event Chairman

Goderich Town Council
Town of Goderich
57 West Street
Goderich ON N7A 2K5
Tuesday, July 29, 2024
Tara Regier
Goderich Track Rebuild Committee
toreilly11@gmail.com, 519-955-4641

RE: Request to Council

To the Members of Goderich Town Council,
We are writing you on behalf of the Goderich Track Rebuild Committee. We are planning to host a Road Hockey Tournament on September 6, 2025 between the hours of 10 and 5 at GDCI.

If possible, we would like to make the following request regarding our upcoming event; Permission to make use of amplified sound. We likely will no longer have live music but wish to play music on a speaker. We would also like to borrow 10 picnic tables and two road barricades to ensure cars do not enter the parking lot at GDCI where games will be played.

Thank you very much for your time and consideration. We hope to see you there!

Sincerely,

Tara Regier
Goderich Track Rebuild Committee

COMMUNITY SAFETY AND WELL-BEING for HURON OVERSIGHT COMMITTEE

MINUTES – July 16, 2025

1. Approval of Agenda

MOVED by: S. Jeffery

SECONDED by: M. Johnston

THAT the Agenda of July 16, 2025, be approved as presented.

CARRIED

2. Approval of Minutes of May 14, 2025

MOVED by: D. Logue

SECONDED by: M. Anderson

THAT the Minutes of May 14, 2025 be approved as presented.

CARRIED

3. Welcome to Guest: The Honourable MPP Lisa Thompson

Co-Chairs Anita Snobelen and Marg Anderson welcomed Minister Thompson to the meeting and thanked her for allowing us to discuss the benefits of the Community Safety and Well-Being Plan, and outlining the need for funding.

4. Delegations and Presentations

a. Community Safety and Well-Being for Huron Overview (A. Snobelen and M. Anderson)

Minister of Rural Affairs, Lisa Thompson, was in attendance at this meeting to learn about the Community Safety and Well-Being Plan for Huron and our ask for a sustainable funding model. Members shared information about the priority areas and how the Community Safety and Well-Being Plan for Huron has benefitted their organization or the work being done in the community. It was noted that although this is a mandated Plan, there has been no funding directly associated with the creation, maintenance, and implementation of the Plan. Municipal in-kind costs for administration of the Plan are approximately \$47,000. MPP Thompson noted that there is a ROD Grant which may be applicable and the Committee should submit an application for funding through this Grant. At 10:40 AM, MPP Thompson left the meeting to attend another function. She was provided with a handout summarizing the Plan and the request for funding (attached).

b. Tanner Steffler Foundation – Youth Advisory Council and Survey Results (Olivia Allen)

Olivia Allen presented findings from their 2024-2025 Youth Mental Health and Substance Use survey. Good discussion was had surrounding the findings and the full report can be found at www.tannerstefflerfoundation.com

c. Ontario Early Adversity and Resilience Framework (HPPH)

Angela Willert discussed the Ontario Early Adversity and Resilience Framework. It was noted that the Community Safety and Well-Being Plan for Huron fits well

within the framework under the focus area “Socially Connected, Equitable, and Inclusive Communities”. A 2-page summary can be found [HERE](#).

5. Welcome to New Members:

- a. Olivia Allen, Tanner Steffler Foundation, has joined the Oversight Committee as a guest member.
- b. Jessica Rudy, CAO, Huron East was welcomed as a member of the Oversight Committee after the recent resignation of Brad McRoberts.

6. Municipal Working Group Update/Action Items (S. Jeffery)

a. CSWB for Huron Plan Review

The CSWB for Huron Plan Review was completed prior to the July 1, 2025 deadline and is being formally adopted by each lower-tier municipality. The Review has been posted on www.cswbhuron.ca and will be filed with the Ministry, although filing is not mandatory.

b. Analytics for Domestic and Family Violence Campaign

M. Johnston shared Google Analytics from the Domestic and Family Violence Campaign. Of note:

- Website visits increased to 192,000 views
- Instagram ads were seen 612,200 times, with a reach of 111,900 unique individuals
- There were 13,755 post engagements
- The cost of the campaign was \$3,000 which was funded through a grant

7. Partner Updates – Roundtable

- a. C. Hardman, CMHA Huron-Perth, mentioned that on August 29, 2025 at 11:00 AM, there will be a flag raising at Goderich Town Hall in support of International Overdose Awareness Day (August 31). All are welcome.
- b. M. Nonkes, Huron County Immigration Partnership, noted that they have prepared a research report regarding housing in relation to Immigrants. Ten key findings are discussed in the report which can be found [HERE](#).
- c. D. Bozzato, Huron-Perth Centre, noted that the CHild and Youth Mental Health table will be meeting in person on September 30 in Mitchell. All are welcome to attend as they discuss their mandate for services for children 0 – 18 years.
- d. K. Clarke, Rural Response for Healthy Children, noted that on September 27, 2025, a 5 km Run for Kids will be held. In addition, a book study will be held during September on Saturdays re “The Anxious Generation”.

8. Website Updates

M. Johnston noted that the website had been updated to include the latest campaign social media posts as well as the Plan Review. Members are encouraged to review the website and forward any new information or sites to M. Johnston for inclusion.

9. Adjournment

MOVED by: R. Phillips

SECONDED by: E. Schooley

THAT the meeting be adjourned at 11:57 AM.

CARRIED

Next Meetings:

- August 5, 2025 at 10:30 AM – Housing and Homelessness Ad Hoc Committee (Zoom)
- July 23, 2025 at 2:30 PM – CSWB for Huron Municipal Working Group (Zoom)
- September 10, 2025 at 10:00 AM – CSWB for Huron Oversight Committee (Hybrid)
 - Commence Creation of 3 – 5 Year Action Plan

Attachments and/or Links for Informational Purposes:

- Analytics for Domestic and Family Violence Campaign
- TSF Youth Survey Results
[Youth Survey Results - TSF.pdf](#)
- Ontario Early Adversity and Resilience Framework:
<https://www.simcoemuskokahealth.org/Promos/Early-Adversity-and-Resilience>
- 2024 Housing and Homelessness Annual Report
<https://www.huroncounty.ca/wp-content/uploads/2025/05/2024-Housing-Homelessness-Annual-Report-May-14-2025.pdf>
- Housing First – Key Takeaways
<https://mentalhealthcommission.ca/resource/housing-first-whats-next/>
- Housing First Report
<https://mentalhealthcommission.ca/wp-content/uploads/2025/06/HousingFirstReport.pdf>

From: Kate Krouskie <misfitmeadow@gmail.com>

Sent: July 25, 2025 11:19 AM

To: Janice Hallahan <Jhallahan@goderich.ca>; Mayor Trevor Bazinet <tbazinet@goderich.ca>; Randy Carroll <rcarroll@goderich.ca>; John Thompson <jthompson@goderich.ca>; Leah Noel <lnoel@goderich.ca>; Liz Petrie <lpetrie@goderich.ca>; Vanessa Kelly <vkelly@goderich.ca>; Allison Segeren <asegeren@goderich.ca>; Andrea Fisher <afisher@goderich.ca>

Subject: Memorial Arena Proposal

Good morning everyone,

A group of concerned citizens would like the Town Staff and Council to address the following questions,

1. Do you have a detailed and fully costed/organized plan regarding how the Clubs plan to finance and operate the Memorial Arena? Do you have the financials for each Club that plans to partner? What if one or many fold or cannot fulfill their financial or other obligations? Who will carry the main control? What if they are unable to compromise and work together? Does the Town have any say in how it will operate?
2. Do you intend to proceed with the plans as set out in the GSP phases or are you considering something more economical like bringing other tax funded services under the same roof? This would reduce overhead and give the option of selling off other properties to reduce the tax burden.
3. How do you plan to fund the Maitland Rec's needs and the 1.3 million in maintenance that is going to be required while drawing down significantly on the Recreation Reserves to fund a similar building? Are we going to let Maitland Rec go into disrepair in order to salvage the Memorial Arena?
4. The Maitland Rec operates at a loss, the Airport Assessment confirms it is unlikely to break even. How is this going to be any different? What if there aren't any profits initially or ever going into the Reserve? Are you going to borrow from other reserve funds that are allocated for other purposes/projects?
5. What exactly are the Clubs offering to cover financially and what will the Town be responsible for over and above the \$140k and \$60k required in the first year and the further \$60k/year thereafter, such as ongoing maintenance, contributions for future phase upgrades etc.?

6. Has the pertinent information been provided to appropriate legal council and accountants familiar with such contracts as yet?

7. Are you really doing what is in the best interest of the Town or just a minority of the population and for political reasons? Have you truly considered the risk vs. rewards for everyone involved? What is the real exposure to taxpayers knowing that every \$100k is approximately a 1% tax increase and that our infrastructure is aging?

8. All of these questions and many more must be carefully considered and addressed prior to moving forward with this significant project. Failure to do so would simply be irresponsible.

We trust you will address each and every question above in the Town Council on Monday. If not please include this message on the next Meeting Agenda so it is part of the Record.

Sincerely,

People who wish to protect the Town and it's Citizens



July 21, 2025

The Honourable Michael Kerzner
Solicitor General of Ontario
25 Grosvenor Street, 18th Floor
Toronto, ON M7A 1Y6

SENT VIA EMAIL: Minister.SOLGEN@ontario.ca

RE: Request for Financial Support for Implementation of Community Safety and Well-Being Plan

Honourable Michael Kerzner,

Please be advised that at their Regular Council meeting held July 21, 2025, the Council of the Township of North Huron passed a resolution requesting Provincial funding for the long-term implementation and maintenance of the Community Safety and Well-Being Plan for Huron County.

As you are aware, the Province of Ontario has legislated for municipalities to develop, adopt, and undertake periodic updates to Community Safety and Well-Being Plans. These Plans outline strategies and actions to be implemented to improve safety and well-being for everyone in the community. Municipalities have welcomed this shift toward proactive, community-driven models of safety and well-being and we recognize the value of addressing the root causes of crime and social disorder through collaboration with health, education, housing and social services in our communities. However, the increased financial and administrative demands associated with implementing and sustaining these Plans has placed a disproportionate burden on municipal governments, especially smaller and rural municipalities with already limited budgets and staffing capacity.

We appreciate the leadership and vision behind the Community Safety and Well-Being Plans strategy and remain committed to its success. Sustained Provincial support is essential to ensure the successful realization of the intent of these Plans.

Regards,

Stephanie Reibel, Deputy Clerk/Planning Coordinator

c.c. The Honourable Lisa Thompson, MPP Huron-Bruce <lisa.thompsonco@pc.ola.org>
Carson Lamb, Director of Legislative Services/Clerk <clamb@northhuron.ca>
Community Safety and Well-Being Plan Working Group for Huron

P.O. Box 90, 274 Josephine Street, Wingham, Ontario N0G 2W0
Phone: 519-357-3550 Fax: 519-357-1110

From: Roderick Scapillati <scapillatirod@gmail.com>
Sent: Tuesday, August 5, 2025 9:03:33 AM
To: Mayor Trevor Bazinet <tbazinet@goderich.ca>; Leah Noel <lnoel@goderich.ca>; Randy Carroll <rcarroll@goderich.ca>; Liz Petrie <lpetrie@goderich.ca>; Allison Segeren <asegeren@goderich.ca>; John Thompson <jthompson@goderich.ca>; Vanessa Kelly <vkelly@goderich.ca>
Subject: Memorial Arena Demolition

Town of Goderich
Mayor Trevor Bazinet and Goderich Council

Greetings Mr. Mayor and Goderich Council,

Topic: Demolition of Goderich Memorial Arena

I ask that this letter be accepted as part of the minutes of the next Council meeting. Thank-you.

The Town of Goderich should demolish the Memorial Arena, preserve the historical items, rezone the site and parking lot as residential and place it on the real estate market.

The homes around the arena deserve a new environment from the chaotic parking and view of a 70 year old building that has served its intended use.

Injecting more money into the Goderich Memorial Arena is neglecting the engineers cautionary report.

Spending \$200 thousand or \$18 Million of taxpayers money for refurbishment of any kind is wrong and goes against the cautionary report on the Memorial Arena by B.M. Ross & Associates, Engineering Consultants.

The Town of Goderich, for many years, has been experiencing extreme difficulty with "replacing" sidewalk infrastructure that involves over 100 areas with multiple slabs of crumbling concrete in each area. Taxpayers/Voters are very observant because it's happening in front of their house in their neighbourhood.

The Town of Goderich and Council should move forward and the demolition will provide, along with rezoning, the transformation to a residential site that will blend in with the existing neighbourhood.

Any future development should be on the south side of the Goderich Huron YMCA sports complex at 190 Suncoast Drive East.

The new development in the future should be a small gymnasium no bigger than the one in the public elementary school to serve the shuffleboard enthusiasts and others etc.

The current ice surface at the YMCA is not collecting maximum earned income potential during available operational hours for future expansion.

Taxpayers should be reminded that at a Council meeting on Jan. 3, 2025, Goderich Council declared the Memorial Arena, ***“closed due to significant safety and accessibility concerns.”***

It would be irresponsible for the Mayor and Goderich Council to support any short or long term funding especially after reading the cautionary report on the Memorial Arena by B.M. Ross & Associates, Engineering Consultants.

Thanks for your time,
Rod Scapillati, scapillatirod@gmail.com
Goderich

From: Michael Bennie <mbenn76@hotmail.com>

Sent: July 31, 2025 12:32 PM

To: Mayor Trevor Bazinet <tbazinet@goderich.ca>; Leah Noel <lnoel@goderich.ca>; Randy Carroll <rcarroll@goderich.ca>; Liz Petrie <lpetrie@goderich.ca>; Allison Segeren <asegeren@goderich.ca>; John Thompson <jthompson@goderich.ca>; Vanessa Kelly <vkelly@goderich.ca>

Subject: Solid Fuel BBQing

Greetings Mr. Mayor, and Councillors,

I am reaching out in regards to the announcement that solid fuel BBQing will no longer be allowed at the beach. I had seen this announced some time back, but saw no signage or enforcement go in at the beach since that time. Then the announcement came that it would be effective "immediately", today.

My concern, respectfully, is in regards to the impact that this bylaw may have on our seasonal visitors to Goderich, and more specifically to the equity deserving groups who frequent our beach during the summer seasons. In my time spent at the water front I would argue that it is almost solely our summer visitors who are BBQing, and that the folks making use of the solid fuel or charcoal BBQs are the ones preparing "cultural" foods. My concern, again respectfully, is that the new bylaw, and it's enforcement will have the impact of making these folks feel targeted in our town; in combination with the incredibly unfortunate sign which still exists leaving out of town on Hwy 21.

I do not feel in any way that this was the intent of the bylaw, my concern is again, with it's impact. I have done a cursory search of council minutes and can not find where reasoning for the bylaw was given. I would imagine it is to help keep our waterfront clean and tidy. I would suggest that I have visited other parks where receptacles were made available for the disposal of ashes. I have been down to the beach early on Saturday and Sunday mornings, and have seen the overfilled garbage cans, and the trash left beside them. I wonder the possibility of having larger dumpsters available for folks to utilize, at one or both ends, similar to how provincial parks require you to dispose of trash and recycling.

I absolutely love the sights, sounds and smells of our waterfront diversity during summer season, and would hate for any of our guests to feel unwelcomed by this new bylaw and it's enforcement.

Regards,

Mike Bennie



THE CORPORATION OF THE TOWN OF GODERICH

BY-LAW NO. 119 OF 2025

**BEING A BY-LAW OF THE CORPORATION OF THE TOWN OF GODERICH
AUTHORIZING THE MUNICIPALITY TO UTILIZE THE DIRECT
ELECTRONIC FUNDS TRANSFER SERVICE OFFERED BY BMO BANK OF
MONTREAL**

WHEREAS the Corporation of the Town of Goderich currently has a contract to utilize the Direct Electronic Funds Transfer service offered by BMO Bank of Montreal to conduct business transactions on behalf of the municipality;

AND WHEREAS the BMO Bank of Montreal requires, as a result of the said service, a separate line of credit in the amount of \$500,000.00 to cover the banks contingent liability regarding credit disbursements processed utilizing this service;

AND WHEREAS By-Law 3 of 2025 authorizes the borrowing of required funds to meet the current expenditures of the municipality for the year 2025;

NOW, THEREFORE, THE COUNCIL OF THE CORPORATION OF THE TOWN OF GODERICH ENACTS AS FOLLOWS:

1. The Chief Administrative Officer and the Treasurer are hereby authorized on behalf of the Municipality to continue to utilize the Direct Electronic Funds Transfer service offered by BMO Bank of Montreal for the year 2025.

**READ A FIRST, SECOND, AND THIRD TIME AND FINALLY PASSED THIS
11TH DAY OF AUGUST 2025.**

MAYOR, Trevor Bazinet

CLERK, Andrea Fisher